

## Changes to the List of Materials

### June 24, 2025

1. Page U hv(1)
  - a. Added TELE-FONIKA Kable S.A.

### June 20, 2025

1. Pages w-1, eq(2.1), fm-1.1
  - a. Added Fiberglass Line Hardware.

### May 30, 2025

1. Pages Ugu-1.1, Ugu-2.1
  - a. Added API

### May 28, 2025

1. Page ea(4.1)
  - a. Added MacLean
    - i. H0 Series, H7 Series.

### May 8, 2025

1. Page av(2)
  - a. Added Copperweld

### April 22, 2025

1. Pages a(3), ea(4.1)
  - a. Added Preformed Line Products

### April 21, 2025

1. Pages rp-1.4
  - a. Added Preformed Line Products.

### February 13, 2025

1. Pages sj-1, sj(1)
  - a. Hubbell
    - i. Moved BP3 and BPF switches from Conditional page sj(1) to Full Listing page sj-1
    - ii. Deleted page sj(1)

### February 11, 2025

1. Page rp(1.5)
  - a. Added Power Grid Pros.

### February 4, 2025

1. page U ja-2
  - a. Added APS
    - i. FGBP Series

### January 23, 2025

1. Pages d-1, d-2
  - a. Line Hardware, Inc.
    - i. Added SWC Series, SWF Series
    - ii. Moved CSW Series to Technical List

December 17, 2024

1. Pages at-3, rp(1)
  - a. Added Central Moloney, Inc.

December 13, 2024

1. Page U he-1
  - a. Revised company name “Electrical Equipment” to “Federal Pacific.

October 31, 2024

1. Page av-1
  - a. Added Alubar

October 11, 2024

1. Pages z-3, z-5.1, z-6, z(5)
  - a. Added Street & Area Lighting (Salco)

June 11, 2024

1. Page k-2
  - a. Revised k(1) from Conditional to k-2 Full listings.
  - b. Added Hubbell Power Systems.

May 10, 2024

1. Pages x-1, z-5.2, z-6
  - a. Added Grip-Tite

April 2, 2024

1. Page be(4.3)
  - a. Added Togami Electric Mfg. Co., Ltd.
    - i. Single-phase and Three-phase.

March 22, 2024

1. Pages c-1; n-1
  - a. Moved Threaded Fasteners, Inc. from Conditional to Full Acceptance.

December 13, 2023

1. Pages u-1; aa, ab
  - a. Corrections to Allied Bolt catalog numbers.

December 5, 2023

1. Page af-1.1
  - a. Added IUSA
    - i. Type C (porcelain), Type C (polymer).

November 1, 2023

1. Page rp(1.4)
  - a. Added Celeco®

August 9, 2023

1. Pages bz-1, bz-2
  - a. Revised Maysteel Trinetics to Hubbell Trinetics.
  - b. Added VS models.

July 5, 2023

1. Page rp(1.3)
  - a. Revised Midsun Group, Inc.
    - i. Changed “E/Bushing Full Cover\*\*\*” to “E/Silicone Wildlife Covers\*\*\*”.

July 3, 2023

1. Page rp(1.3)
  - a. Added Midsun Group, Inc.
    - i. E/Flex Barrier\*, E/Anti-Nesting Barrier\*, E/Bushing Full Cover\*\*

March 27, 2023

1. Page z-5.1
  - a. Updated Hubbell catalog numbers.

March 5, 2023

1. Page g(1.3)
  - a. Revised Wagner listings to include both 8’ and 10’ arms.

March 1, 2023

1. Page g(1.3)
  - a. Added Wagners
    - i. Catalog numbers: WGN-S1000, WGN-S3000

November 29, 2022

1. Page be(2.3)
  - a. Added Siemens
    - i. CMR multi-phase recloser.

August 19, 2022

1. Page U hv(1)
  - a. Added LS Cable and System U.S.A., Inc.
    - i. (VI) Dow Endurance™ HFDC 4202 EC

July 26, 2022

1. Added page U hv-4
  - a. Cable, Underground, 600 Volt Cable (Alternative Cable Constructions)

May 24, 2022

1. Pages U he-1 and U he-2
  - a. Added Howard Industries.

April 13, 2022

1. Page eq(2.1)
  - a. Added Fiberglass Line Hardware
    - i. catalog numbers FLH0-1-15C1 and FLHR-1-15V.

March 25, 2022

1. Section ai – Ground Rods
  - a. Revised page numbering for consistency: page ai(1) changed to ai-4; page ai(3) changed to ai-5.

March 24, 2022

1. Page rp(1)
  - a. Added Kaddas
    - i. Catalog numbers KE1501, KE1182-03, KE1203, KE1077 Rev A, KE1079 Rev B, KE1198, KE1166-01.

#### February 18, 2022

1. Pages Uhb-1.2 and Uhb-2.2
  - a. Moved Richards from page Uhb-1.2 (200A rated) to Uhb-2.2 (600A rated).
  - b. Removed page Uhb-1.2.

#### February 15, 2022

1. Page p-11
  - a. Added Richards
    - i. Catalog numbers ABWC Series.
2. Pages Uhb-1.2 and Uhb-2
  - a. Moved Richards CSH Series from page Uhb-1.2 (200A) to Uhb-2 (600A).

#### December 2, 2021

1. Pages p-11, ap-1, ap-2
  - a. Added AFL.

#### August 3, 2021

1. Page be(2.3)
  - a. Added Siemens
    - i. CMR

#### May 6, 2021

1. Page Ugn-2
  - a. Added Aluma-Form
    - i. ENC Series

#### April 27, 2021

1. Page Ugk-2.2
  - a. Added Prysmian
    - i. PCT Series (15, 25, 35kV)

#### February 9, 2021

1. Page be(4.3)
  - a. Added Southern States single-phase SSR type recloser.

#### February 4, 2021

1. Pages rp(1), rp(1.2)
  - a. Revised “Cantega” to “Hubbell Power Systems”.
  - b. Added trademark to Reliaguard.

#### December 10, 2020

1. Page ap-2
  - a. Modified page number from “1.1” to “2”.

#### November 18, 2020

1. Pages an-3 and an(3.1)
  - a. Moved Virginia Transformer from page an(3.1) Conditional to page an-3 Full Acceptance.

November 6, 2020

1. Page ae-1
  - a. Added Celeco
    - i. Catalog Numbers: HSCEL, RPCEL

October 26, 2020

1. Page Uhb-1.1
  - a. Added TE Connectivity
    - i. Catalog Numbers: 25 kV, used with loadbreak connectors (without test point) - ELB-25-200 series without jacket seal, ELB-25-200-ES series with jacket seal

October 23, 2020

1. Page p(1)
  - a. Added TE Connectivity (Raychem)
    - i. Catalog number: TIL Series

September 30, 2020

1. Pages a(3), ea(4), ea(5) – Added new Hendrix insulator models.
  - a. Catalog Numbers: HPI-15VTC, HPI-15VTP, HPI-25VTC-02, HPI-35VTC-02, HPI-35VTP-02, HPI-LP-14FS/FA, HPI-LP-16F, HPI-CLP-15, HPI-CLP-17, HPI-CLP-20

July 7, 2020

1. Page cm-2 – Added Aluma-Form, Inc.

June 25, 2020

1. Page an(1.1) - Added additional kVA ratings for Prolec GE.
2. Page an(1.2) – Added Prolec GE for non-porcelain bushings.

May 21, 2020

1. Added Hubbell Power Systems
  - a. Page gj(3)

April 20, 2020

1. Pages sd-1.1, se-1.1
  - a. Added Instrument Transformer Equipment Corp (ITEC)

April 15, 2020

1. Pages cg-4
  - a. Revised “Bridges Electric” to “Siemens”.
  - b. Added note to Siemens:
    - i. applies to both polymer and porcelain insulators

March 27, 2020

1. Pages z(2)
  - a. Added Watson Anchor.

March 23, 2020

1. Page Uhb-1.2
  - a. Added Richards Manufacturing CS8 Series cold-shrinkable connector and CHS Series deadbreak elbow.

2. Page Ufz-1
  - a. Added Durham Company 9112212 250 Splice-n-Tap

#### March 13, 2020

1. Page av-1 Conductor, ACSR
  - a. Added WTEC

#### February 11, 2020

1. Added Centelsa
  - a. Page av-1 – Conductor, ACSR
  - b. Page U hv-2 – Cable, underground, 600V

#### February 10, 2020

1. Revised all references of “U-1” to “7 CFR 1728.204”.
  - a. Pages U hv-1, U hv-1.1, U hv(1).

#### February 7, 2020

1. Added SAE
  - a. Page dh-2 – Pole Ground, Alternative Materials
    - i. CD-2W-12, CD-2WC-12, CD-4C-12, CD-2C-12, CD-1/0C-12, CD-2/0C-12, CC25, CC55, CF7000

#### January 6, 2020

1. Added ConduGround
  - a. Page cj(1) - Pole Ground Wire, alternative conductor
  - b. Page sr(2) - Conductor for Substation Grounding, alternative conductor

#### December 26, 2019

1. Revised Malton to American Padmount Systems (APS) listings
  - a. Page Ugn-1
    - i. Remove MEV Series
  - b. Pages U gu-2.1, U ja-2
2. Revise Malton to ABB
  - a. Pages U he-1, U he-2, U he-3.2,

#### September 24, 2019

1. af – Cutout, distribution, open
  - a. Added Peak Demand Inc.
    - i. Catalog numbers: FCP series (porcelain) and FCS series (polymer).

#### September 9, 2019

1. w-1 Guy Strain Insulators, fiberglass
  - a. Added Preformed Line Products
    - i. GSF16 Series and GSF21 Series

#### August 16, 2019

1. be(4.3) – Recloser, vacuum interrupter with solid dielectric
  - a. Added Southern States
2. go-1 – Fault Indicators, overhead
  - a. Added Smart Grid Solutions

- i. FI-5A
- 3. Ugo-1 – Fault Indicators, underground
  - a. Added Smart Grid Solutions
    - i. FI-3C

#### July 18, 2019

- 1. ae-1 – Surge (lightning) Arrester, Distribution Class
  - a. Added Celeco
    - i. Model PSAMOV-HDDC

#### June 27, 2019

- 1. U go – Fault Indicators
  - a. Updated catalog number for Horstmann.
  - b. Added new Horstmann model 41-2001.

#### June 19, 2019

- 1. Uhv(1) Cable, underground
  - a. Added General Cable insulation:
    - i. (EAM) General Cable EI-4000-LF

#### May 15, 2019

- 1. ea(2) – Insulator, post type (Composite/Polymer)
  - a. Added new model from K-Line Insulators
    - i. KL 28SKG109 (24.9/14.4kV)
- 2. sb-2 – Switch, disconnect (single-pole, hook operated distribution class)
  - a. Added new model from Royal Switchgear
    - i. BISL – 15kV thru 25kV

#### May 14, 2019

- 1. z(5) – Power Installed Screw Anchors
  - a. Added Oklahoma Design Technologies, LLC
    - i. STAD Series and CSTAD Series

#### May 8, 2019

- 1. z(5) – Power Installed Screw Anchors
  - a. Added Cantsink
    - i. 1.5RCS Series
- 2. Uan(1) – Transformers, Distribution, Pad-Mounted, Dead-Front
  - a. Added Power Partners
    - i. Single-phase 5-167 kVA
- 3. Uhy-1.1 – Splice, Underground, Permanent
  - a. Added new units from TE Connectivity-Energy
    - i. Catalog numbers CSJU-1511, CSJU-S-1511, CSJU-2511, CSJU-S-2511

#### April 24, 2019

- 1. Uhv(1) – Cable Underground
  - a. Added LS Cable
    - i. VII insulation without flat strap neutral

#### April 19, 2019

- 1. be(2.2) Recloser, vacuum interrupter
  - a. Added Eaton

- i. Model NOVA-NXT.
- 2. Revised all “Cooper Power Systems” to “Eaton”.

#### April 10, 2019

- 3. Uhb-1.1 – Cable Accessories
  - a. Added TE Connectivity-Energy
    - i. Models ELB-15-200 and ELB-15-200-ES.

#### November 28, 2018

- 1. y(3) - Conzinal 95% Zinc - 5% Aluminum+ Mischmetal Alloy (AL-ZN-MM) Coated Steel Wire Strands
  - a. Added Conex Cable LLC

#### November 2, 2018

- 1. y(2) - Zinc - 5% Aluminum - Mischmetal alloy (Zn-5Al-MM) – Coated, Steel Wire Strands
  - a. Revised existing listing for Bekaert.
    - i. Added additional wire sizes.
      - 1. (S-M): 1/4", 3/8", & 7/16".
      - 2. (HS): 9/32".
      - 3. (EHS): 9/32".
    - ii. Revised Note to “Class A” coating.

#### October 23, 2018

- 1. sj(1) – Switches, oil circuit recloser by-pass
  - a. Added Hubbell (Chance)
    - i. Type: BPF – 15kV, 27kV
- 2. sb-2 – Switch, disconnect (single-pole, hook operated distribution class)
  - a. Added Hubbell (Chance)
    - i. Type: M3C – 15kV, 27kV

#### August 31, 2018

- 1. cj-1 Pole Ground Wire
  - a. Added sizes for Copperweld Bimetallics, LLC
    - i. No 4 AWG Stranded (7x0680”), No. 4 AWG, No. 2 AWG Stranded (7x0860”), No. 2 AWG, 7 No. 10 AWG, 2/0 (19x0860” & 7x1379”)
  - b. Revised notes referring to Copperweld Bimetallics, LLC
- 2. sr-1 Steel Conductor for Substation Grounding, Copper-Clad or Galvanized
  - a. Moved from Conditional [sr(1)] to Full listing [sr-1] Copperweld Bimetallics, LLC
    - i. 7 no 8 AWG, 2/0 (19x0860” & 7x1379”), 7 no 7 AWG, 7 no 6 AWG, 7 no 5 AWG, 7 no 4 AWG, 4/0 (19x1055”), 19 no 9 AWG, 19 no 8 AWG, 19 no 7 AWG, 19 no 6 AWG, 19 no 5 AWG
  - b. Updated notes referring to Copperweld Bimetallics, LLC.

#### July 31, 2018

- 1. af(1) - Cutouts, Distribution, Open with Linkbreak Attachment
  - a. Added Hubbell C-Polymer 27kv and 35kV.

#### July 20, 2018

- 1. Uhv-1
  - a. Removed all listings for Crosslinked Polyethylene (XLP).
    - i. Plain XLP is no longer an acceptable insulation per RUS standards, [7 CFR 1728F.204](#) (formerly the U-1 spec).

#### July 18, 2018



1. UHV(1) Cable, underground
  - a. Added General Cable new tree retardant insulation compound LG XL8080TR (VII).
  - b. Added LS Cable & Systems (VIII).

#### June 12, 2018

1. c-1 Machine Bolts; o-1 Oval Eye Bolts
  - a. Added Action Manufacturing

#### May 21, 2018

1. a-2 Insulators, Pin type, polymber
  - a. Added Aluma-Form
    - i. Catalog numbers INS-15-PC-1, 55-3; INS-15-PF-1 55-4; INS-25-PJ-2

#### May 8, 2018

1. Page rp(1.2) Wildlife Guards
  - a. Added Reliaguard

#### March 20, 2018

1. Page g(1.3) Crossarms, fiberglass
  - a. Added new Shakespeare models
    - i. Without centermount: MTN, HTN, TTN
    - ii. With centermount: STB, MTB, HTB, TTB

#### March 19, 2018

1. Page sd-1 Current Transformers, Outdoor Type
  - a. Added new models for Arteché
    - i. Catalog numbers for 0.6kV: IRH-1
    - ii. Catalog numbers for 15kV: ME-015, MK-15, MI-015, KM-15, KCB-17
    - iii. Catalog numbers for 25kV: ME-025, MK-25, MI-025, KM-25, KCB-24
    - iv. Catalog numbers for 34.5kV: CRK-36, CE-034, ME-036, MK-36, KM-36
    - v. Catalog numbers for 69kV: CRH-72, CRK-72, CE-069
2. Page se-1 Voltage Transformers, Outdoor Type
  - a. Added new models for Arteché
    - i. Catalog numbers for 15kV: URJ-17, ME-015, MK-15, MI-015, KM-15, KCB-17
    - ii. Catalog numbers for 25kV: URJ-24, VRJ-24, URN-24, VRN-24, ME-025, MK-25, MI-025, KM-25, KCB-24
    - iii. Catalog numbers for 34.5kV: ME-036, MK-36, KM-36
    - iv. Catalog numbers for 69kV: URU-72, VRU-72

#### March 9, 2018

1. Page al(1) Ground Wire Staples
  - a. Added Fasco
    - i. Catalog numbers: EF40-315, EF40-315CU

#### March 8, 2018

1. Page U gu-1.1 Pedestal, Power (Above-Grade)
  - a. Added Nordic Fiberglass additional sizes.
    - i. Catalog numbers: PSPX-101830-MG, PHH-152315-MG

#### February 2, 2018

1. Page n-1 – Bolt, double arming
  - a. Added Action Manufacturing

#### December 4, 2017

1. Page z-6 Anchors, Power-Installed Screw, Distribution
  - a. Added new units to Hubbell (Chance)
    - i. Catalog numbers: C1025006, C1025007, C1025010.

November 17, 2017

2. Page ap-1.1 Clamp, hot line, ACSR with armor rods
  - a. Added Aluma-Form
    - i. Catalog numbers: AF-BC20, AF-1540, AF-1530

November 2, 2017

1. Page U hv(1) U hv - Cable, Underground, 15 kV and 25 kV Cable
  - a. Revised company name “Superior Essex” to “LS Cable & System U.S.A., Inc.”

September 12, 2017

1. Added Page sj(1) Switches, oil circuit recloser by-pass
  - a. Added Hubbell (Chance)
    - i. Catalog number: BP3 – 600A, 900A

September 8, 2017

1. Page cj-1 Pole Ground Wire
  - a. Revised “CommScope BiMetals” to “AFL Copperclad”
    - i. Added sizes No. 4 and No. 2
2. Page sr-1 Steel Conductor for Substation Grounding, Copper-Clad or Galvanized
  - a. Revised “CommScope BiMetals” to “AFL Copperclad”
    - i. Added sizes 19 No. 9 AWG and 19 No. 8 AWG

July 21, 2017

3. Page U he-3.1 Padmounted Switchgear (200 and 600 amp)
  - a. Added Elastimold
    - i. Type MVS, single-phase and three phase, 200 and 600 amp, 15-38 kV
    - ii. Type MVI, single-phase and three phase, 200 and 600 amp, 15-38 kV

July 19, 2017

4. Page ah-1 Tie, insulator, formed type
  - a. Added “Alloy Side, Spool and Top Ties” to Preformed Line Products
5. Added Page ea-3 Insulators, post type
  - a. Added Eprecsa USA, LLC
    - i. catalog numbers: 13PD, 22PD, 33PD

July 7, 2017

6. Page ah-1 Tie, insulator, formed type
  - a. Added 3 new products to Preformed Line Products
    - i. EZST-series, TT-series and UT-series

June 20, 2017

1. Page sd-1 Current Transformers, outdoor type
  - a. Revised company name to “Arteche” from “Arteche USA”.
  - b. Added CRF-17 and CRH-36, which were omitted from the original listing.
2. Page se-1 Voltage Transformers, outdoor type
  - a. Revised company name to “Arteche” from “Arteche USA”.

May 1, 2017

1. Page bx-1.1 Splice, automatic, Distribution
  - a. Added 2 new splices to Aluma-Form, Inc. listing.
    - i. Cat. #: ASC1020
      1. AAC (1/0 & 2/0), AAAC (1/0 & 2/0), and ACSR (1/0 & 2/0)
    - ii. Cat. # ASC3040
      1. AAC (3/0 & 4/0), AAAC (3/0 & 4/0), and ACSR (3/0 & 4/0)

April 26, 2017

1. Pages ah-1 and ah(1) Tie, insulator, formed type
  - a. Moved Preformed Line Products “EZ-WRAP” ties from Conditional listing on page ah(1) to Full listing on page ah-1.

April 25, 2017

1. Page Uan-1 Transformers, Distribution, Pad-Mounted, Dead-Front
  - a. Added Magnetron S.A.S.
    - i. Pad mounted 5-167 kVA transformer series.

# **LIST OF MATERIALS**

## **Acceptable for Use on Systems of USDA Rural Development Electrification Borrowers**

**United States Department of Agriculture  
Rural Development Utilities Programs  
Electric Programs**

**Informational Publication 202-1  
Current as of June 24, 2025**

### **DISCLAIMER**

*Every effort has been made to ensure the accuracy of this document.  
However, in case of discrepancies, records of Technical Standards  
Committee "A" are the authoritative source.*

## PREFACE

This list supersedes all preceding issues including revisions. Revised sheets reflecting changes in the list will be issued quarterly and should be inserted in order to keep your copy up to date.

The items shown in this publication include material and equipment for transmission and distribution facilities. Items not listed include office equipment, tools and work equipment, items of electric general plant and consumer owned wiring facilities. The listings apply only to new items of material and equipment and not to used items.

In addition to items accepted on a general basis, this list also includes items accepted on a conditional basis. As one of the conditions in the acceptance of an item on a conditional basis, contractors are required to obtain the borrower's concurrence prior to its use.

The inclusion of an item in this list does not indicate that item's manufacturer or its principals have not been debarred, suspended, proposed for debarment, declared ineligible or voluntarily excluded pursuant to Executive Order 12549, Debarment or Suspension, or any rules or regulations issued thereunder, including 7 CFR Part 3017 ("Debarment Regulations"). Therefore, borrowers must comply with the requirements imposed by the Debarment Regulations before entering into any "covered transaction", as defined by 7 CFR Part 3017, involving any item on this list.

The acceptance of an additional item or the deletion of an existing item is a function of the Technical Standards Committees. Any manufacturer desiring to have a new item placed on the list, or any user believing an existing item should be removed from the list, is invited to submit the matter to the Committees. Any communication calling attention to an error or omission in the list, such as a wrong catalog number, an obsolete item, etc., will be appreciated. All communications should be addressed to Technical Standards Committee "A" (Electric), USDA Rural Development Utilities Programs, Stop 1569, Washington, D. C. 20250-1569.

## INDEX – PART I

### **-A-**

Air break switches .....	cg
Anchor rod .....	x
Anchor rod bonding clamps .....	ck
Anchor shackle .....	bo
Anchors .....	z
Angle suspension bracket .....	cr
Angle thimble eye bolt .....	ba
Anodes .....	U si
Arm assemblies, narrow profile .....	eq
Armor grip suspension assembly .....	m
Armor grip suspension assembly with socket eye .....	ei
Armor rods .....	bv
Arms, laminated upswept .....	fq
Arresters, surge .....	ae
Automatic and formed type deadends .....	by
Automatic splices .....	bx

### **-B-**

Ball hook .....	eh
Ball, oval eye .....	fp
Ball, Y-clevis .....	ft
Bolt, angle eye (thimble type) .....	ba
carriage .....	i
clevis .....	ef
double arming .....	n
double upset .....	q
oval eye .....	o
eye double arming .....	dy
machine .....	c
shoulder eye .....	o
single upset .....	bs
thimble eye, angle .....	ba
straight eye (thimble eye) .....	ao
Brace, crossarm, steel .....	h
crossarm, fiber reinforced plastic .....	cu
crossarm, wood .....	cu
sidearm diagonal .....	ac
sidearm vertical .....	bb
special crossarm .....	em
Bracket, angle suspension .....	cr
cutout and arrester extension .....	fm
cutout extension .....	fn
extension .....	fj
insulated .....	da
narrow profile .....	eq
offset neutral .....	ec
oil circuit recloser .....	fk
pole top pin .....	cs
post insulator .....	eb
swinging angle .....	fu
transformer .....	dm
transformer secondary insulated .....	fo

Capacitor hangers.....	fd
Capacitor oil switch .....	bz
Capacitor, shunt.....	fc
Carriage bolt.....	i
Chain link (end link).....	br
Clamp, anchor rod bonding.....	ck
deadend .....	l
deadend with socket eye.....	ej
ground rod.....	aj
ground wire .....	dp
guy.....	u
hot line.....	ap
loop deadend .....	bn
suspension .....	m
suspension with socket eye .....	ei
Clevis bolt.....	ef
Clevis type wireholder .....	bt
Clevis, conduit, insulated .....	dr
secondary swinging.....	s
service deadend .....	bh
service swinging.....	as
thimble.....	ci
Clip, ground wire .....	al
guy.....	dz
Combination cutout and arrester.....	ax
Combination power fuse and disconnect switch .....	sl
Compression deadends .....	cp
Compression splices .....	cy
Conductor.....	av
Conduit clevis, insulated .....	dr
Conduit wireholder .....	ds
Connector, grounding, transformer .....	bu
hot line.....	fi
Connectors.....	p
Cross brace assembly.....	vx
Crossarm assemblies and arm spacers.....	gj
Crossarm assembly, "Z" type (wishbone) .....	gz
Crossarm assembly, H frame (small angle – 161 & 230 kV).....	gw
Crossarm assembly, H frame (tangent – 161 & 230 kV) .....	gy
Crossarm brace, sidearm diagonal .....	ac
Crossarm brace, sidearm vertical .....	bb
Crossarm brace, special .....	em
Crossarm brace, steel .....	h
Crossarm brace, wood .....	cu
Crossarm pin, steel .....	f
Crossarm reinforcing plate .....	eg
Crossarm saddle .....	fg
Crossarms .....	g
Current limiting backup fuses.....	ag
Current transformers .....	sd
Cutout and arrester extension bracket.....	fm
Cutout and arrester, combination.....	ax
Cutout extension bracket .....	fn
Cutouts and fuses .....	af

-D-

Deadend clamp .....	l
Deadend clamp with socket eye .....	ej
Deadend for guy strand.....	u
Deadend for steel strand.....	l
Deadend, automatic & formed type .....	by
compression.....	cp
secondary.....	cq
service.....	dt
Disconnect switch, hook operated .....	sb
Double arming bolt .....	n
Double arming eye bolt .....	dy
Double arming plate .....	ct
Double upset bolt .....	q

-E-

Elliptical eye screw.....	dq
End link (chain link).....	br
Extension link .....	du
Extension link (fiberglass) .....	eu
Eye bolt, double arming .....	dy
oval.....	o
Eye nut .....	aa
Eye screw, elliptical.....	dq

-F-

Fault Indicators.....	go
Fiber reinforced plastic crossarm braces .....	cu
Fuses and cutouts.....	af
Fuses, current limiting, backup .....	ag
power, substation .....	af

-G-

Gain, pole.....	bi
Grid gain.....	bi
Ground rod clamp .....	aj
Ground rods .....	ai
Ground wire clamp .....	dp
Ground wire clip .....	al
Ground wire staple .....	al
Ground wire support, overhead .....	ed
Ground wire, pole.....	cj
Ground, pole .....	dh
Grounding conductor, substation, coated steel .....	sr
Grounding connector, transformer .....	bu
Guy attachment (Distribution) .....	v
Guy attachment (Transmission).....	fv
Guy clamp .....	u
Guy clip .....	dz
Guy deadend.....	u
Guy hook.....	bj
Guy marker.....	at
Guy plate .....	bk



Guy strain insulator .....	w
Guy wire .....	y
Guy wire clip.....	dz
Guying plate .....	fv

#### -H-

H frame crossarm assembly (small angle – 161 & 230 kV).....	gw
H frame crossarm assembly (tangent – 161 & 230 kV) .....	gy
Hangers, capacitor .....	fd
Hook, ball .....	eh
guy.....	bj
Hook operated disconnect switch .....	sb
Hot line clamp .....	ap
Hot line connector .....	fi

#### -I-

Insulated bracket.....	da
Insulator and stud, post type .....	ea
Insulator, guy strain .....	w
pin type.....	a
polymer distribution deadend.....	k
spool.....	cm
suspension .....	k

#### -K-

Keys, pole.....	z
-----------------	---

#### -L-

Laminated upswept arms .....	fq
Lag screw .....	j
Link, chain (end link) .....	br
extension .....	du
extension (fiberglass).....	eu
Locknuts .....	ek
Loop deadend clamp.....	bn

#### -M-

Machine bolt.....	c
Marker, guy .....	at
Meter sockets .....	gb
Meters, watthour .....	ga

#### -N-

Narrow profile brackets and arm assemblies.....	eq
Neutral bracket, offset.....	ec
Numbers, pole and letters .....	az
Nut, eye .....	aa
thimble eye.....	ab

-O-

Offset neutral bracket.....	ec
Oil circuit recloser bracket.....	fk
Oil circuit reclosers .....	be
Oval eye ball .....	fp
Oval eye bolt .....	o
Oval tube splice.....	cx
Overhead ground wire support .....	ed

-P-

Pin type insulator.....	a
Pin, crossarm .....	f
pole top, steel.....	b
Pipe spacer .....	dl
Plastic wire guard.....	er
Plate, crossarm reinforcing .....	eg
double arming .....	ct
guy.....	bk
pole bearing .....	fs
pole eye.....	v
Pole bearing plate .....	fs
Pole eye plate .....	v
Pole gain .....	bi
Pole ground .....	dh
Pole ground wire .....	cj
Pole keys.....	z
Pole numbers and letters .....	az
Pole top pin bracket .....	cs
Pole top pin, steel.....	b
Post insulator bracket.....	eb
Post type insulator and stud.....	ea
Power fuses, substation .....	af
Primary metering rack .....	fl

-R-

Rack, primary metering .....	fl
Reclosers, automatic circuit .....	be
Regulator by-pass switch.....	sk
Regulators, voltage .....	sc
Rod, anchor.....	x
Rods, armor .....	bv
ground .....	ai

-S-

Saddle crossarm .....	fg
Screw, elliptical eye.....	dq
lag.....	j
Secondary swinging clevis.....	s
Sectional ground rods .....	ai
Sectionalizer.....	el
Service deadend .....	dt
Service deadend clevis .....	bh
Service swinging clevis .....	as

Shackle, anchor .....	bo
Shoulder eye bolt .....	o
Shunt capacitors .....	fc
Sidearm diagonal crossarm brace .....	ac
Sidearm vertical crossarm brace .....	bb
Single upset bolt.....	bs
Sockets, meter .....	gb
Spacer, pipe .....	dl
Special crossarm braces.....	em
Splice cover, plastic .....	es
Splice for steel strand.....	cz
Splice, automatic.....	bx
compression .....	cy
formed type .....	ex
oval tube.....	cx
Spool Insulator .....	cm
Spring washer .....	aw
Staple, ground wire .....	al
Steel strand .....	y
Structure assembly (small angle – 161 & 230 kV).....	gw
Structure assembly (tangent – 161 & 230 kV) .....	gy
Substation grounding conductor, coated steel.....	sr
Support, overhead ground wire.....	ed
Surge arresters .....	ae
Suspension clamp.....	m
Suspension clamp with socket eye .....	ei
Suspension insulator.....	k
Swinging angle bracket.....	fu
Switch, capacitor oil .....	bz
combination power fuse and disconnect.....	sl
hook operated disconnect.....	sb
pole top air break .....	cg
recloser, by-pass.....	sj
regulator by-pass .....	sk

-T-

Thimble clevises.....	ci
Thimble eye bolt, angle .....	ba
Thimble eye bolt, straight.....	ao
Thimble eye nut.....	ab
Tie, insulator, formed type.....	ah
Transformer bracket.....	dm
Transformer grounding connector.....	bu
Transformer secondary bracket, insulated.....	fo
Transformers, current.....	sd
pole and power.....	an
voltage.....	se

-V-

Vacuum circuit reclosers .....	be
Voltage regulators .....	sc
Voltage transformers.....	se

-W-

Washer, spring .....	aw
Washers .....	d
Watthour meters.....	ga
Wildlife guards.....	rp
Wire guard, plastic .....	er
Wire, guy .....	y
Wireholder .....	ar
Wireholder, clevis type .....	bt
conduit.....	ds
Wood crossarm brace .....	cu

-Y-

Y-clevis ball .....	ft
---------------------	----

-Z-

“Z” type (wishbone) crossarm assembly .....	gz
---	----

## INDEX – PART II

### Underground Distribution Equipment

Anodes .....	U si
Arrester, surge .....	U ae
Boot, insulated .....	U gq
Bracket, combination.....	U hj
pothead mounting .....	U hd
Cable .....	U hv
Cable accessories .....	U hb
Cable route marker .....	U hx
Cable support.....	U hc
Combination cutout and arrester.....	U ax
Connector block, secondary.....	U gp
transformer .....	U fz
Connector, secondary tap .....	U fw
Cutout and arrester, combination.....	U ax
Enclosure, equipment .....	U gn
Fault indicator.....	U go
Heat shrink tubing .....	U hr
Jacketed cable restoration kits.....	U hf
Pad, equipment .....	U ja
Pedestal, power .....	U gu
Recloser, pad-mounted.....	U be
Regulator, voltage, pad-mounted.....	U sc
Safety signs.....	U hw
Secondary tap connector .....	U fw
Secondary tap or splice cover.....	U hr
Shield, cable riser.....	U gc
splice .....	U jb
Splice shield .....	U jb
Splice, secondary .....	U gp
underground.....	U hy
Stake, power pedestal.....	U gv
Switch, air, group-operated .....	U cg
Switchgear, padmounted .....	U he
Terminations, elbow .....	U hp
multipoint.....	U hq
outdoor and indoor .....	U gk
Terminator sealing kit.....	U hf
Transformer connector block .....	U fz
Transformer pad.....	U ja
Transformer, current .....	U sd
Transformers .....	U an
Tubing, heat shrink.....	U hr

a – Insulator, pin type, porcelain

ANSI Class Application	55-2 5 kV	55-3 12.5/7.2 kV and 13.2/7.62 kV systems	55-4 12.5/7.2 kV and 13.2/7.62 kV systems (where greater insulation is needed)
Pinhole diameter	1 in.	1 in.	1 in.
ICB Porcelain Products (Knox) <sup>2</sup> Victor Insulators, Inc. Gamma Insulators Corp.	ICB 552 253 8 6188R-70	ICB 553 261-S 5, VI 605R 6184R-70	ICB 554 366-S 6, VI 606R 6183R-70
ANSI Class Application	56-1 24.9/14.4 kV distribution lines	56-3 33 – 34.5 kV transmission lines	56-4 44 – 46 kV transmission lines
Pinhole diameter	1-3/8 in. Metal thimble (unless noted)	1-3/8 in. Metal thimble	1-3/8 in. Metal thimble
ICB Groupo IUSA <sup>1</sup> Porcelain Products (Knox) Victor Insulators, Inc. Gamma Insulators Corp.	ICB 561 P-3000 - 27-R <sup>1</sup> , VI 627R 8248R-70	- - 2045-S 245-R, VI 645R 8190R-70	- - - 255-R -

<sup>1</sup>Does not have a metal thimble.

<sup>2</sup>ANSI class 55-2, 55-3, and 55-4 pin insulators manufactured at both the Knoxville and Macomb plants are acceptable.

a – Insulators, pin type, polymer

Manufacturer	Catalog Number	ANSI Class
Advanced Rubber Products	ARP-SKPI-55-3	55-3
	ARP-SKPI-56-1	56-1
Aluma-Form	INS-15-PC-1	55-3
	INS-15-PF-1	55-4
	INS-25-PH-2	56-1
Hendrix	HPI-55-3	55-3
	HPI-55-4	55-4
	HPI-25-J-02	56-1
Preformed Line Products	IP-15-C	55-3
	IP-15-F	55-4
	IP-25-J2	56-1

a(3)  
April 22, 2025

a – Insulators, pin type, composite, vise top

Manufacturer	Catalog Number	ANSI Class	Conditions
<u>Hendrix</u>	HPI-15VTC	55-4	To Obtain Experience. For use with Conductor Diameters of 1.75 inches or less.
	HPI-15VTP	55-4	
	HPI-25VTC-02	56-1	
	HPI-35VTC-02	55-7	
	HPI-35VTP-02	55-7	
<u>Preformed Line Products</u>	IP-15-VTU	55-3, 55-4	To Obtain Experience.
	IP-15-VTN	55-3, 55-4	
	IP-15-VTC	55-3, 55-4	
	IP-15-PVTU	55-3, 55-4	
	IP-15-PVTN	55-3, 55-4	
	IP-15-PVTC	55-3, 55-4	
	IP-25-VTU2	56-1	
	IP-25-VTN2	56-1	
	IP-25-VTC2	56-1	
	IP-25-PVTU2	56-1	
	IP-25-PVTN2	56-1	
	IP-25-PVTC2	56-1	
	IP-35-VTU2	55-7	
	IP-35-VTN2	55-7	
	IP-35-VTC2	55-7	
	IP-35-PVTU2	55-7	
	IP-35-PVTN2	55-7	
	IP-35-PVTC2	55-7	



b – Pin, pole top, steel

#### DISTRIBUTION

	12.5/7.2 or 13.2/7.62 kV	24.9/14.4 kV
Pin length, inches:	20	20
Thread diameter, inches:	1	1-3/8
Hole spacing, inches:	8	8
RUS Specification:	D-3	DT-3
Hubbell (Chance)	2199	2195
Joslyn	J740	J720
Kortick	-	K8086
MacLean (Continental)	U36606F-REA	U36652

Pins listed below have 4-1/2" offset which eliminates the use of Item cs

Hubbell (Chance)	C206-0271
Joslyn	J25179
MacLean (Continental)	U36549

#### TRANSMISSION

Pin Length, inches:	24
Thread diameter, inches:	1-3/8
Hole spacing, inches:	8
RUS Specification:	DT-3
Hubbell (Chance)	2196
Kortick	K8087
MacLean (Continental)	U36653F

#### NOTE

1. Flared type pins may be mounted with either side against the pole.

b – Pin, pole-top  
(Non-lead threads)

Manufacturer	Conditions
Hubbell Power Systems 2195P (1-3/8" threads) 2199P (1" threads)	To obtain experience.
Hughes Brothers 2770-A20-100 (1" threads) 2770-A20-130 (1-3/8" threads)	To obtain experience.
Joslyn J740Z (1" threads) J720Z (1-3/8" threads)	To obtain experience.

b – Pin, Fiber-reinforced plastic pole top

Manufacturer	Conditions
Joslyn 7581-624NT (1" threads)* 7581-624XNT (1-3/8" threads)* * Add suffix LT (less tabs) if for steel pole.	To obtain experience.

c – Bolt, machine

Applicable Specification: ANSI C135.1, “Standards for Galvanized Steel Bolts and Nuts” except that the lengths are in the ranges given below.

Applicable Sizes:                    ½-inch diameter, 6 through 10-inch length  
    5/8-inch diameter, 6 through 24-inch length  
    ¾-inch diameter, 6 through 26-inch length  
    7/8-inch diameter, 6 through 28-inch length

The following manufacturers have shown compliance with the applicable specifications for machine bolts:

Action Manufacturing  
Allied Bolt, Inc.  
Hughes Brothers  
\* Joslyn Manufacturing Company  
Kortick Manufacturing Company  
MacLean (Continental)  
\* Portland Bolt & Manufacturing Company  
The Rockford Bolt & Steel Company  
Steel City Bolt & Screw Co., Inc.  
Threaded Fasteners, Inc.

\*\*Static proof” design available.

d – Washers, Flat

Flat Rolled Steel

Size, inches: Thickness, in.: Hole Diam., in.:	2-1/4 x 2-1/4 3/16 13/16	3 x 3 1/4 13/16	4 x 4 3/16 13/16	4 x 4 1/2 13/16	1-3/8 round 12 gauge 9/16	1-3/4 round 10 gauge 11/16
Allied Bolt, Inc.	11550	11551	11557	-	104	1103
C & C Spacer	4	-	-	-	-	-
FWC	FW1076	-	FW1080	-	FW1086	FW1088
Hubbell (Chance)	6814	6817	6818	6819-1/2	6803	6805
Hughes	SW2-1/4-70-3/16	SW3-70	SW4-70	SW4-70(1/2)	RW1-3/8-50	-
Joslyn	J1076	J1079	J1080	-	J1086	J1088
Kortick	K1553	K1555	K1557	K1559-1/2	K1524	K1525
Line Hardware	SWF Series	SWF Series	SWF Series	-	-	-
MacLean (Continental)	U5485	U5487A	U5488	U5490A	U5478	U5479
Wrought Washer	011206	-	-	-	-	-

Flat Cast

Size, inches: Thickness, in.: Hole Diam., in.:	3 x 3 1/4 13/16
Hubbell (Chance) (N)	BB214
Joslyn (Flagg) (N)	P56A

Spurred – 3" Round, 3/16" Thick, 13/16" Hole

MacLean (Continental)	TCSF-30-6
-----------------------	-----------

(A) Aluminum Alloy

(M) Malleable Iron

(N) Nodular Iron

d – Washers, Curved

Curved Cast

Size, inches:	2-1/4 x 2-1/4	3 x 3	3 x 4	4 x 4
Thickness, in.:	1/4	5/16	7/16	1/2
Hole Diam., in.:	11/16	11/16	15/16	13/16
Hubbell (Chance) (N)	GCW1A	GCW31	CRW4A	GCW41
Joslyn (Flagg) (M)	P141	P143	P120	P144
Line Hardware (M)	SWC Series	SWC Series	SWC Series	SWC Series
MacLean (Bethea)	-	WC-33-5	WC-34-7	WC-44-6
MacLean (Continental)	-	CW-33-5	CW-34-7	CW-44-6
M.D. Henry Company, Inc. (A)	UW-225	UW-335	UW-347	UW-446

(A) Aluminum Alloy

(M) Malleable Iron

(N) Nodular Iron

Curved Rolled Steel

Sizes, inches:	4 x 4(1)
Thickness, in.:	1/4
Hole Diam., in.:	15/16
Joslyn (Steel)	J6829
Line Hardware, Inc.	SWC Series

1. To be used only on transmission systems.

f – Pin, crossarm  
(With square washer, nut and MF locknut)

DISTRIBUTION

Thread (inches diam.)	1	1-3/8	1	1-3/8
Length above base (in.)	5	7	5	7
Length below base (in.)	5-3/4	7	1-1/2	1-3/4
Shank (inches diam.)	5/8	5/8	5/8	3/4

	<u>Long Shank</u>		<u>Short Shank</u>	
Hubbell (Chance)	881	4717	886	-
Joslyn	J203	J647	J221	J630
Kortick	K7104	K7611	K7122	K7631
MacLean (Continental)	U558	U3137A	U579	U3142

Clamp Type Pin

Thread (inches diam.)	1	1-3/8
Length above base (in.)	5-3/4	7
Hubbell (Chance)	14322	14322-1
Joslyn	J3322	J3324

Washer Plate for Clamp Type Pin

These plates are equipped with lugs to prevent slippage of pin along crossarm. They may be used to replace the bottom plate on pins already installed.

Hubbell (Chance)	450091
------------------	--------

f – Pin, crossarm  
(With square washer, nut and locknut)

TRANSMISSION

Thread (inches diameter)	1-3/8	1-3/8
Length above base (inches)	10	10
Length below base (inches)	7	1-3/4
Shank (inches diameter)	3/4	3/4
	<u>Long Shank</u>	<u>Short Shank</u>
Hubbell (Chance)	4332	-
Joslyn	J610	J633
Kortick	K7643	K7635
MacLean (Continental)	U3140	U3145

Conditional List

f(1)

July 2009

f – Pin, crossarm  
(Non-lead threads)  
(With square washer, nut and MF locknut)

Manufacturer	Conditions
<u>Hubbell</u> 881P – 1" thread, 5 3/4" shank 886P – 1" thread, 1 1/2" shank	To obtain experience.
<u>Hughes Brothers</u> 2775-A5-3/4, 1" thread, 5-3/4" shank	To obtain experience.
<u>Joslyn</u> J203Z, 1" thread, 5-3/4" shank J221Z, 1" thread, 1-1/2" shank J647Z, 1-3/8" thread, 7" shank J630Z, 1-3/8" thread, 1-3/4" shank	To obtain experience.



g – Crossarms, fiberglass

<u>Manufacturer</u>	<u>Description</u>	<u>Conditions</u>
<u>Aluma-Form, Inc.*</u>		
FTA20-4-96	8'	To obtain experience.
FTA20-6-96	8'	
FTA20-6-120	10'	
FTA25-4-96	8'	
FTA25-6-96	8'	
FTA25-6-120	10'	
FTA30-4-96	8'	
FTA30-6-96	8'	
FTA30-6-120	10'	
<u>Creative Pultrusions, Inc.</u>		
<u>Braced Application</u>		To obtain experience.
MT30962N (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
MT30962N (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
MT31202N (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT40962N (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT40962N (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT41202N (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT60962N (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT60962N (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT61202N (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT80962N (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT80962N (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT81202N (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
<u>Braceless (centermount) Application</u>		
MT30962I (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
MT30962I (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
MT31202I (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT40962D (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT40962D (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT41202D (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT60962M (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT60962M (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT61202M (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	
HT80962P (with Horizontal Bushing at Center Hole)	8' Type 3 Drill Pattern	
HT80962P (with Horizontal Bushing at Center Hole)	8' Type 4 Drill Pattern	
HT81202P (with Horizontal Bushing at Center Hole)	10' Type 5 Drill Pattern	

g – Crossarms, fiberglass

<u>Manufacturer</u>	<u>Description</u>	<u>Conditions</u>
<u>Geotek (PUPI)</u>		
<u>Braced Application</u>		
T220009603X (with horizontal bushing at center hole)	8' Type-3 Drill Pattern	To obtain experience.
T220009604X (with horizontal bushing at center hole)	8' Type-4 Drill Pattern	
T220012005X (with horizontal bushing at center hole)	10' Type-5 Drill Pattern	
T200009603X	8' Type-3 Drill Pattern	
T200009604X	8' Type-4 Drill Pattern	
T200012005X	10' Type-5 Drill Pattern	
T300009603X	8' Type-3 Drill Pattern	
T250009603X	8' Type-3 Drill Pattern	
T250009604X	8' Type-4 Drill Pattern	
T250012005X	10' Type-5 Drill Pattern	
T300009604X	8' Type-4 Drill Pattern	
T300012005X	10' Type-5 Drill Pattern	
<u>Braceless (Centermount) Application</u>		
TZ220209603X	8' Type-3 Drill Pattern	To obtain experience.
TB220009603X	8' Type-3 Drill Pattern	To obtain experience.
TB220009604X	8' Type-4 Drill Pattern	
TB220012005X	10' Type-5 Drill Pattern	
TB200009603X	8' Type-3 Drill Pattern	
TB200009604X	8' Type-4 Drill Pattern	
TB200012005X	10' Type-5 Drill Pattern	
TB300009603X	8' Type-3 Drill Pattern	
TB250009603X	8' Type-3 Drill Pattern	
TB250009604X	8' Type-4 Drill Pattern	
TB250012005X	10' Type-5 Drill Pattern	
TB300009604X	8' Type-4 Drill Pattern	
TB300012005X	10' Type-5 Drill Pattern	
TZ220209604X	8' Type-4 Drill Pattern	
TZ220212005X	10' Type-5 Drill Pattern	

\*May be used in Braceless or Braced Application.

g – Crossarms, fiberglass

<u>Manufacturer</u>	<u>Description</u>	<u>Conditions</u>
<u>MacLean Power Systems</u>		
<u>Braced Application</u>		
PW08REA003	8' Type-3 Drill Pattern	To obtain Experience
PW08REA004	8' Type-4 Drill Pattern	
PW08REA005	8' Type-5 Drill Pattern	
PX08REA003	8' Type-3 Drill Pattern	To obtain Experience
PX08REA004	8' Type-4 Drill Pattern	
PX10REA005	10' Type-5 Drill Pattern	
<u>Braceless (Centermount) Application</u>		
PW08ST003	8' Type-3 Drill Pattern	To Obtain Experience
PW08ST004	8' Type-4 Drill Pattern	
PW10ST005	10' Type-5 Drill Pattern	
PX08ST003	8' Type-3 Drill Pattern	To obtain Experience
PX08ST004	8' Type-4 Drill Pattern	
PX10ST005	10' Type-5 Drill Pattern	
<u>Powertrusion International, Inc.</u>		To obtain experience.
<u>Braced Application</u>		
PST08001NR03	8' Type-3 Drill Pattern	
PST08001NR04	8' Type-4 Drill Pattern	
PST10001NR05	10' Type-5 Drill Pattern	
PHT08001NR03	8' Type-3 Drill Pattern	
PHT08001NR04	8' Type-4 Drill Pattern	
PHT10001NR05	10' Type-5 Drill Pattern	
<u>Braceless (Centermount) Application</u>		To obtain experience.
PST08001BR03	8' Type-3 Drill Pattern	
PST08001BR04	8' Type-4 Drill Pattern	
PST10001BR05	10' Type-5 Drill Pattern	
PHT08001BR03	8' Type-3 Drill Pattern	
PHT08001BR04	8' Type-4 Drill Pattern	
PHT10001BR05	10' Type-5 Drill Pattern	

\*May be used in Braceless or Braced Application.

g – Crossarms, fiberglass

<u>Manufacturer</u>	<u>Description</u>	<u>Conditions</u>
<u>Shakespeare</u>		
<u>without Center Mount</u>		To obtain experience.
STN096N0040(X)**	8' Type-3 Drill Pattern	
STN096N0060(X)**	8' Type-4 Drill Pattern	
STN120N0060(X)**	10' Type-5 Drill Pattern	
MTN096N0040(X)**	8' Type-3 Drill Pattern	
MTN096N0060(X)**	8' Type-4 Drill Pattern	
MTN120N0060(X)**	10' Type-5 Drill Pattern	
HTN096N0040(X)**	8' Type-3 Drill Pattern	
HTN096N0060(X)**	8' Type-4 Drill Pattern	
HTN120N0060(X)**	10' Type-5 Drill Pattern	
TTN096N0040(X)**	8' Type-3 Drill Pattern	
TTN096N0060(X)**	8' Type-4 Drill Pattern	
TTN120N0060(X)**	10' Type-5 Drill Pattern	
<u>with Center Mount</u>		To obtain experience.
STB096N1240(X)**	8' Type-3 Drill Pattern	
STB096N1260(X)**	8' Type-4 Drill Pattern	
STB120N1260(X)**	10' Type-5 Drill Pattern	
MTB096N1240(X)**	8' Type-3 Drill Pattern	
MTB096N1260(X)**	8' Type-4 Drill Pattern	
MTB120N1260(X)**	10' Type-5 Drill Pattern	
HTB096N1240(X)**	8' Type-3 Drill Pattern	
HTB096N1260(X)**	8' Type-4 Drill Pattern	
HTB120N1260(X)**	10' Type-5 Drill Pattern	
TTB096N1240(X)**	8' Type-3 Drill Pattern	
TTB096N1260(X)**	8' Type-4 Drill Pattern	
TTB120N1260(X)**	10' Type-5 Drill Pattern	
(**X=2-gray color or 5-dark bronze color)		
<u>DIS-TRAN Wood Products, LLC</u>		
CTLBC Series, CTSBC Series, CTHBC Series, CTLBB Series, CTSBB Series, CTHBB Series,	8' Type-3 and Type-4, 10' Type-5 Drill Pattern	To obtain experience.
<u>Wagners</u>		
WGN-S1000	8' or 10'	To obtain experience.
WGN-S3000	8' or 10'	

Note: Gripping studs or teeth on clamp type crossarm pins (item f) should not be installed against the surface of the fiberglass crossarms.

Conditional List  
g(2)  
July 2009

g – Crossarms, composite

<u>Manufacturer</u>	<u>Description</u>	<u>Conditions</u>
<u>Petroflex North America, Inc.</u> <u>Braced Application</u> CA-8(X)** (**X=B for black color X=G for grey color)	8' Type-4 Drill Pattern	To obtain experience.

h – Brace, crossarm, steel

Wherever item “h” is shown on a construction drawing, use a brace from page cu.

i – Bolt, carriage

Applicable Specification: ANSI C135.1, “Standard for Galvanized Steel Bolts and Nuts.”

Applicable Sizes: 3/8 inch diameter, 3 through 6 inch length  
1/2 inch diameter, 3 through 6 inch length

The following manufacturers have shown compliance with the applicable specifications for carriage bolts.

Allied Bolt, Inc.  
Hubbell (Chance)  
Hughes Brothers  
Joslyn Manufacturing Company  
Kortick Manufacturing Company  
MacLean (Continental)  
The Rockford Bolt & Steel Company

j – Screw, lag

Applicable Specifications: ANSI C135.3 “Standard for Zinc Coated Ferrous Lag Screws”

Applicable Sizes:                   1/2 inch diameter, 4 inch length  
  1/2 inch diameter, 5 inch length  
  5/8 inch diameter, 4 inch length  
  5/8 inch diameter, 5 inch length

The following manufacturers have shown compliance with the applicable specifications for lag screws:

Allied Bolt, Inc.  
Hubbell (Chance)  
Joslyn Manufacturing Company  
Kortick Manufacturing Company  
MacLean (Continental)



k – Insulators, suspension

ANSI Class Type	52-9A Clevis	52-1 Clevis	52-4 Clevis	52-3 Ball & Socket
Disc Diameter	4-1/4"	6"	9" or 9-1/2"	9" or 9-1/2"
M & E Rating, lbs.	10,000	10,000	15,000	15,000
Leakage	6-3/4"	7"	11-1/2"	11-1/2"
Flashover, kV: Dry	60	60	80	80
Flashover, kV: Wet	30	30	50	50
NOTES	(3) (4)	(3) (4)	(5)	(2)

Manufacturer	Catalog Number			
ICB	ICB 529-A	ICB 521	-	-
Lapp	-	-	9100	9000
Locke	16044	16583	15S410	15S409
Gamma Insulators Corp.	6815-70	6605-70	8265	8255
			8267	8256
				8257
Sediver	CT-4R2-M	-	-	-
Victor Insulators, Inc.	817	804	-	-

ANSI Class Type	52-3 Ball & Socket	52-4 Clevis	52-5 Ball & Socket	52-6 Clevis
Disc Diameter	10"	10"	10"	10"
M & E Rating, lbs.	15,000	15,000	25,000	25,000
Leakage	11-1/2"	11-1/2"	11"	11"
Flashover, kV: Dry	80	80	80	80
Flashover, kV: Wet	50	50	50	50
NOTES	(2)	(1)	(2)	-

Manufacturer	Catalog Number			
GEC Alsthom	-	105452	-	-
Lapp	8200	8100	301425	2300
Locke	-	20S580	-	30S257
Gamma Insulators Corp.	-	-	8258	-
Porcelain Prod. (Knox)	81022	81012	-	-
Sediver	-	CT-8R2	-	-

Notes:

- (1) Use two for 24.9/14.4 kV deadends.
- (2) To be used only on transmission lines.
- (3) To be used only on distribution lines.
- (4) Use two insulators for 12.5/7.2 kV deadends and three for 24.9/14.4 kV deadends.
- (5) Use two insulators for 24.9/14.4 kV deadends.

k – Insulator, suspension, Toughened Glass

Manufacturer

---

Sediver

10" suspension insulator  
N-8R2 (ball & socket, 20,000 lbs.)  
CT-14R2 (clevis, 30,000 lbs.)  
N-14R2 (ball & socket, 30,000 lbs.)

Hubbell Power Systems

10" suspension insulator  
PSN70146 (ball & socket, 15,000 lbs.)  
PSN100146 (ball & socket, 22,000 lbs.)  
PSN12146 (ball & socket, 25,000 lbs.)  
PSN14146 (ball & socket, 30,000 lbs.)

11" suspension insulator  
PSN160146 (ball & socket, 36,000 lbs.)  
PSN180146 (ball & socket, 40,000 lbs.)  
PSN21156 (ball & socket, 50,000 lbs.)

k – Insulator, polymer distribution deadend

Manufacturer	Conditions
<u>Aluma-Form</u>	
DEI-15	1. To obtain experience.
DEI-28	2. For use as deadends on distribution lines only.
DEI-25/35	3. Not recommended for use in areas subject to contamination.
DEI-35	
<u>Advanced Rubber Products*</u>	
ARP-15EACE-I (EPDM – 15 kV)	Same as above.
ARP-25EACE-I (EPDM – 25 kV)	
ARP-35EACE-I (EPDM – 35 kV)	
ARP-15SKCE-S (Silicone – 15 kV)	
ARP-15SKCE-A (Silicone – 15 kV)	
ARP-25SKCE-S (Silicone – 25 kV)	
ARP-27SKCE-SSI (Silicone – 25 kV)	
ARP-35SKCE-S (Silicone – 35 kV)	
* A = Aluminum end-fitting, I = Cast iron end-fitting, S = Steel end-fitting	
<u>Dulmison</u>	
H-15 kV-4	Same as above.
H-25 kV-6	
<u>GLP</u>	
DS-15 (15 kV)	
DS-28 (25 kV)	
<u>Grupo IUSA</u>	Same as above.
ASSI-15-70 (15 kV)	
ASSI-25-70 (25 kV)	
ASSI-35-70 (35 kV)	
<u>Hubbell (Ohio Brass)</u>	
Veri*Lite PDI	Same as above.
401015-0215 (15 kV)	
401025-0215 (25 kV)	
401028-0215 (25kV) (DS-28)	
401035-0215 (35 kV)	
401046-0215 (35 kV) DS-46)	
<u>K-Line</u>	
KL-15ASCTM (15 kV line-to-line)	Same as above.
KL-28ASCTM (25 kV line-to-line)	
KL-35SCTM (35 kV line-to-line)	
<u>MacLean (Reliable)</u>	
DS-15G (15 kV)	Same as above.
DS-15M (15 kV) (metal end fittings)	
DS-28G (25 kV)	
DS-28M (25 kV) (metal end fittings)	
DS-35G (35 kV)	
DS-35M (35 kV) (metal end fittings)	

NOTE: When insulators from this page are used, adjust construction drawing material list quantities as necessary. Recommended maximum working load is 5,000 lbs.

k – Insulator, polymer distribution deadend

Manufacturer	Conditions
<u>Porcelain Products</u> PDEI-15, 15 kV PDEI-25, 25 kV	1. To obtain experience. 2. For use as deadends on distribution lines only. 3. Not recommended for use in areas subject to contamination.
<u>Pyungil Co. Ltd</u> DN15SD-CT, 15kV DN28SD-CT, 28kV DN35SD-CT, 35kV	Same as above.
<u>Salisbury</u> 9501U-SI (silicone – 15 kV) 9502U-SI (silicone – ANSI DS-28) 9503U-SI (silicone – 35 kV) 9502L-EP (silicone – 25 kV)	Same as above.
<u>Sediver</u> ODI-11-70-15 (15 kV) ODI-15-70-28 (25 kV) ODI-17-70-35 (35 kV)	Same as above.
<u>Victor Insulators, Inc.</u> 8015 (15kV) 8025 (25kV) 8035 (35kV) 8215 (15kV) 8225 (25kV) 8235 (35kV)	Same as above.
<u>Volt Tek</u> 1515-00 (EPDM – 15 kV) 2515-00 (EPDM – 25 kV) 3515-00 (EPDM – 35kV) 1515S-00 (Silicone – 15kV) 2515S-00 (Silicone – 28kV) 3515S-00 (Silicone – 35kV)	Same as above.
<u>Electroporcelana Gamma S.A.</u> PS015 (15kV) PS025 (25kV) PS035 (35kV)	1. To obtain experience. 2. For use as deadends on distribution lines only. 3. Not recommended for use in areas subject to contamination.

NOTE: When insulators from this page are used, adjust construction drawing material list quantities as necessary. Recommended maximum working load is 5000 lbs.

I – Clamp, deadend

DISTRIBUTION

<u>Copper 2 through 6</u> <u>CWC 4A through 8A</u>		ACSR (Aluminum Clamps)			
		<u>4/0 &amp; 3/0</u>	<u>2/0</u>	<u>1/0</u>	<u>2&amp;4</u>
-	AFL	302	302	302	302
80500-2000	Hubbell (Anderson)	PG-57N	PG46N	PG-46N	PG-46N
-	C & R	CR-20-90	CR-10-90	CR-10-90	CR-10-90
-	Lapp	306120N	306118N	306118N	306118N
-	MacLean (Bethea)	DA-20N	DA-15-N	DA-15-N	DA-15-N

I – Deadend for steel strand (overhead ground wire)

TRANSMISSION

For high strength, extra high strength steel strand and aluminum clad steel strand

<u>Manufacturer</u>	<u>High Strength Steel</u>		<u>Aluminum-clad steel</u>			<u>Extra High Strength</u>		
	<u>3/8"</u>	<u>7/16"</u>	<u>7 No. 9 AWG</u>	<u>7 No. 8 AWG</u>	<u>7 No. 7 AWG</u>	<u>5/16"</u>	<u>3/8"</u>	<u>7/16"</u>
<u>Compression Type</u>								
AFL Burndy Hubbell (Fargo)	4620.12 YTW375E 861255	4627.14 YTW438E 861430	YTW7M9T 861225	YTW7M8T 861227	YTW7M7T 861430	861022	861225	861430
<u>Formed Type*</u>								
Helical Line Prod. Hubbell (Chance)	HG210-3/8	HG211-7/16	HG523-12.5M	HG525-16M 16M-AWTLG	HG528-20M 20M-AWTLG	HG209-5/16	HG210-3/8	HG211-7/16
* Class B galvanizing. When overhead ground wire has Class C galvanizing, formed deadend should also have Class C galvanizing.								
<u>Automatic Type</u>								
Hubbell (Fargo) MacLean (Reliable)	GDE-302 5202	GDE-303 5203	GDE-302 5202	GDE-302 5202	GDE-303 5203	GDE-301 5201	GDE-302 5202	GDE-303 5203
<u>Clamp Type</u>								
MacLean (Continental) Hubbell (Anderson) MacLean (Bethea)	FQD-55-3LW SWDE-55N FD-550-N	FQD-55-3-LW SWDE-55N						

I – Clamp, deadend

DISTRIBUTION

2-Bolt Straight Line, Aluminum Alloy\*

Manufacturer	Conditions
<u>Burndy</u> Aluminum alloy deadend Catalog No. CUW26RE-1 (#2-2/0 Str. Aluminum, #4-2/0 ACSR)	1. To obtain experience. 2. Applications limited to replacements under hot line conditions.
<u>C &amp; R Products</u> Catalog No. CRDE-10-180 (#4 – 2/0 ACSR) Catalog No. CRDE-20-180 (3/0 – 4/0 ACSR)	Same as above.
<u>Hubbell (Anderson)</u> Aluminum alloy deadend Catalog No. ADSO-88(#2-1/0 ACSR) Catalog No. ADS-48-N (2/0 ACSR) Catalog No. ADS-60-N (3/0 ACSR)	Same as above.
<u>Hubbell (Chance)</u> Aluminum alloy deadend Catalog No. SDF10A (4 through 4/0 ACSR)	Same as above.
<u>Hubbell (Fargo)</u> Aluminum alloy deadend Catalog No. GD-961A side opening keeper (No. 4 and No. 2 ACSR) Catalog No. GD-972A (2/0, 3/0, 4/0 ACSR)	Same as above.
<u>MacLean (Bethea)</u> Aluminum alloy deadend Catalog No. ASO-684-2 (1/0, 2/0, 3/0 ACSR) Catalog No. ASD-2-N (4-2/0 ACSR) Catalog No. ASD-34-N 3/0, 4/0 ACSR Catalog No. HDSO 57 (with side opening) (4-4/0 ACSR)	Same as above.
<u>Aluma-Form</u> Catalog# DES-ASD-1 8 - 2/0 ACSR Catalog# DES-ASD-45 4/0 - 477 ACSR Catalog# DES-ASO-398-1 6 - 2/0 ACSR Catalog# DES-ASO-684-1 4 - 336.4 ACSR (Side Opening) Catalog# DES-ASO-858-2 4 - 556.5 ACSR (Side Opening) Catalog# DES-HDSO-47 8 - 2/0 ACSR (Side Opening) Catalog# DES-HDSO-57 4 - 4/0 ACSR (Side Opening) Catalog# DES-HDSO-82 2-477 ACSR (Side Opening) Catalog# DES-HDSO-88L-6 4-556.5 ACSR (Side Opening)	Same as above.

\*Straight line deadend clamps are applicable for urban construction where tensions are moderate and on lines often worked hot.

I – Clamp, deadend

DISTRIBUTION

(wedge type)

Manufacturer	Conditions
<u>Hubbell (Fargo)</u>	
GDW-2010A (#4 – 2/0 ACSR) Bare Aluminum jaws	To obtain experience.
GDW-2010 (#4 – 2/0 Str Cu) Plated Aluminum jaws for use with copper conductor	
GDW-2040A (#4 – 4/0 ACSR) Bare Aluminum jaws	
GDW-2040 (#4 – 3/0 Str Cu) Plated Aluminum jaws for use with copper conductor	
GDW-556 (266.8 – 477 kcmil ACSR)	



m – Clamp, suspension

2 BOLT – DISTRIBUTION

	Copper & CWC	ACSR with Straight or Formed Armor Rods			
		4	2	1/0 & 2/0	3/0 & 4/0
ABB	6240	6241	6242	6243	6244
AFL	-	-	-	-	HSU*
C & R Products	-	-	-	CRSC-1	CRSC-2
Dulmison	-	-	-	-	HSU*
Hubbell (Anderson)	MS-46-N	MS-60-N	MS-70-N	HAS-85-N	HAS-104-N
Hubbell (Chance)	FWG1	FWG2	FWG3	FWG4	-
Lapp	305740N	306027N	306028N	306029N	306030N
MacLean (Bethea)	FS-46-N	GW-1-N	LS-0-N	LS-1-N	LS-2-N
MacLean (Continental)	FSC-46-N	FSC-60-N	SC-70-N	SC-85-N	SC-105-N
Preformed Line Products	-	-	-	-	AGS*

\*Accepted for larger sizes.

m – Clamp, Suspension

ANGLE – DISTRIBUTION  
No. 2 & 4 ACSR  
Plus Rods

---

2300  
AAC-301 & 302  
-  
GD-907A  
306092  
AC-60  
RALS-1

ABB  
MacLean (Continental)  
Hubbell (Anderson)  
Hubbell (Chance)  
Hubbell (Fargo)  
Lapp  
Line Hardware  
MacLean (Bethea)

2-BOLT TRANSMISSION  
For 3/8" Steel Overhead  
Ground Wire

---

6240  
FSC-46N  
MS-46-N  
FGW1  
-  
305740N  
-

Conditional List  
m(1)  
July 2009

m – Clamp, suspension – cushioned

Condition: To obtain experience

ACSR						
kcmil						
	266.8	336.4	477	556.5	795	954
Preformed	CGS-1100	CGS-1102	CGS-1105	CGS-1106	CGS-1110	CGS-1112

m – Clamp, suspension, high temperature  
For use with High Temperature Conductors

Manufacturer	Conditions
<u>Preformed Line Products (PLP)</u> Suspension System	4. To obtain experience. 5. Use high temperature accessories approved by the manufacturer and accepted by RUS
To be used with CTC Global High Temperature Conductors ACCC (Aluminum Conductor Composite Core)	

Note: These clamps are acceptable when installed using tools and dies in accordance with the conductor manufacturer's recommendations.

n – Bolt, double arming

Applicable Specification: ANSI C135.1, “Standard for Galvanized Steel Bolts and Nuts.”

Applicable Sizes:                      5/8 inch diameter, 12 inch through 24 inch length  
   ¾ inch diameter, 20 inch through 24 inch length

The following manufacturers have shown compliance with the applicable specifications for double arming bolts:

Action Manufacturing  
Allied Bolt, Inc.  
Hubbell (Chance)  
Hughes Brothers  
\* Joslyn Manufacturing Company  
Kortick Manufacturing Company  
MacLean (Continental)  
Portland Bolt & Manufacturing Company  
Steel City Bolt & Screw Co., Inc.  
Threaded Fasteners, Inc.

\*“Static proof” designs available.

o – Bolt, eye, oval

Applicable Specification: ANSI C135.4, “Standards for Galvanized Ferrous Eye Bolts and Nuts for Overhead Line Construction.”

Applicable Sizes: 5/8-inch diameter, 6 through 20-inch length  
3/4-inch diameter, 8 through 20-inch length

The following manufacturers have shown compliance with the applicable specifications for oval eye bolts:

Action Manufacturing  
Allied Bolt, Inc.  
Berny’s Forging Company  
\* Joslyn Manufacturing Company  
Hubbell Power Systems (5/8-inch diameter ONLY)  
Kortick Manufacturing Company  
MacLean (Continental)

\*\*“Static proof” designs available.

Shoulder Eye Bolt  
for Transmission Structures  
3/4 inch diameter, 8 inch through 20 inch length

	<u>Catalog Number</u>
Joslyn	J9528 to J9540
Kortick	K9558 to K2570

p – Connectors, distribution (Parallel Groove)

Applicable Specification: ANSI C119.4

ACSR to ACSR  
To same size or smaller

Bare Conductor

	<u>4/0 – 2/0</u>	<u>1/0</u>	<u>2</u>	<u>4</u>
AFL	-	396.6	490.0	490.0
Blackburn	PAE 4141-9	PAE 2121-9	PAE 2121-9	PAE 2121-9
Burndy	KVS28A	UCG25R	UC25R2R	UC25R2R
Connector Mfg.	APC-2/0	APC-2/0	APC-1/0	APC-1/0
Hubbell (Anderson)	LC-53A	LC-51C	LC-51A	LC-51A
Hubbell (Fargo)	GA-9040L	GA-9020L	GA-9002L	GA-9003L
MacLean (Reliable)	APG-3	APG-2	APG-1	APG-1
Penn-Union	PCAA-20BF	PCAA-15BF	PCAA-10BF	PCAA-10BF
TE Connectivity – Energy	1710521-5	1710521-3	1710521-1	1710521-1

Over Armor Rods

	<u>3/0</u>	<u>2/0</u>	<u>1/0</u>	<u>2</u>	<u>4</u>
Blackburn	-	-	PAA10	PAA10	PAA10
Burndy	-	-	UC32R	UC32R	UC32R
Hubbell (Anderson)	LC-83A	LC-52C	LC-52C	LC-52C	LC-52C
Hubbell (Fargo)	GA-9843	GA-9842	GA-9041L	GA-9020L	GA-9020L
MacLean (Reliable)	-	-	744AL	600AL	600AL
Penn-Union	-	-	ARC-12	ARC-11	ARC-14

p – Connectors, Distribution (Parallel Groove)

Applicable Specification: ANSI C119.4

ACSR to Copper or Copperweld-Copper

ACSR Size (Bare Conductor)

	3/0	2/0	1/0	2	4
AFL	197	R193	R193	195	195
Blackburn	PAC7	PAC7	PAC345	2CA	4CA
Hubbell (Anderson)	LC-811A	LC-811A	LC-522A	LC-511A	LC-511
Hubbell (Fargo)	GA-9040L	GA-9040L	GA-9020L	GA-9002L	GA-9003L
MacLean (Reliable)	600ALC	555ALC	438ALC	438ALC	438ALC

ACSR Size (Over Armor Rods)

	3/0	2/0	1/0	2	4
AFL	201	R197	R197	R197	199
Blackburn	-	-	PAC7	PAC7	PAC7
Hubbell (Anderson)	LC-833	LC-833	LC-811A	LC-811A	LC-811
Hubbell (Fargo)	GA-9843C	GA-9842C	GA-9040L	GA-9020L	GA-9020L
MacLean (Reliable)	-	-	744ALC	600ALC	600ALC



p – Connector, Distribution

Applicable Specification: ANSI C119.4

Copper Type Conductors  
Connections to same size or smaller

Bare Conductor

Copperweld Copper Copper		2A 0x7	2x3	4A	6A 4	8A 6
(s)	Blackburn	1/0H	1H	2H	4H	6H
(s)	Burndy	KS-25	KS-23	KS-23	KS-20	KS-17
(s)	Dossert	DS-10-F	DS-6-F	DS-6-F	DS-3-F	DS-2-F
(s)	Greaves	-	A-8	-	A-5	A-3
(s)	Homac	-	1F	2F	4F	6F
	Hubbell (Anderson)	DG-1/0	DG-1	DG-2	DG-4	DG-6
	Hubbell (Fargo)	GC-5020	GC-5002S	GC-5002	GC-5004	GC-5006
(s)	ILSCO	IK-1/0	IK-2	IK-2	IK-4	IK-6
(s)	Kearney/Eaton	118109	118109	118108	118104	118102
(s)	Krueger & Hudepohl	UC58C-EV	-	-	-	-
(s)	Penn-Union	S1/0	S2	S3	S4	S6
	Richards Manufacturing	VC10	VC10	VC7	VC5	VC3
	Royal Switchgear	1739	1739	-	-	-

Over Armor Rods

	Burndy	KVS-31	KVS-31	KVS-28	KVS-26	KVS-26
	Hubbell (Anderson)	K-5	K-4	K-4	K-2	K-2
	Hubbell (Fargo)	GC-5035	GC-5035	GC-5040	GC-5020S	GC-5020
	ILSCO	IKB-350	IKB-350	IKB-4/0	-	-
(s)	Kearney/Eaton	118112	118112	118111	118110	118110
	Penn-Union	VT-4	VT-3	VT-3	VT-2	VT-1

(s) Designates split bolt connectors

Long Connectors (Split Bolt)  
Copper to Copper

	2	4	6
Blackburn	2H3	4H3	6H3
Burndy	KS-22-3	KS-20-3	KS-17-3
Dossert	DS5-3	DS3-3	DS2-3
Greaves	A-9	A-6	A-4
Homac	-	4F	6F
Hubbell (Anderson)	C-2-L	C-4-L	C-6-L
Kearney/Eaton	118107	118105	118103
Penn-Union	SEL-2	SEL-4	SEL-6

p – Connectors, Service (Parallel Groove)

Applicable Specification: ANSI C119.4  
Aluminum-to-Aluminum  
Solid or Stranded

	No. 2	No. 4
AFL	490.0	490.0
Blackburn	PAE 2121-9	PAE 2121-9
Burndy	UC25R2R	UC25R2R
Hubbell (Anderson)	LC-51A	LC-51A
Hubbell (Fargo)	GA-9002L	GA-9002L
MacLean (Reliable)	APG-1	APG-1
Penn-Union	PCAA-10BF	PCAA-10BF

p – Connectors, Service (Parallel Groove)

Applicable Specification: ANSI C119.4  
Aluminum-to-Copper  
Solid or Stranded

	<u>2 Al to 4 Cu</u>	<u>4 Al to 6 Cu</u>
Blackburn	PAC345	PAC345
Hubbell (Anderson)	LC-511A	LC-511A
Hubbell (Fargo)	GA-9002L	GA-9002L

p – Connectors, Service

Applicable Specification: ANSI C119.4  
Copper-to-Copper  
Solid or Stranded

Manufacturer	No. 4	No. 6
Blackburn	4N	6N
Burndy	KP4C	KP6C
Dossert	ES-4	ES-6
Hubbell (Anderson)	4E	6ES
Hubbell (Fargo)	GC-5004	GC-5006
IlSCO	SX-4	SX-6
Maclean (Reliable)	BVC-4	BVC-6
Penn-Union	SX-4	SX-6
Richards Manufacturing	VC5	VC3
Southport	SE-3	SE-2

p – Connectors, Guy Bond (Parallel Groove)

Applicable Specification: ANSI C119.4

ACSR to Guy Strand

	2/0	1/0	2 & 4
AFL	396.6	396.6	490.0
Blackburn	PAE 2121-9	PAE 2121-9	PAE 2121-9
Burndy	UC 28R	UCG25R	UCG25R
Dossert	AC103-LW	AC101-LW	AC100-LW
Hubbell (Anderson)	LC-52A-GP	LC-51C-GP	LC-51A-GP
Hubbell (Fargo)	GA-9040L	GA-9040L	GA-9040L
MacLean (Reliable)	744AL	555AL	438AL
Penn-Union	ALC-15	ALC-10	PCA-010

Copper to Guy Strand

TE Connectivity – Energy	C-LOK Series
Blackburn	K-1
	2HPW (1/4")
	1/0 HPW (3/8")
Burndy	UC8W26L
C & R	CRJC-1
Dossert	UDV 13-1-P
Galvan Industries, Inc.	K1
Hubbell (Anderson)	LC-511A
Hubbell (Fargo)	GC-8040P
ILSCO	SK-3 (1/4")
	SK-1/0 (3/8")
Joslyn	J8300
Kearney/Eaton	9968-1
Krueger & Hudepohl	UC58B-EV
MacLean (Reliable)	438ALC
Penn-Union	JC-1-AC
	(1/4", 3/8" guy strand)
	(1/0 strand copper max.)

p – Connectors, Compression  
Applicable Specification: ANSI C119.4

DISTRIBUTION

	Aluminum to aluminum	Aluminum to copper	Copper to copper	Tap Connections (Al to Al, Al to Cu)
Blackburn	Type WR	Type WR	Type CF-1	Type WR
Burndy	"Hycrimp" (Type YH)	"Hycrimp" (Type YH)	"Crimpit" (Type YC-C)	"Cabelok Crimpit" (Type YP-U)
Cembre	-	-	C	-
Homac	H Tap-OB&DB	H Tap-OB&DB	CC	H Tap-OB&DB
Hubbell (Anderson)	AC Series	AC Series	VCUC	VCP
Kearney/Eaton	"Squeezeon" (Aluminum)	"Squeezeon" (Aluminum)	"Squeezeon" (Copper)	"Squeezeon" (Aluminum)
Penn-Union	"Press-On" (Aluminum)	"Press-On" (Aluminum)	"Press-On" (Copper)	"Penn-L-Tap"

NOTE: These connectors are acceptable when installed using tools and dies in accordance with the connector manufacturer's recommendations.

p – Connectors, Compression  
Applicable Specification: ANSI C119.4

SERVICE

	Aluminum-to-Aluminum Aluminum-to-Copper	Copper-to-Copper
Blackburn	CS, KL ICS-1, IKL (Insulated)	-
Burndy	"Linkits" (Type YSU, YSD) "Insulink"(ES)	"Hysplice" (Types YDS-C, YDS-W)
Homac	"Shure Splicers"	-
Hubbell (Anderson)	VAUS	VHS
Kearney/Eaton	"Serv-ens"	-
National Tel. Supply	"Nicopress"	-
Penn-Union	"Penn Sleeves"	-

These connectors are furnished in a variety of sizes to fit all combinations of aluminum and copper service wire.

NOTE: These connectors are acceptable when installed using tools and dies in accordance with the connector manufacturer's recommendations.

p – Connectors, Transmission  
Applicable Specification: ANSI C119.4

BOLTED TYPE

ACSR to ACSR  
ACSR to Copper

AFL 580 Series

Burndy (ACSR to ACSR) UP-A, UP-R

When ordering these clamps specify size, stranding and material of both conductors.

COMPRESSION TYPE

ACSR to ACSR  
Same Size

Conductor Size	AFL	Blackburn	Burndy	Hubbell (Anderson)	Kearney/Eaton
1/0	5074.438	RCJ10	YCS25R	VPUS	OHR-1/0-61AJ
2/0	5074.484	RCJ20	YCS26R	-	OHR-2/0-61AJ
3/0	5075.547	RCJ30	YCS27R	Order	OHR-3/0-61AJ
4/0	5075.609	RCJ40	YCS28R	by	OHR-4/0-61AJ
266.8 kcmil	5076 Order by	RCJ266M	YCS30R	Conductor	HR-266-267AJ
336.4 kcmil	5076 stranding	RCJ336M	YCS33R	Size	HR-336-267AJ

ACSR to Copper

AFL 5070 Series  
Burndy YCR-R-CA  
Hubbell (Anderson) VPUS

(Order by conductor sizes)

NOTE: These connectors are acceptable when installed using tools and dies in accordance with the connector manufacturer's recommendations.



p – Connectors  
(wedge type)

Manufacturer	Aluminum-to-aluminum	Aluminum-to-copper	Copper-to-copper	Tap Connections (Al to Al ,Al to Cu)
AFL	Wedge Tap	Wedge Tap	-	Wedge Tap
TE Connectivity – Energy	AMPACT MINIWEDGE	AMPACT MINIWEDGE	AMPACT C-LOK Series	AMPACT MINIWEDGE
Burndy	WEJTAP	WEJTAP	WEJTAP	WEJTAP
Connector Products, Inc.	Aluminum Tap Connector	Aluminum Tap Connector	-	Aluminum Tap Connector
Homac	Power Tap	Power Tap	-	Power Tap
Richards Manufacturing Co.	ABWC series	ABWC series	-	ABWC series

p – Connectors

Manufacturer	Conditions
<u>Blackburn</u> Bolted, insulated IPC 1102 (#2-1/0 run, #2 tap) IPC 4111 (1/0-4/0 run, #2-1/0 tap) IPC 4141 (1/0-4/0 run, 1/0-4/0 tap)	1. For use on 600 volt maximum insulated conductors. 2. To be used only for connecting service drop conductors to service entrance conductors. 3. To obtain experience.
<u>Homac</u> *Compression, Insulated "Shure Splicers" Types Q1N and U1N	To obtain experience.
<u>Hubbell (Anderson)</u> *Compression al to al al to cu "Versa-Crimp" L tap.  Parallel groove, aluminum LC-52C (1/0 – 6/1 ACSR over armor rods) LC-51C (1/0 – 6/1 ACSR)	To obtain experience.  To obtain experience.
<u>Kupler</u> Bolted, insulated 130001 (#2-1/0 run, #2 tap) 130003 (1/0-4/0 run, #2-1/0 tap) 130004 (1/0-4/0 run, 1/0-4/0 tap)	1. For use on 600 volt maximum insulated conductors. 2. To be used only for connecting service drop conductors to service entrance conductors. 3. To obtain experience.
<u>Penn Union</u> *Compression, Insulated Type PIK	To obtain experience.
<u>TE Connectivity (Raychem)</u> Insulated service compression connector, TIL Series	To Obtain Experience.
<u>Utilco</u> Two bolt style, al to al Type PM	To obtain experience.

\*NOTE: These connectors are acceptable when installed with tools and dies in accordance with the connector manufacturer's recommendations.

q – Bolt, double upset

Applicable Specification: "RUS Specifications for Single and Double Upset Spool Bolts," D-5

Diameter, inches:	5/8	5/8	5/8	5/8
Length, inches:	7	8	9	10

Manufacturer

Allied Bolt, Inc.	-	-	1716	1717
Hubbell (Chance)	-	7826	7828	7830
Joslyn	-	J2394	J2395	J2396
Kortick	K4760	K4761	K4762	K4763
MacLean (Continental)	U31065	U31067	U31069	U31071

s – Clevis, secondary swinging

Applicable Specifications: "RUS Specifications for Secondary Swinging Clevises," D-6

Manufacturer	Clevis only*	Clevis with 1-3/4" groove spool	Clevis with 3" groove spool
Hubbell (Chance)	0352	0352-C909-1032	0352-C909-1034
Joslyn	J0322	-	-
Kortick	K9259	K9109	K9149
MacLean (Continental)	U32043	U36043	U32143

\*Catalog Number does not include spool. See page cm for spool type insulators.

u – Deadend for galvanized steel or  
aluminum-clad steel guy strand

3-Bolt Guy Clamp

	<u>Light (1/2" bolts)</u>	<u>Heavy (5/8" bolts)*</u>
Almat	-	K162-4
Allied Bolt, Inc.	5059	5056
Hubbell (Chance)	6450	6461
Joslyn	J930	J931
Kortick	K4124	K4005
MacLean (Continental)	U5273	U5275

U-Bolt Guy Clamp

	<u>Light (3/8" bolts)</u>	<u>Heavy (1/2" bolts)</u>
Hubbell (Chance)	GCU38C	-
Joslyn (Flagg)	PAX-64C	PAX-67C
MacLean (Continental)	GC-64C	GC-67C

Offset Guy Clamp

	<u>Light (1/2" bolts)</u>	<u>Heavy (5/8" bolts)</u>
Hubbell (Chance)	6409	6410
Joslyn	J926	J927

\*For use on transmission.

u – Deadend for galvanized steel guy strand

Strand Size:	<u>1/4</u>	9/32"	5/16"	3/8"	7/16"
			<u>Automatic</u>		
<u>Aluma-Form</u>	AGD-250 AGDU-250	-	AGD-312 AGDU-312	AGD-375 AGDU-375	AGD-437
<u>MacLean (Reliable)</u>					
Bail for thimble eye	5100	5201	5201	5102	5103
Bail for guy insulator	5150	5251	5251	5152	5153
			<u>Formed Type</u>		
<u>AFL</u>					
For standard guy*	GYDEGB061	GYDEGB071	GYDEGB079	GYDEGB091	GYDEGB110
<u>Dulmison</u>					
For standard guy*	SGG-0610	SGG-710	SGG-0790	SGG-0915	SGG-1105
<u>Florida Wire &amp; Cable</u>					
For standard guy*	FLA 1300	FLA 1400	FLA 1500	FLA 1600	FLA 1700
<u>Helical Line Products</u>					
For standard guy*	HG-207-1/4"	HG-208-9/32"	HG-209-5/16"	HG-210-3/8"	HG-211-7/16"
<u>Payer Industries</u>					
For standard guy*	25-GNBS	-	30-GNBS	35-GNBS	38-GNBS
<u>Preformed Line Products</u>					
For standard guy*	GDE-1104	GDE-1105	GDE-1106	GDE-1107	GDE-1108
For wrapped guy	WGL-2100	WGL-2101	WGL-2102	WGL-2103	WGL-2104

\*Class B galvanizing. When guy wire has Class C galvanizing, formed deadend should also have Class C galvanizing.

u – Deadend for aluminum clad steel guy strand

Strand Size	3#10 (4M)	7#12 (6M)	7#11 (8M)	7#10 (10M)	7X.110" (11.5M)	7#9 (12.5M)	7X.121" (14M)	7#8 (16M)	7X.148" (20M)
<u>Formed Type</u> <u>Aluminum-Clad Steel Guy Strand</u>									
<u>AFL</u> For standard guy	GYDEAW055	GYDEAW060	GYDEAW068	GYDEAW077	GYDEAW082	GYDEAW087	GYDEAW090	GYDEAW096	GYDEAW112
<u>Dulmison</u> For standard guy	AWGG 0555	AWGG 0600	AWGG 0685	AWGG 0770	AWGG 0825	AWGG 0870	AWGG 0905	AWGG 0965	AWGG1125
<u>Helical Line Products</u> For standard guy	-	HG517-6M	HG519-8M	HG521-10M	-	HG523-12.5M	HG524-14M	HG525-16M	HG528-20M
<u>Hubbell (Chance)</u> For standard guy	-	6M-AWTLG	8M-AWTLG	10M-AWTLG	-	12.5M-AWTLG	-	-	-
<u>Preformed Line Products</u> For standard guy	AWDE-4108	AWDE-4110	AWDE-4113	AWDE-4116	AWDE-4118	AWDE-4119	AWDE-4120	AWDE-4122	AWDE-4126
For wrapped guy	-	WGL-4110	WGL-4113	WGL-4116	-	WGL-4120	-	-	-
<u>Automatic</u> <u>Aluminum-Clad Steel Guy Strand</u>									
Hubbell (Fargo)	-	GDE-300	GDE-301	GDE-301	-	GDE-302	-	-	-
MacLean (Reliable)	-	5200	5201	5201	-	5202	-	-	-

v – Guy Attachment  
for 5/8" bolt

Type:	Formed Strap	Angle Bolt Eye	Guy Hook	Guy Hook*
Maximum Working Load Rating	23,130 N (5200 lbs.)	23,130 N (5200 lbs.)	23,130 N (5200 lbs.)	37,800 N (8500 lbs.)
Eaton				
Hubbell (Chance)	5004	0100	-	GH5
Joslyn	J25164	J6500	J6555 J6556	-
Joslyn (Flagg)	-	-	-	P151X
Kortick	K4035 K4047	K3140	-	-
Line Hardware	-	-	-	HGA-58C
MacLean (Bethea)	-	-	-	AG-5
MacLean (Continental)	U31030	U5531	GAD	GAD-56-4
Power Play Products	-	-	-	B58GH
M.D. Henry Company, Inc.	-	-	-	UGA-56C

\*This hook may be used in place of the wrapped guy arrangement in assemblies E3-2 and E3-3.



Pole Eye Plates  
(5/8" Bolt)

Type	Pole Eye Plate
Maximum Working Load Rating	37,800 N. (8500 lbs.)
Hubbell (Anderson)	GSP-05
Line Hardware	PGA-548
MacLean (Bethea)	PE5-6A
MacLean (Continental)	PEP-66-45

v – Guy attachment

Manufacturer	Conditions
<u>MacLean (Continental)</u> Pole Band, UCB-15E	To obtain experience. For distribution lines only and 10,000 lbs maximum loading.
<u>Hubbell (Chance)</u> Pole Band, with cone head bolt 6280, and guy clip 456 6276 (for 6" to 10" pole) 6277 (for 8" to 14" pole)	To obtain experience. For distribution lines only and 10,000 lbs maximum loading.
<u>Joslyn</u> Pole Band, with cone head bolt J-6281, and guy clip J-6275 J-6280 (for 6" to 10" pole) J-6270 (for 8" to 14" pole)	To obtain experience. For distribution lines only and 10,000 lbs maximum loading.

w – Insulators, guy strain  
(Fiber Reinforced Plastic)

Ult. Strength, lbs.	11,000	15,000	21,000
<u>Aluma-Form, Inc.</u>	-	FGS 16 Series	FGS 21 Series
<u>Dulmison</u>	II1-1P Series	HSI-2X Series	HSI3-2P Series
<u>Fiberglass Line Hardware</u>		FCC Series FCTE Series	FCC Series FCTE Series
<u>GAMMA CORONA</u>	-	GS15 Series	GS21 Series
<u>EPAC</u>	CC Series	CC Series	CC Series
<u>Gamma Insulators Corp.</u>	-	GS15 Series	-
<u>Hubbell (Chance)</u>	-	GS-16	GS-21
<u>Hughes Brothers</u>	-	692 Series	694 Series
<u>Joslyn (Flagg)</u>	150 Series	150 Series	210 Series
<u>K-Line</u>	-	-	KL Series
<u>MacLean (Continental)</u>	G-11 Series GAC 11 Series (for 5/16" guy strand)	G-15 Series GAC 15 Series (for 3/8" guy strand)	G-21 Series -
<u>Preformed Line Products</u>	-	GSF16 Series	GSF21 Series

x – Rod, anchor

Applicable Specification: ANSI C135.2, “Standards for Galvanized Ferrous Strand Eye Anchor Rods”

Applicable Sizes:

- Single guy: 5/8 inch diam. 6, 7 and 8  $\frac{3}{4}$ t long  
3/4 inch diam. 8, 9 and 10 feet long  
1 inch diam. 9 and 10 feet long
- Double guy: 5/8 inch diam. 7 and 8  $\frac{3}{4}$ t long  
3/4 inch diam. 8, 9 and 10 feet long  
1 inch diam. 9 and 10 feet long
- Single Guy: Drive: 5/8 inch diam. 7 and 8  $\frac{3}{4}$ t long  
3/4 inch diam. 8, 9 and 10 feet long  
1 inch diam. 9 and 10 feet long
- Double Guy: Drive: 5/8 inch diam. 7 and 8  $\frac{3}{4}$ t long  
3/4 inch diam. 8, 9 and 10 feet long  
1 inch diam. 9 and 10 feet long

The following manufacturers have shown compliance with the applicable specifications. Some manufacturers cannot supply all sizes listed above. Check with manufacturer or distributor for availability.

Allied Bolt, Inc.  
Dixie  
Eritech (Carolina Galvanizing/Knight)  
Grip-Tite  
Hubbell (Chance)  
Joslyn  
Kortick  
Utilities Service

x – Rod, anchor

Applicable Specification: ANSI C135.2 “Standards for Galvanized Ferrous Strand Eye Anchor Rods” except rods are copper covered. Copper coating thickness is **13 mils minimum** at any point and a 15 mil average. All purchases should specify that a factory certification to the thickness of the copper must accompany the shipment of the rods.

Applicable Sizes: Dou<sup>3</sup>/<sub>4</sub> Guy – 3/4 inch diameter, 8 and 9 feet long.

Manufacturer	Conditions
Joslyn	<ol style="list-style-type: none"><li>1. To obtain experience.</li><li>2. For transmission purposes only.</li><li>3. For use with log anchors or copper covered plate anchors only.</li><li>4. To be used with copper coated hardware or bronze hardware underground.</li></ol>

Conditional List

x(2)

July 2012

x – Rod, anchor

Applicable Specification: ANSI C135.2 “Standards for Galvanized Ferrous Strand Eye Anchor Rods” except rods are copper covered. Rods meet UL-465 specification for copper coating thickness of **10 mils minimum at any point.** All purchases should specify that a factory certification to the thickness of the copper must accompany the shipment of the rods.

Applicable Sizes: Double Guy – 3/4 inch diameter, 8 and 9 feet long.

Manufacturer

Conditions

y – Galvanized Steel Strand

Usage: Guy, Distribution or Transmission Line  
Overhead Static Wire

ASTM Specification: A 475 – For Guy Strand  
A 363 – For Overhead Static Wire

Following grades/diameters of steel wire strands are preferred sizes:

For Guying

Siemens-Martin Distribution Line	High Strength Dist. Or Trans.	Extra High Strength Grade	
		Distribution	Transmission
1/4" dia.	1/4" dia.	1/4" dia.	1/4" dia.
-	9/32"	9/32"	9/32"
-	5/16"	5/16"	5/16"
3/8"	3/8"	3/8"	3/8"
7/16"	7/16"		7/16"

For Overhead Static Wire (Groundwire)

High Strength (dia.)	Extra High Strength Grade (dia.)
-	5/16"
3/8"	3/8"
7/16"	7/16"

Alcan Cable  
Armco Steel Corporation  
Bekaert Steel Wire Corporation  
Cal-Wire  
Central de Herramientes, S.A. de C.V.  
Conex Cable, LLC  
Davis-Walker  
DeAcero, S.A. de C.V.  
Emcocables  
Florida Wire and Cable  
Guardian Cable Systems, LLC  
Indiana Steel and Wire  
Knight Industries  
Mitchell Industries  
National Strand Products  
Paulsen Wire and Rope Corporation  
Seal Wire Company  
Southwire

Note: The buyer should specify Class A, B, or C coating per ASTM A363 or A475.

y – Steel Strand

Aluminum-Clad  
Specifications: ASTM B415 and B416

For overhead groundwire

(Joint and splice requirements for wire and strand to meet ASTM A363)

AWG Sizes: (a) 7 No. 10, (c) 7 No. 9, (d) 7 No. 8, (e) 7 No. 7

Emcocables	(a), (c), (d), (e)
Intral and Company, Ltd.	(a), (c), (d), –e)
Nehri–g - Conex	(a), (c), (d), (e)
AFL	(a), (c), (d), (e)

For guy strand

(M is rated breaking load in thousand lbs)

M Sizes: 6M (7 No. 12), 8M (7 No. 11), 10M (7 No. 10), 11.5M (7 x .110"), 12.5M (7 No. 9), 14M (7 x .121"),  
16M (7 No. 8), 18M (7 x .139"), 20M (7 x .148")

Alumoclad de Mexico, S.A. de C.V.	8M, 10M, 16M
Emcocables	6M, 8M, 10M, 12.5M, 16M, 18M, 20M
Intral and Company, Ltd.	6M, 8M, 10M, 12.5M, 16M, 18M, –0M
Nehri–g - Conex	8M, 10M, 12.5M, 16M, 18M
AFL	6M, 8M, 10M, 12.5M, 14M, 16M, 18M, 20M



Conditional List  
y(1)  
July 2009

y – Aluminum Coated Steel Wire  
Applicable Specification ASTM A474

National Strand Products, 3/8"

Distribution Guy Strand

Siemens-Martin  
High Strength  
Extra High Strength

To obtain experience.

Transmission Guy Strand

High Strength  
Extra High Strength

To obtain experience.

Overhead Static Wire

High Strength  
Extra High Strength

1. To obtain experience.
2. Must meet the joint requirements of ASTM A363.

y - Zinc - 5% Aluminum - Mischmetal alloy (Zn-5Al-MM) - Coated  
Steel Wire Strands  
Applicable Specification ASTM A855

**Bekaert Corporation**

Type/Grade:    Nominal diameter (7-wire strand) in.

(S-M): 1/4", 3/8", & 7/16".  
(HS): 1/4", 5/16", 3/8", & 7/16", 9/32".  
(EHS): 1/4", 5/16", 3/8", & 7/16", 9/32".

Conditions

Distribution Guy Strand  
Siemens-Martin (S-M)  
High Strength (HS)  
Extra High Strength (EHS)

To obtain experience.

Transmission Guy Strand  
High Strength (HS)  
Extra High Strength (EHS)

To obtain experience.

Overhead Static Wire  
High Strength (HS)  
Extra High Strength (EHS)

1. To obtain experience.  
2. Must meet the joint requirements of ASTM A363.

NOTE: Only available with Class A coating.

Type/Grade:    Nominal diameter (7-wire strand), in.

(S-M): 1/4", 3/8", & 7/16".  
(HS): 1/4", 9/32", 5/16", 3/8", & 7/16".  
(EHS): 1/4", 9/32", 5/16", 3/8", & 7/16".

**Indiana Steel & Wire Co.**

**Guardian Cable Systems, LLC**

Conditions

Distribution Guy Strand  
Siemens-Martin (S-M)  
High Strength (HS)  
Extra High Strength (EHS)

To obtain experience.

Transmission Guy Strand  
High Strength (HS)  
Extra High Strength (EHS)

To obtain experience.

Overhead Static Wire  
High Strength (HS)  
Extra High Strength (EHS)

1. To obtain experience.  
2. Must meet the joint requirements of ASTM A363.

NOTE: The buyer should specify Class A, B, or C coating.

y - Conzinal 95% Zinc - 5% Aluminum+ Mischmetal Alloy (AL-ZN-MM)  
Coated Steel Wire Strands

Applicable Specifications:	ASTM A363, A475, A855/A855M, A925
	ASTM B498, B802/B802M, B803/B803M, B958/B958M

**Conex Cable LLC**

Type/Grade:    Nominal diameter (7-wire strand) in.

(EHS):    1/4", 5/16", 3/8", & 7/16".

Conditions

Distribution Guy Strand  
Extra High Strength (EHS)

To obtain experience.

Transmission Guy Strand  
Extra High Strength (EHS)

To obtain experience.

Overhead Static Wire  
Extra High Strength (EHS)

To obtain experience.

z - Anchors, Expanding and Plate

DISTRIBUTION

Designated Maximum holding power-lbs.		6,000	8,000	10,000	12,000
Min. Area (sq. in.)		90	100	120	135
Rod Dia. (inch <sup>3</sup> / <sub>4</sub> )		<sup>3</sup> / <sub>4</sub>	<sup>5</sup> / <sub>8</sub>	<sup>3</sup> / <sub>4</sub>	<sup>3</sup> / <sub>4</sub>
Rod Length (feet)		7	7	8	-
<u>Type</u>					
Grip-Tite	8 way	A322812G	A322812G	A322812G	A322812G
Hubbell (Chance)	8 way	88135	88135	88135	88135
MacLean Power Systems	8 way	-	J8115	J8135	J8135
Line Hardware	8 way	8-100G	8-115G	8-135G	8-135G

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z - Anchors, plate

Applicable Specification "RUS Specification for Steel Plate Anchors," T-3

TRANSMISSION

Minimum Area 400 sq. in.

3/4" Galv. Rods

<u>Grip-Tite</u>	XP24 - 3/4 - G
Hubbell (Chance)	X24 - 3/4
<u>MacLean Power Systems</u>	J3524 - 3/4
<u>Line Hardware</u>	CP-24G

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z - Anchors, Service

Designated Maximum Holding Power in Sand - 2500 lbs.

	Screw	Expanding
Eritech (Carolina Galvanizing)	86346606	-
Grip-Tite	-	322065G
Hubbell (Chance)	6346	6870
MacLean Power Systems	J6526W-CA	JO870
Line Hardware	-	8-70G
Salco	NW756606	-

z - Anchors, Swamp

DISTRIBUTION

10" dia. 12" dia. 15" dia.

MacLean Power Systems	D-6710-S	D-6713-S	D-6715-S
Foresight	-	MR-SR*	-
Hubbell (Chance)	C1101169	C1101170	C1101171

\*Drive type anchor. Surface area meets or exceeds that of 12" diameter anchors.

NOTE: Where galvanized anchors are listed, the same anchors ungalvanized (black asphalt coated) are also acceptable.

z - Anchors, Rock

Anchor Size - inches	1-3/4	1-3/4	1-3/4	1-3/4
Rod Length - inches	15	30	53	18
Rod Diameter - inches	3/4	3/4	3/4	1
Almat	K148-15	K148-30	K148-53	-
Hubbell (Chance)	R315	R330	R353	-
MacLean Power Systems	J3436	J3437	J3438	-
Kortick	K5503	K5504	K5505	K2377

z - Pole keys

Hubbell (Chance)	P-4817
MacLean Power Systems	J-4817

z - Anchors, Power-installed screw

Manufacturer: Earth Contact Products  
Multi-Helix Screw Anchors

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	TAF-150-36 TAF-150-66	TAF-150-66	TAF-150-66	
A2 (Soil Class 3)	TAF-150-36 TAF-150-66	TAF-150-66	TAF-150-66	
B (Soil Classes 4 & 5)	TAF-150-36 TAF-150-66	TAF-150-66	TAF-150-66	
C (Soil Classes 6 & 7)	TAF-150-36 TAF-150-66	TAF-150-66	TAF-150-66	

Manufacturer: MacLean Power Systems  
Multi-Helix Screw Anchors

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	D-6632 D-6636 D-6637	D-6632 D-6636 D-6637	D-6636 D-6637 D-6638	D-6636 D-6637 D-6638
A2 (Soil Class 3)	D-6632 D-6636 D-6637	D-6632 D-6636 D-6637	D-6636 D-6637 D-6638	D-6637 D-6638
B (Soil Classes 4 & 5)	D-6632 D-6636 D-6637	D-6636 D-6637 D-6638	D-6636 D-6637	D-6638
C (Soil Classes 6 & 7)	D-6636 D-6637	D-6637	D-6638	

NOTES:

1. See RUS Specification T-10 for definitions and explanations.
2. Anchors in the 53,400 N (12,000 lb.) category or above for use on wood poles must be used with hardware commensurate with the working load. Hardware may provide for either single or multiple guy attachments to anchor.
3. Anchors listed in a specific working load category and/or soil class may generally be used at lower working load categories and/or lower numerical soil classes.



z - Anchors, Power-installed screw

Manufacturer: Hubbell (A. B. Chance Company)  
"SS" Multi Helix Anchors

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	012642AE 012642AEJ 012642EJN	012642AE 012642AEJ 012642EJN	012642AEJ 012642EJN 012642EJNS	012642AEJ 012642EJN 012642ENJNS
A2 (Soil Class 3)	012642AE 012642AEJ 012642EJN	012642AE 012642AEJ 012642EJN	012642AEJ 012642EJN 012642EJNS	012642EJN 012642EJNS
B (Soil Classes 4 & 5)	012642AE 012642AEJ 012642EJN	012642AEJ 012642EJN	012642AEJ 012642EJN 012642EJNS	012642EJNS
C (Soil Classes 6 & 7)	012642AEJ 012642EJN	012642EJN	012642EJNS	

Manufacturer: Street & Area Lighting (Salco)  
Multi-Helix Screw Anchors

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	S736U810 S766U81012 S784U101214	S736U810 S766U81012 S784U101214	S766U81012 S784U101214 S7126U10121414	S766U81012 S784U101214 S7126U10121414
A2 (Soil Class 3)	S736U810 S766U81012 S784U101214	S736U810 S766U81012 S784U101214	S766U81012 S784U101214 S7126U10121414	S784U101214 S7126U10121414
B (Soil Classes 4 & 5)	S736U810 S766U81012 S784U101214	S766U81012 S784U101214	S766U81012 S784U101214 S7126U10121414	S7126U10121414
C (Soil Classes 6 & 7)	S766U81012 S784U101214	S784U101214	S7126U10121414	

NOTES:

1. See RUS Specification T-10 for definitions and explanations.
2. Anchors in the 53,400 N (12,000 lb.) category or above for use on wood poles must be used with hardware commensurate with the working load. Hardware may provide for either single or multiple guy attachments to anchor.
3. Anchors listed in a specific working load category and/or soil class may generally be used at lower working load categories and/or lower numerical soil classes.

z - Anchors, Power-installed screw

Manufacturer: Grip-Tite Manufacturing Co.

Soil Type	Working Load Categories			
	35,600 N (8,000 lb.)	53,400 N (12,000 lb.)	71,000 N (16,000 lb.)	89,000 N (20,000 lb.)
A1 (Soil Class 2)	G66327 G66347 G66367 G66377	G66327 G66347 G66367 G66377	G66367 G66377	G66367 G66377
A2 (Soil Class 3)	G66327 G66347 G66367 G66377	G66327 G66347 G66367 G66377	G66367 G66377	G66377
B (Soil Classes 4 & 5)	G66327 G66347 G66367 G66377 G134-6	G66367 G66377		
C (Soil Classes 6 & 7)	G66367 G66377	G66377		

NOTES:

1. See RUS Specification T-10 for definitions and explanations.
2. Anchors in the 53,400 N (12,000 lb.) category or above for use on wood poles must be used with hardware commensurate with the working load. Hardware may provide for either single or multiple guy attachments to anchor.
3. Anchors listed in a specific working load category and/or soil class may generally be used at lower working load categories and/or lower numerical soil classes.

## z - Anchors, Power-Installed Screw, Distribution

Manufacturer	Catalog Number	Rating (lbs.)
<u>Hubbell (Chance)</u>	C1025006	10,000
	C1025007	10,000
	C1025010	10,000
	C1025207	8,000
	C1025210	8,000
<u>Grip-Tite</u>	GHD250-114	10,000
	GHD250-134	10,000
	GHD225-112	8,000
	GHD225-134	8,000
	G112-6	6,000
<u>Salco</u>	SD225-12-1	10,000
	SD225-14-1	10,000
	PH7-12-1	7,000
	PH7-14-1	7,000

Conditional List  
z(2)  
March 2020

z - Anchors, plate

<u>Manufacturer</u>	<u>Catalog #</u>	<u>Conditions</u>
Watson Anchor*	W16B18775	To obtain experience.
	W16B18710	
	W20B18710	
	W20B25010	
	W24B18710	
	W24B25010	
	W30B50012	
	W36B62515	

NOTES:

\*Watson cap nut and anchor rod should be used. Consult manufacturer for proper pairing.

z – Anchors, screw, power installed

Manufacturer	Conditions
<u>Bathurst</u> BMS-003 (6,000 lbs.) BMS-003R (5/8" rod) BMS-004 (10,000 lbs.) BMS-004R (3/4" rod)	To obtain experience.
<u>Cantsink</u> 1.5RCS Series	To obtain experience.
<u>Earth Contact Products</u> TAPL-625-10-12 (6,000 lb., 5/8" rod) TAPL-100-10-14 (10,000 lb., 1" rod)	
<u>Foresight</u> MR-1, MR-2, MR-3, MR-4	To obtain experience. Each installation must be proof tested. Maximum rating is test value achieved.
<u>Hubbell (Chance)</u> 024462 (6,000 and 8,000 lb.) 12332P (5/8" rod) 12587 (5/8" thimble eye nut) 024484 (10,000 and 12,000 lb.) 12632P (3/4" rod) 6512 (3/4" thimble eye nut)	To obtain experience.
<u>MacLean Power Systems</u> J1IB-CA (6,000 & 8,000 lb., 5/8" rod) J13C-CA (10,000 & 12,000 lb., 3/4" rod)	To obtain experience.
<u>Oklahoma Design Technologies, LLC</u> STAD Series CSTAD Series	To obtain experience.
<u>Street &amp; Area Lighting (Salco)</u> S100-84 (10,000 lb., 1" rod) TEN-1 (1" triple eye nut)	To obtain experience.

NOTES:

1. Where galvanized anchors are listed, the same anchors ungalvanized (coated) are also acceptable.
2. Catalog numbers shown for screw anchors are for anchors with 1-3/8" hubs. Equivalent anchors with 1-1/2" hubs are also acceptable. (A special installing wrench is required.)

aa, ab  
December 13, 2023

aa – Nut, eye  
b - Nut, thimble eye

	aa			ab	
	Oval eye nut 5/8"	Oval eye nut 3/4"	Thimble Eyelet	Thimble eye nut 5/8"	Thimble eye nut 3/4"
Allied Bolt, Inc.	5876	5877	2050	5050	5051
Berny's Forging Co.	OE1	-	-	-	-
Dixie	-	-	-	D6510	-
Hubbell (Chance)	6502	-	B14A	6510	-
Hughes	EN60	-	-	-	-
Joslyn	J1092	-	J1126	J6510	-
Kortick	K4212	J1093	K4413	K3111	-
Line Hardware	OEN-58	-	BEL-58	-	-
MacLean (Continental)	EN-5	-	BE-5	TN-5	-

ac-1  
July 2009

ac - Brace, sidearm diagonal

	1-1/2 inch angle 3/16" x 5'	1-3/4 inch angle 3/16" x 7'
Hubbell (Chance)	-	6984
Joslyn	-	J1525
Kortick	K1951	K1954
MacLean (Continental)	U5210	U5212

ae – Surge (lightning) Arrester, Distribution Class

SiC Type

Manufacturer	Type	Ratings, kV	Housing	Duty
General Electric	Alugard	9, 10, 18	Porcelain	Heavy

MOV Type

Manufacturer	Type	Ratings, kV	Housing	Duty
Celeco	PSAMOV-HDDC	9-27	Polymer	Heavy
	HSCEL	9-27	Polymer	Heavy
	RPCEL	9-27	Polymer	Riser Pole
Eaton	AZL VariSTAR	9-27	Porcelain	Heavy
TE Connectivity	HDA Series	9-27	Polymer	Normal
	DAH Series	9-27	Polymer	Heavy
Aluma-Form, Inc.	AHD	3-27	Polymer	Heavy
	ARP	3-27	Polymer	Riser Pole



ae - Surge (Lightning) Arresters, Substation\*

SiC Type				
Manufacturer	Type	Accepted Ratings - kV	Housing	Manufacturer's Classification
General Electric	Alugard	3, 9, 10, 18	Porcelain	Distribution

MOV Type				
Manufacturer	Type	Accepted Ratings - kV	Housing	Manufacturer's Classification
Hubbell Power Systems (Ohio Brass)	DynaVar			
	VLA	3-27	Porcelain	Station
	VL	3-48	Porcelain	Station
	VN	54-312	Porcelain	Station

\* For instructions concerning application at substations, refer to RUS Bulletin 1724E-300, "Guide for the Design of Substations for Electric Borrowers." In the purchase of arresters, care should be taken to select the type and voltage ratings in accordance with the line voltage and the type of construction (grounded or ungrounded).

ae - Surge (Lightning) Arresters, Distribution Class

CONDITION OF ACCEPTANCE: To Obtain Experience

MOV Type				
Manufacturer	Type	Ratings, kV	Housing	Duty
ABB	Polim-D	9,10,18	Polymer	Heavy
Eaton	AZS VariSTAR	9,10,18,27	Porcelain	Normal
	UNS Ultra Sil Housed VariSTAR	9,10,18,27	Polymer	Normal
	UHS Ultra Sil Housed VariSTAR	9,10,18,27	Polymer	Heavy
General Electric	Tranquell, 9L23 Series	9,10,18,27	Polymer	Heavy
Hubbell Power Systems (Ohio Brass)	DynaVar PDV-65	9,10,18,27	Polymer	Normal
	PDV-100 Optima	9,10,18,27	Polymer	Heavy
Joslyn	ZNP	9,10,18,27	Polymer	Normal
	ZHP	9,10,18,27	Polymer	Heavy

MOV Type (Internally Gapped)				
Manufacturer	Type	Ratings, kV	Housing	Duty
Eaton	URT Evolution	9,10,18,27	Polymer	Heavy

ae – Surge Arrester, Substation\*

CONDITION OF ACCEPTANCE: To Obtain Experience

MOV Type

Manufacturer	Type	Accepted Ratings – kV	Housing	Manufacturer's Classification
ABB	XPI-III	9, 10, 18, 27	Polymer	Intermediate
	XPS	9, 10, 18, 27	Polymer	Station
	EXLIM-R	9, 10, 18, 27	Porcelain	Station
	EXLIM-Q	9, 10, 18, 27	Porcelain	Station
Eaton	VariSTAR	3-312	Porcelain	Station
	VariSTAR AZF	3-120	Porcelain	Intermediate
	VariSTAR UI	3-108	Polymer	Intermediate – 3.9 kJ/kV <sup>(1)</sup>
	VariSTAR US	3-108	Polymer	Station – 3.4 kJ/kV
	VariSTAR US	3-108	Polymer	Station – 3.9 kJ/kV <sup>(1)</sup>
	VariSTAR US	120-240	Polymer	Station – 6.2 kJ/kV <sup>(1)</sup>
	VariSTAR UH	3-108	Polymer	Station – 5.6 kJ/kV
	VariSTAR UH	3-108	Polymer	Station – 6.2 kJ/kV <sup>(1)</sup>
	VariSTAR UH	120-240	Polymer	Station – 10 kJ/kV <sup>(1)</sup>
	VariSTAR UX	3-108	Polymer	Station – 10 kJ/kV <sup>(1)</sup>
	VariSTAR UXL	3-360 kV	Polymer	Station – 15 kJ/kV <sup>(2)</sup>
General Electric	Tranquell	2.7-612	Porcelain	Station
	Tranquell	3-120	Porcelain	Intermediate
Hubbell Power Systems (Ohio Brass)	PVI-LP	3-72	Polymer	Intermediate
	PVIA	3-72	Polymer	Intermediate
	PVI	3-144	Polymer	Intermediate
	EVP	3-288	Polymer	Station
	SVN	54-444	Polymer	Station
	MVN	54-444	Porcelain	Station
Joslyn	Type ZS	3-240	Porcelain	Station
	Type ZSH	258-468	Porcelain	Station
	Type ZIP	3-120	Polymer	Intermediate
	Type ZSP	3-144	Polymer	Station
MagneTek	ZSE-E2A	3-39	Porcelain	Station
	ZSE-E3A	45-312	Porcelain	Station
Siemens Power	3EQ1	36-240	Polymer	Station
	3EQ4	96-444	Polymer	Station
	3EP2	12-384	Porcelain	Station
	3EP4	12-150	Porcelain	Station
TE Connectivity	PBA	3-192	Polymer	Intermediate

\*For instructions concerning application at substations refer to RUS Bulletin 1724E-300, "Design Guide for Rural Substations." In the purchase of arresters, care should be taken to select the type and voltage rating in accordance with the line voltage and the type of construction (grounded or ungrounded).

(1) Energy ratings based on single impulse ratings.

(2) Meets Class H energy levels per IEEE Std C62.11™-2012 standard.

af – Cutouts, Distribution, Open

Manufacturer	Type	Voltage Rating
ABB	ICX	15, 27 kV
	LBU-II	15, 27 kV
Advanced Rubber Products	LCNL-15 – polymer (load break)	15 kV
	LCNL-27 – polymer (load break)	27 kV
	LCNL-36 – polymer (load break)	36 kV
	CSNL-15 – polymer	15 kV
	CSNL-27 – polymer	27 kV
	CSNL-36 – polymer	36 kV
Aluma-Form, Inc.	CPG-15 (porcelain)	15 kV
	CPG-27 (porcelain)	27 kV
	CSG-15 (polymer)	15 kV
	CSG-27 (polymer)	27 kV
Eaton	S1	15, 27 kV
	L (porcelain)	15, 27 kV
	L (polymer)	15, 27 kV
Hubbell (Chance)	C	15, 27, 35 kV
	C (load break)	15, 27, 35 kV
	C-Polymer	15, 27 kV
	C-Polymer (Load break)	15, 27 kV
Kearney/Eaton	HX	15, 27 kV
Peak Demand Inc.	FCP series	15, 27, 36kV
Power Line Hardware	DHC	15, 27 kV
	SIL (polymer)	15, 27 kV
MacLean Power Systems	XS-Polymer	15, 27 kV
Southern States	Series 66	15, 27 kV
	Series 70	15 kV
United Copper Industries	APD1516100110	15 kV
	APD2712100125	27 kV

NOTE: The buyer should specify the load rating, voltage rating, interrupting rating and required accessories. Cutouts used on underground riser poles should be load break type or have hooks for portable load interrupters.

af – Cutouts, Distribution, Open

Manufacturer	Type	Voltage Rating
IUSA	C (porcelain)	15, 27 kV
	C (polymer)	15, 27 kV

NOTE: The buyer should specify the load rating, voltage rating, interrupting rating and required accessories. Cutouts used on underground riser poles should be load break type or have hooks for portable load interrupters.

af - Cutout, open-link fuse support

<u>Manufacturer</u>	<u>Mounting</u>	<u>12.5/7.2 kV 50 amp.</u>	<u>24.9/14.4 kV 50 amp.</u>
Eaton	Crossarm Bushing	FT1A2 FT10A3	FT1A4 -
Kearney/Eaton	Crossarm Bushing	6484-55 6483-59	- -

NOTE: The open link fuse supports listed above are fuse supports only and have no inherent interrupting capacity. They should be used with fuse links capable of interrupting at least 1200 amperes and for transformer protection only.

af - Power Fuses, Substation

Manufacturer	Type	Voltage Rating (kV)
Eaton	CMU (Boric acid, non-refillable)	15-34.5
Eaton (Cutler-Hammer)	RDB (Boric acid, refillable)	15-34.5
	DBA (Boric acid, non-refillable)	46-69
	DBU (Boric acid, non-refillable)	15-34.5
Kearney/Eaton	HX	15
	HX	27
S & C Electric*	SMD (Boric Acid)	15-138
Southern States	Series P	15-161

\*Available with porcelain insulators. "Available with "Cypoxy" cycloaliphatic epoxy insulators 34.5 kV on request.

NOTE: All fuses listed on this page should be furnished with NEMA standard insulators. The buyer should specify the current rating, voltage rating, interrupting rating and required accessories.

af - Cutouts, Distribution, Open

Manufacturer	Type	Voltage Rating	Conditions
Peak Demand Inc.	FCS series (polymer)	15, 27, 36kV	To obtain experience.



af - Cutouts, Distribution, Open  
with Linkbreak Attachment

Manufacturer	Type	Voltage Rating	Conditions
Hubbell	C	15, 27 kV	1. To obtain experience. 2. Limited to 100 amp cutouts. 3. To be used only with Hubbell (Chance), Eaton and Kearney fuses. Will not break S&C and some other fuse types.
	C-Polymer	15, 27, 35kV	1. To obtain experience. 2. Limited to 100 amp cutouts. 3. To be used only with Hubbell (Chance), Eaton and Kearney fuses. Will not break S&C and some other fuse types.

ag - Fuses, Current Limiting, Backup

Manufacturer	Conditions
<u>ABB</u> 15 kV Class Type CLTX, 25K/15T 25 kV Class Type CLTX, 25K/15T	1. To obtain experience. 2. Must be used in series with external expulsion fuse 25K OR 15T or smaller or with CSP transformers 50 kVA or smaller.
<u>Eaton</u> 15 kV Class FAH series 25 kV Class FAH series	Same as above.
<u>General Electric</u> 15 kV Class 9F59U Series 25 kV Class 9F59U	Same as above.
<u>High-Tech Fuses</u> 15 kV Class No. HTDE23 (X)025 25 kV Class No. HTDE24 (X)025 35 kV Class No. HTDE25 (X)025	Same as above.
<u>Hubbell (Chance)</u> 15 kV Class Type K-Mate 25 Catalog No. C70L-31KA 25 kV Class Type K-Mate 25 Catalog No. C70L-32KA	Same as above.

ah - Tie, insulator, formed type

<u>AFL</u>	DTF "Dist. F Neck Tie w/Pad" (Order for specific conductor size and insulator) DBST "Double Side Tie w/Pad" (Order for specific conductor size and insulator) SPL "Spool Tie for ACSR" (Side tie for use on spool insulator with 1-3/4" Neck) DSTCF "Double support Tie (Order for specific conductor size and insulator) STF "Side Tie w/pad" (Order for specific conductor size and insulator) LTF "Longspan Tie w/pad" (Order for specific conductor size and insulator)
<u>Dulmison</u>	LT "Longspan" top tie (Order for specific conductor size and insulator) ST side tie (Order for specific conductor size and insulator) Type SPL* (Side tie for use on spool insulator with 1-3/4" groove) DBST double side tie (Order for specific conductor size and insulator) DST double support tie (Order for specific conductor size and insulator)
<u>Helical Line Products</u>	HTT Series (Order for specific conductor size and insulator)
<u>Hubbell (Chance)</u>	Super Top-Tie, Type STT for single or double support use, with insulators 2-1/4" through 3-1/2" neck diameter and single support use on spool insulators with 1-3/4" groove diameter (Order for specific conductor size.)
<u>Preformed Line Products</u>	Alloy Side, Spool and Top Ties EZ-WRAP* spool tie (order for specific conductor size) EZ-WRAP Side Ties, EZST-series EZ-WRAP Twin Ties, TT-series WT "Wraplock" (Order for specific conductor size and insulator) S" "Groove-Formed" side tie (Order for specific conductor size and insulator) Spool Tie for ACSR, Type SPL* (Side tie for use on spool insulator with 1-3/4" groove) DST double support top tie (Order for specific conductor size and insulator) DBST double side tie (Order for specific conductor size and insulator) UT-series Distribution Tie

\*Not for side mounting on pin or post insulators.

Conditional List  
ah(1)  
April 2017

ah - Tie, insulator, formed type

Manufacturer	Conditions
<u>Dulmison</u> Type QSPL "Quick Spool" spool tie (Order for specific conductor size)	To obtain experience.

ai - Rods, Ground, 13-mil

Applicable Size: The standard length is 8 feet and catalog numbers listed below are for this length. Longer rods may be required for special conditions.

Copper-covered ground rods are listed with a **13-mil minimum** at any point and a 15-mil average covering of copper. All purchases should specify that a factory certification of the thickness of the copper must accompany the shipment of the rods.

Copper-covered

	<u>5/8"</u>	<u>3/4"</u>
Alumoclad	AL- 588	-
Blackburn	625813MX	-
Boggs	EB-810-13	-
Erico	615883	-
Galvan Industries, Inc.	6258G13	7508G13
Harger	588RUS	
Joslyn	J8338-13	-
Korns	KCG588-13	-
Republic Wire	RGC5883	-
South Atlantic, LLC (Southern Grounding)	C58813	C34813
Wilcor	WA588C	-

ai - Rods, Ground

Applicable Size: The standard length is 8 feet and catalog numbers listed below are for this length. Longer rods may be required for special conditions.

Hot Dip Galvanized Steel

Manufacturer	5/8"	3/4"
Blackburn	-	GR7508
Boggs	G588	G348
	PTG588**	PTG348**
Dixie	D8578	D8618
Erico	815880	813480
	815889**	813489**
Galvan Industries, Inc.	GR6258F	GR7508F
	GR6258FP**	GR7508FP**
Grip-Tite	GT588	GT348
Hubbell (Chance)	8578	8618
	C203-0107**	-
	C203-0377*	-
Joslyn	J5328	J5338
Korns	KG58	KG34
Kortick	K4658	K4678
Line Hardware	GR-588G	GR-348G
Lloyd	6258H	7508H
MacLean (Continental)	U5307	U6338
Porcelain Products	7338	7348
South Atlantic, LLC (Southern Grounding)	ZZ588	Z348
Wilcor	WA8580G	WA8340G

Electro-Galvanized Steel

Apache	G588	G348
	G588PT**	G348PT**
Blackburn	GR6258	-
Calpico	G8580	-
LMP	6258E**	7508E**

Stainless Steel

Erico	685880	683480
Galvan Industries, Inc.	S6258	S7508
Harger	588SS3	-
Wilcor	WA 588-S	WA348-S

\*Rod furnished with clamp.

\*\*Rod furnished with 4 ft., No. 6 tinned or galvanized copper pigtail.

NOTE: The diameter of all galvanized ground rods must meet the latest edition of the National Electrical Safety Code (NESC).

ai - Rods, ground, sectional, 13-mil

Galvanized steel and  
Copper-covered steel

Copper-covered ground rods are listed with a **13-mil minimum** at any point and a 15-mil average covering of copper. All purchases should specify that a factory certification of the thickness of the copper must accompany the shipment of the rods. Rods are copper-covered unless marked galvanized steel.

Sectional Ground Rods

Manufacturer	8' long	10' long	Coupling	Driving studs
<u>Blackburn</u>	6258S13MX	6260S13MX	60C 60CNT2*	60DS 60DSNT*
<u>Demark</u> Galv. Steel	-	-	GRC 58B* GRC 58G*	-
<u>Erico</u>	635883	635803	CR-58/CC-58*	DS58
<u>Galvan Industries, Inc.</u> Galv. Steel	6258G13S	6260G13S	GRC-625G** GRC-34G**	
Copper-covered			60-C 60-TC*	60-DS
<u>Hubbell (Chance)</u> Galv. Steel	C203-0052	8512	8611	-
<u>Joslyn</u> Galv. Steel	- -	- -	J9182 J23282A	J9186 -
<u>South Atlantic, LLC</u> <u>(Southern Grounding)</u>	CS58813 CS34813	CS581013 CS341013	- -	- -

\* Threadless coupling or drive head

\*\* Threadless coupling for galvanized rod

NOTE: The diameter of all galvanized ground rods must meet the latest edition of the National Electrical Safety Code (NESC).

ai - Rods, Ground, 10-mil

These copper-covered ground rods are listed with a **10-mil minimum** at any point. They must also be Underwriters Laboratory (UL) listed. All purchases should verify that rods have official UL mark.

Copper-covered steel

Manufacturer	5/8" x 8'	3/4" x 8'	5/8" x 10'	3/4" x 10'
Erico	615880	613480	615800	613400
Galvan Industries, Inc.	6258	7508		
Southern Grounding Products (South Atlantic, LLC)	C588	C348	C5810	C3410



ai - Rods, ground, sectional, 10-mil

Galvanized steel and Copper-covered steel

Copper-covered ground rods are listed with a **10-mil minimum** at any point. They must also be Underwriters Laboratory (UL) listed. All purchases should verify that rods have official UL mark. Rods are copper-covered unless marked galvanized steel.

Sectional Ground Rods

<u>Manufacturer</u>	<u>Rod</u>				<u>Coupling</u>		<u>Driving studs</u>	
	<u>5/8" x 8'</u>	<u>3/4" x 8'</u>	<u>5/8" x 10'</u>	<u>3/4" x 10'</u>	<u>5/8"</u>	<u>3/4"</u>	<u>5/8"</u>	<u>3/4"</u>
Erico	635880	633480	635800	633400	CR58	CR34	DS58	DS34
Galvan Industries, Inc.	6258S		6260S		60-C		60-DS	
Southern Grounding Products (South Atlantic, LLC)	CS588		CS5810		58C	34C	DS58	DS34

NOTE: The diameter of all galvanized ground rods must meet the latest edition of the National Electrical Safety Code (NESC).

aj - Clamp, Ground Rod

Manufacturer	For 5/8" Copper-covered Rod	For 3/4" Galv. or Stainless Steel Rod	For 5/8" Galv. or Stainless Steel Rod
TE Connectivity - Energy	C-LOK Series	81412-1	81412-1
Blackburn	G5	-	-
Boggs	G31	-	-
Burndy	GRC58	-	-
C & R Products	CRGC-58	-	-
Connector Castings	G5	-	-
Dossert	GNL62H	-	-
*Erico (Cadweld)			
1 ground wire	GR1-161G	GR1-181G	GR1-161G
2 ground wires	GT1-161G	GT1-181G	GT1-161G
Erico	EHL58C1T	-	EHL58G1T
	EHL58C1K	-	EHL58G1K
	EHL58C1G	-	EHL58G1G
Eritech (Carolina Galv./Knight)	CP 58	UCSS	-
*FCI Burndy	Type BCR-1	Type BCR-1	Type BCR-1
	BS-2012	BS-2017	BS-2012
Galvan Industries, Inc.	G5	-	-
	SRC	SRC	SRC
	SRC-SS	SRC-SS	SRC-SS
	DGC-5844	-	-
	DGC-5866	-	-
	G-580	-	-
Greaves/Mercury			
*Harger			
1 ground wire	G11-588	G11-348	G11-588
2 ground wires	G21-588	G21-348	G21-588
Hubbell (Anderson)	GC-5	-	-
IlSCO	GRC-58	-	-
Joslyn	J8392AB	J25985	J25932
Kortick	K4647	-	-
Lew Electric Fittings	GRC-5/8"	-	-
Line Hardware	RC-58CE	-	-
Penn-Union	CEB-2	CEB-3-TN	CEB-2-TN
MacLean (Reliable)	E58	3459	3459
*Thermoweld	Type CR-1	Type CR-1	Type CR-1
	M-2012	M-2017	M-2012
Wilcor	HGR5/8	WAU 5834-B	WAU 5834-B

\*Includes disposable molds.

aj - Clamp, ground rod

Manufacturer	Conditions
<u>Burndy</u> YGHP (for 5/8" copper-covered rods)	To obtain experience.
<u>DeMark</u> Copperhead (for 5/8" copper-covered, galvanized, and stainless rods)	To obtain experience.
<u>DMC Power</u> ** GC***B***-625 (for 5/8" steel rods) GC***B***-662 (for 5/8" copper clad rods) GC*3/4***-750 (for 3/4" steel rods)	To obtain experience.
<u>Line Hardwar</u> " RC-3 <sup>3</sup> / <sub>4</sub> " or 5/8" and 3/4") galvanized or stainless steel ground rods	To obtain experience.
<u>Thomas &amp; Betts</u> DGC58-44 (#4 copper ground wire) DGC58-66 (#6 copper ground wire) (for 5/8" copper-covered rods)	To obtain experience.

\*\* These clamps require the use of special swage connection tools for installation. Manufacturer's recommendations should be followed.

al - Staples, ground wire

Applicable Specification: "ANSI C135.14, "Standards for Staples with Rolled or Slash Points"

Length x Spread (inches): Diameter:	1/2 x 1/4 9 gauge Galv. Steel	2 x 1/2 8 gauge Galv. Steel	1-1/2 x 3/8 8 gauge 1/4 copper- Coated	3 x 1-1/16 1/4 Molding
Apollo	AP521-S1672G	AP521-S1570	AP501-S6652	AP500-S6497
Copperweld Bimetallics, LLC	-	CP52	-	-
FWC	FW1672G	FW157	FW6652	FW6497
Hubbell (Chance)	C205-0247	C205-0216	9167	9161
Joslyn	J1672G	J157	J6652	J6497
Kortick	-	-	K247	K236
L & J Industrial Staples	C1525148-G	D2050162-G	C1538162-C	D3090250-C
Larson	-	350453	750233	721312
Lindsey	10248	-	-	10270
Minerallac (Redmore®)	CG1525K	DG2050Q CG2050Q	CC1538Q	DG3090W
MacLean (Continental)	U88	U86	U48	U46

Barbed staples, ground wire

Length x Spread (inches) Diameter	1-1/2 x 3/8 .131 Galv. Steel	2 x 5/8 .165 Galv. Steel	1-1/2 x 3/8 .140 Copper-Coated	3 x 1-1/16 7/32 Galv. Steel
Apollo	AP520-57488HTG	AP501-S66525	-	-
Hubbell Power Systems	C205-0460	C205-0463	C205-0464	C205-0462
Joslyn	J7656	J7672	J7682	J7664
Minerallac (Redmore®)	CG1538M(B)	CG2063T(B)	CC1538P(B)	CG3090N(B)

Staples, alumoweld

Length x Spread (inches) Diameter	2 x 1/2 1/4 gauge	1-1/2 x 3/8 8 gauge	3 x 1-1/16 1/4 molding
Apollo	AP531-S6655AL	AP531-S6652AL	AP530-S7493AL
Minerallac (Redmore®)	-	-	DA3090W

Clip, ground wire

Kearney/Eaton

12326

al - Staples, ground wire

Applicable Specification: ANSI C135.14, "Standards for Staples with Rolled or Slash Points"

<u>Manufacturer</u>	<u>Thickness (gauge)</u>	<u>Conditions</u>
<u>ITW Paslode</u> GS-16 (1-1/2" Galvanized)	16 ga.	To obtain experience.
<u>Fasco</u> EF40-315 (1-9/16" Galv. Steel)	10 ga.	To obtain experience.
EF40-315CU (1-9/16" Copper-Clad)	10 ga.	To obtain experience.

Note: These staples utilize power tools for installation. Use of a hammer for hand driving of these staples is not recommended.

an - Transformers, distribution, pole type  
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

Applicable Specifications: "RUS Specifications for Rural Distribution Transformers," D-10

Listing is by type rather than by catalog number because of the many possible combinations of voltage, kVA and taps and protective equipment.

	7.2/12.5 & 7.62/13.2	14.4/24.9	Dual Voltage
<u>Power Partners, Inc.</u>			
Conventional, single bushing	S-B3	S-B3	S-B3
Self-protected, single bushing	CSP-B3	CSP-B3	CSP-B3
Conventional, two bushing	S-A	S-A	S-A

Type S-B3 may also be obtained with internal fuse, with internal fuse and double gap, and with lightning arrester and open link cutout (Type PC).

Arkansas Electric Cooperative  
Conventional, single bushing

ASE	-	-
-----	---	---

Central Moloney

Conventional, single bushing	AOD	AOD	AOD
Conventional, two bushing	AOD	AOD	AOD
Self-protected, single bushing	DVP	DVP	DVP

The single bushing transformer may also be obtained with bushing mounted cutout and lightning arrester, and with internal fuse and double gap.

Eaton<sup>1</sup>

Conventional, single bushing*	REA-Conv	REA-Conv	REA-Conv
Self-protected, single bushing*	REA-CSP	REA-CSP	REA-CSP
Conventional, two bushing*	REA-Conv	REA-Conv	REA-Conv

Conventional single bushing type may also be purchased with external overload protection and double gap and with bushing mounted cutout and lightning arrester.

\*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

Note:

1. Available with optional covers insulated for 15 kV dielectric strength at additional cost. (Transformer covers with higher electrical insulation, together with other coordinated electrical insulating protective measures, should help to significantly lessen shock and electrocution hazards to raptors, other birds, and small mammals.)

an - Transformers, distribution, pole type  
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

	7.2/12.5 & 7.62/13.2	14.4/24.9	Dual Voltage
<u>ERMCO, INC.</u> <sup>1</sup>			
Conventional, single bushing	CONV	CONV	CONV
Conventional, two bushing	CONV	CONV	CONV
Self-protected, single bushing	CSP	CSP	CSP

The single bushing transformer may also be obtained with double gap and internal fuse (Type DG) or lightning arrester and external cutout (Type COLA).

Dead-front for use in "enclosure: Add "R" (Radial) or "LF" (Loop feed) to designation

<u>Howard Industries</u>			
Conventional, single bushing	REC-C	REC-C	REC-C
Conventional, two bushing	Conv-2B	Conv-2B	Conv-2B
Self-protected, single bushing	REC-P	REC-P	REC-P
Conventional, single bushing, amorphous core	REC-C-AM	REC-C-AM	REC-C-AM
Conventional, two bushing, amorphous core	Conv-2B-AM	Conv-2B-AM	Conv-2B-AM
Self-protected, single bushing, amorphous core	REC-P-AM	REC-P-AM	REC-P-AM

<u>Kuhlman</u>			
Conventional, single bushing	I	I	I
Conventional, two bushing	B	B	B
Self-protected, single bushing	H	H	H

Type I may also be purchased with internal fuse, with internal fuse and double gap (Type G), and with bushing mounted cutout and lightning arrester (Type J).

<u>Moloney Electric, Inc.</u>			
Conventional, single bushing	CONV	CONV	CONV
Conventional, two bushing	CONV	CONV	CONV
Self-protected, single bushing	CSP	CSP	CSP

Note:

1. Available with optional covers insulated for 15 kV dielectric strength at additional cost. (Transformer covers with higher electrical insulation, together with other coordinated electrical insulating protective measures, should help to significantly lessen shock and electrocution hazards to raptors, other birds, and small mammals.)

an - Transformers, distribution, pole type  
Primary Voltages 7.2/12.5, 7.62/13.2 and 14.4/24.9 kV

	7.2/12.5 & 7.62/13.2	14.4/24.9	Dual Voltage
<u>Magnetic Electric</u>			
Conventional, single bushing	AOD	AOD	AOD
Conventional, two bushing	AOD	AOD	AOD
Self-protected, single bushing	AOD	AOD	AOD
<u>Magnetron, S.A.</u>			
Conventional, single bushing, Single Phase 10–500 kVA	X	X	-
Conventional, two bushing, Single Phase 10–500 kVA	X	X	-
<u>Sesco</u>			
Conventional, single bushing	RU	-	-
Self-protected, single bushing	ESP	-	-
Conventional, two bushing	CONV	-	-
Type RU may also be purchased with internal fuse and/or lightning arrester.			
<u>United (Ky. AEC)</u>			
Conventional, single bushing	SC	SC	DSC
Conventional, two bushing	SC	SC	DSC
Self-protected, single bushing	SCP	SCP	DSCP
SC and DSC may be purchased with external fuse and arrester (SP and DSP)			
<u>VanTran</u>			
Conventional, single bushing	CR	-	-
Self-protected, single bushing	CSP-R	-	-
Conventional, two bushing	CD	-	-



an - Transformers, Power  
Single-Phase, Step-Down for Distribution Substation Use

Manufacturer	Primary Voltage (kV)	Nominal OA Capacity (kVA)	
		167 - 833	1250 - 10,000
<u>ABB</u>	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
<u>Central Moloney</u>	34.4	X	
<u>Eaton*</u>	34.4	X	X
	43.8	X	X
<p>*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.</p>			
<u>Kuhlman</u>	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
<u>Pennsylvania Transformer Technology, Inc.</u>	34.4	X	X
	43.8	X	X
	67.0	X	X
<u>Waukesha Electric Systems</u>	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X

All acceptances are based on RUS Specification S-3: Specifications for Step-Down Distribution Substation Transformers, and, 15 kV or 25 kV class secondary voltages.

115 kV and 138 kV transformers may have one step reduced BIL.

an - Transformers, Power  
Three-Phase, Step-Down for Distribution Substation Use

Manufacturer	Primary Voltage - kV	Nominal OA Capacity	
		750 to 3750 kVA	5 to 30 MVA
<u>ABB</u>	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB Types UTS-A, UTT-B and UVW load tap changers.

<u>Eaton*</u>	34.4	X	X
	43.8	X	X

\*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.

Transformers 5 MVA and larger also accepted as load tap changing transformers using Eaton Types 550, 550B and 550C load tap changers.

<u>Kuhlman</u>	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using Siemens-Allis Types TLS and TLH load tap changers

<u>Virginia Transformer</u>	34.4	X	X
	43.8		X
	67.0		X
	115		X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB type UZE and Reinhausen type RMV-2 tap changers.

an - Transformers, Power  
Three-Phase, Step-Down for Distribution Substation Use

Manufacturer	Primary Voltage - kV	Nominal OA Capacity	
		750 to 3750 kVA	5 to 30 MVA
<u>ABB</u>	34.4	X	X
	43.8	X	X
<u>Pennsylvania Transformer Technology, Inc.</u>	34.4	X	X
	43.8	X	X
	67.0	X	X
	115		X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using Eaton Types 550, 550B and 550C load tap changers.

<u>Waukesha Electric Systems</u>	34.4	X	X
	43.8	X	X
	67.0	X	X
	115	X	X
	138		X

Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB Type UZE; Reinhausen RMT-1; Reinhausen RMV-2; or Waukesha Electric Systems Type UZD load tap changers.

Notes:

All acceptances are based on RUS Specification S-3: Specifications for Step-Down Distribution Substation Transformers, and, 15 kV or 25 kV class secondary voltages.

115 kV and 138 kV transformers may have one step reduced BIL.

an - Transformers, Step Ratio, Single Phase,  
Autotransformers or Two-Winding Transformers  
for Use in System Voltage Conversion

<u>Manufacturer</u>	<u>Designation</u>	<u>Size</u>
<u>Howard Industries</u>		
2-WND	STEPS	167-500
AUTO	STEP-AUTO	100-1500

NOTE: Two-winding transformers are self-protected under external short circuit in accordance with ANSI C57.12.90A. Auto-transformers will withstand 25 times rated current under external short circuit in accordance with ANSI C57.12.90A.

an - Transformers, Distribution, Pole Type

Manufacturer	Conditions
<u>Power Partners, Inc.</u> 7.2/12.5, 7.62/13.2 14.4/24.9 kV & Dual Voltage	
Single-phase, single bushing, 25 and 50 kVA pole type distribution transformers with amorphous metal cores.	To obtain experience.
Single-phase, single bushing and two-bushing with internal UMX Under-oil Arrester or with internal "Tranquell" Under-oil Arrester.	To obtain experience.
<u>Eaton<sup>1</sup></u> 7.2/12.5, 7.62/13.2, 14.4/24.9 kV and Dual Voltage*	
Single-phase, single bushing, self-protected, with Magnex Interrupter	To obtain experience.
Above or Conventional, single or two bushing; Type REA Conv. or Self-protected, single bushing Type REA-CSP with Type AZU, MOV, heavy-duty under-oil arrester.	To obtain experience.
<p>*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.</p>	
<u>ERMCO, Inc.<sup>1</sup></u> 7.2/12.5 and 7.62/13.2 and 14.4/24.9 kV	
Single-phase, single bushing with internal Tranquell Under-oil Arrester	To obtain experience.

Note:

1. Available with optional covers insulated for 15 KV dielectric strength at additional cost. (Transformer covers with higher electrical insulation, together with other coordinated electrical insulating protective measures, should help to significantly lessen shock and electrocution hazards to raptors, other birds, and small mammals.)

an - Transformers, Distribution, Pole Type

Manufacturer	Conditions
<u>Prolec GE</u> 12.47/7.2, 13.2/7.62, & 14.4/24.9 kV; 5 through 167 kVA Single bushing and two bushing Conventional & self-protected and 12.47/7.2 x 24.9/14.4 dual voltage	To obtain experience.
<u>Howard Industries</u> 7.2/12.5, 7.62/13.2, 14.4/24.9 kV and Dual Voltage  Single-phase, single bushing, and two bushing with internal "AZU" or "Tranquell" under-oil arrester	To obtain experience.
<u>Kuhlman</u> 7.2/12.5 kV and 7.62/13.2 kV Toroform design 10, 15, & 25 kVA	To obtain experience.
<u>NECO</u> 7.2/12.5 kV and 14.4/24.9 kV Single-phase, two bushing, 10-50 kVA, Conventional	To obtain experience.
<u>VanTran</u> 14.4/24.9 kV and Dual Voltage  Conventional, single bushing Type CR  Conventional, two bushing Type CD  Self-protected, single bushing Type CSP-R	To obtain experience.  To obtain experience.  To obtain experience.

an - Transformers, Distribution, Pole Type  
with non-porcelain secondary bushings

Manufacturer	Conditions
<u>Eaton*</u> Fully or conditionally accepted with Central Moloney polymer secondary bushings <small>*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.</small>	To obtain experience.
<u>ERMCO, INC.<sup>1</sup></u> Fully or conditionally accepted with Central Moloney polymer secondary bushings	To obtain experience.
<u>Howard Industries</u> Fully or conditionally accepted with Central Moloney polymer secondary bushings	To obtain experience.
<u>Kuhlman</u> Fully or conditionally accepted with Central Moloney polymer secondary bushings	To obtain experience.
<u>Magnetic Electric</u> Fully accepted with Central Moloney polymer secondary bushings	To obtain experience.
<u>Prolec GE</u> Fully accepted with Celeco and H.J. International polymer secondary bushings	To obtain experience.
<u>United (Ky. AEC)</u> Fully accepted with Central Moloney polymer secondary bushings	To obtain experience.

Note:

1. Available with optional covers insulated for 15 KV dielectric strength at additional cost. (Transformer covers with higher electrical insulation, together with other coordinated electrical insulating protective measures, should help to significantly lessen shock and electrocution hazards to raptors, other birds, and small mammals.)

Conditional List  
an(2)  
July 2009

an - Transformers, Power  
Single-Phase, Step-Down  
for Distribution Substation Use

Conditions for Acceptance: "E" - To obtain experience  
"T" - Manufacturer to furnish RUS with satisfactory test results  
(Only performance specifications have been submitted)

Manufacturer	Primary Voltage - kV-	Nominal OA Capacity (kVA)	
		167 - 833	1250 - 10,000
<u>Delta-Star</u>	34.4	E	E
	43.8	E	E
	67.0	E	T
	115	-	T
<u>ESCO</u>	34.4	E	-
<u>Ferranti-Packard</u>	67.0	T	E
<u>Industrias IEM, S.A. de C.V.</u>	67	-	E

All acceptances are based on RUS Specification S-3: Specifications for Step-Down Distribution Substation Transformers, and 15 kV or 25 kV class secondary voltages.

115 kV and 138 kV transformers may have one step reduced BIL.



an - Transformers, Power  
Three-Phase, Step-Down  
for Distribution Substation Use

Conditions for Acceptance: "E" - To obtain experience  
"T" - Manufacturer to furnish RUS with satisfactory test results  
(Only performance specifications have been submitted)

Manufacturer	Primary Voltage - kV	Nominal OA Capacity	
		750 to 3750 kVA	5 to 30 MVA
<u>Delta Star</u>	34.4	E	E
	43.8	E	E
	67.0	E	E
	115	-	E
	138	-	T
Transformers 5 MVA and larger also accepted as load tap changing transformers using Seimens-Allis Types TLS and TLH-21 load tap changers.			
<u>Ferranti-Packard</u>	34.4	E	T
	67.0	T	E
	115	-	E
<u>GE-Prolec</u>	67	-	E
	115	-	E
	138	-	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using Reinhausen type RMV-II, Reinhausen type RMV-A, and ABB type UZE load tap changers.			
<u>Howard Industries</u>	115	-	E
	138	-	E
<u>Hyundai Heavy Industries Co., Ltd.</u>	115	-	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB type UZE and Reinhausen type RMV-II load tap changers.			
<u>Industrias IEM, S.A. de C.V</u>	115	-	E
<u>MGM</u>	34.4	E	T
	43.8	E	T
	67.0	T	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using ABB Types UTS-A and UTT-B load tap changers.			
<u>CG Power Systems USA, Inc.</u>	34.4	-	E
	67.0	-	E
	115	-	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using Reinhausen type RMV-II, Reinhausen type RMV-A, and ABB type UZE load tap changers.			
<u>Uptegraff</u>	34.4	T	E
	43.8	T	E

Conditional List  
an(3.1)  
November 18, 2020

an - Transformers, Power  
Three-Phase, Step-Down  
for Distribution Substation Use

Conditions for Acceptance: "E" - To obtain experience  
"T" - Manufacturer to furnish RUS with satisfactory test results  
(Only performance specifications have been submitted)

Manufacturer	Primary Voltage - kV	Nominal OA Capacity	
		750 to 3750 kVA	5 to 30 MVA
<u>Georgia Transformer</u>	138	-	E
<u>WEG</u>	67.0	-	E
	115	-	E
	138	-	E
Transformers 5 MVA and larger also accepted as load tap changing transformers using Reinhausen type RMV-II load tap changers.			
<u>Howard Industries</u>	67.0	-	E

All acceptances are based on RUS Specification S-3: Specifications for Step-Down Distribution Substation Transformers, and 15 kV or 25 kV class secondary voltages.

115 kV and 138 kV transformers may have one step reduced BIL.

an - Transformers, Step Ratio, Single Phase,  
Autotransformers or Two-Winding Transformers  
for Use in System Voltage Conversion

Condition of Acceptance: To obtain experience

Manufacturer	Designation	Size
<u>Power Partners, Inc.</u>		
2-WND	"Jumbo"	167-500
<u>Central Moloney</u>		
2-WND	AOD	167-500
<u>Eaton*</u>		
2-WND	"Round-Coil"	167-500
AUTO	MEPS-AUTO	167-1000
*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.		
<u>Delta Star</u>		
2-WND	LTD	167-500
AUTO	LTD-A	167-1000
<u>General Electric</u>		
2-WND	HS STEP	167-500
AUTO	HS STEP	167-1000

NOTE: Two-winding transformers are self-protected under external short circuit in accordance with ANSI C57.12.90A. Auto-transformers will withstand 25 times rated current under external short circuit in accordance with ANSI C57.12.90A.

ao-1  
July 2009

ao - Bolt, strand eye, straight (thimble eye)

Applicable Specification: ANSI C135.4, "Standards for Galvanized Ferrous Eye Bolts and Nuts for Overhead Line Construction."

Applicable Sizes: 5/8 inch, 6 through 3/4 inch length 3/4 inch, 8 through 12 inch length

The following manufacturers have shown compliance with the applicable specification:

Hubbell (Chance)  
Joslyn Manufacturing Company  
Kortick Manufacturing Company  
MacLean (Continental)

ap – Clamp, hot line  
Copper and Copperweld-copper Conductor  
(Clamps with internal springs and enclosed threads)

<u>Conductor</u>	<u>Conductor Size</u>
Copper:	6 thru 2/0
Copperweld-copper:	8A thru 2A
<hr/>	
<u>Manufacturer</u>	
AFL	HT1-563/563RUS HT2-858/563RUS
Blackburn Connector Products, Inc.	HLC 2108 HTC 100 HTC 100-6 HTC 200 HTC 200-4
Electric Motion Company	EM HLC-101
H-J Enterprises	UBBC20-001
Hubbell (Anderson)	BC-2/0
Hubbell (Chance)	S1520CC
Hubbell (Fargo)	GH-100S
	GH-201 (For use with CL Fuse)
Ideal	3532
MacLean (Reliable)	C1520
Penn-Union	HLC-020-LS
Richards Manufacturing, Sales Inc.	BHLC-100

ap - Clamp, hot line  
ACSR with armor rods  
Clamps listed below have spring action and enclosed thread chambers.

Manufacturer	Tap Conductor	Conductor Size				
		477 & 336.4	4/0 & 3/0	2/0	1/0 & 2	4
Aluma-Form	Aluminum Copper		AF-1540 AF-1540	AF-BC20 AF-BC20	AF-1530 AF-1530	AF-BC20 AF-BC20
AFL	Aluminum	HT2-858/563RUS HT3-1125/563RUS	HT1-563/563RUS HT2-858/563RUS	HT1-563/563RUS HT2-858/563RUS	HT1-563/563RUS	HT1-563/563RUS
	Copper	HT2-858/563RUS HT3-1125/563RUS	HT1-563/563RUS HT2-858/563RUS	HT1-563/563RUS HT2-858/563RUS	HT1-563/563RUS	HT1-563/563RUS
Connector Mfg.	Aluminum		HL 4/0	-	-	-
	Copper		-	-	-	-
Connector Products, Inc.	Aluminum	HTC 200 HTC 200-4 HTC 300	HTC 100 HTC 100-6 HTC 200 HTC 200-4	HTC 100 HTC 100-6 HTC 200 HTC 200-4	HTC 100 HTC 100-6	HTC 100 HTC 100-6
	Copper	HTC 200 HTC 200-4 HTC 300	HTC 100 HTC 100-6 HTC 200 HTC 200-4	HTC 100 HTC 100-6 HTC 200 HTC 200-4	HTC 100 HTC 100-6	HTC 100 HTC 100-6
H-J Enterprises	Aluminum		-	UBBC30-001	UBBC30-001	UBBC30-001
	Copper		-	UBBC30-001TP	UBBC30-001TP	UBBC30-001TP
Hubbell (Anderson)	Aluminum		AC-800	AH-4	AH-4	AH-4
	Copper		AC-800-GP	AH-4-GP	AH-4-GP	AH-4-GP
Hubbell (Chance)	Aluminum		S1540-AA	S1540-AA	S1530-AA	S1530-AA
	Copper		S1540-AC	S1540-AC	S1530-AC	S1530-AC
Hubbell (Fargo)	Aluminum		GH-202AL	GH-202AL	GH-101A	GH-101A
	Copper		GH-102AC	GH-102AC	GH-101AC	GH-101AC
MacLean (Reliable)	Aluminum		-	-	C1530A	C1530A
	Copper		-	-	C1530A	C1530A
Penn Union	Aluminum		-	-	HLCA-040	HLCA-040
	Copper		-	-	HLCA-040	HLCA-040
Richards Manufacturing, Sales Inc.	Aluminum Copper				AHLC300-TN	AHLC300-TN
Utilco	Aluminum		-	HLC-397	-	HLC-40
	Copper		-	-	-	-

ar-1  
July 2009

ar - Wireholder

Applicable specification: "RUS Specification for Service Wireholders," D-15

	With #22 Wood Screw
Blackburn	SW3
Hubbell (Chance)	3-11-44
Porcelain Products	1986

NOTE: For triplex type service cable see clevis type wireholders on page bt-1.

Conditional List  
ar(1)  
July 2009

ar - Wireholder  
(with #22 wood screw)

Manufacturer	Conditions
<u>Hubbell Power Systems (Chance)</u> C207-0138 (nylon alloy)	To obtain experience.
<u>Joslyn</u> J089Z (nylon alloy)	To obtain experience.



as-1  
July 2009

as - Clevis, service swinging

Applicable Specifications: "RUS Specifications for Service Swinging Clevises," D-7

<u>Manufacturer</u>	<u>Clevis Only*</u>	<u>Clevis with Wet Process Spool</u>	<u>Clevis with Dry Process Spool</u>
Hubbell (Chance)	1948C	1948C-C909-1031	1948C-0606
Joslyn	J1614	-	-
Kortick	K9260	K9141	K9142
MacLean (Continental)	U32004	U31003	U31004

\*Catalog number does not include spool; for spool insulators see Item cm.

at-1  
July 2009

at - Guy Marker, 8 Foot Length

<u>Steel</u>		
<u>Manufacturer</u>	<u>Full Round</u>	<u>Half Round</u>
Joslyn	J1618	J1528
Kortick	K3729	-

at - Guy Marker  
8 Foot Length  
Plastic or Fiberglass

Manufacturer	Catalog Number
Auburn Extrusions	TK-808 (Yellow) (with bolt type clamp)
Charles Industries	12-08GWMYC-FR
Custom Plastics	CPI-100XX-PVC Series
Dulmison	HGG-OL8Y-C (Yellow)*
Electrical Materials	70-7 tie G (Gray)* 70-7 tie Y (Yellow)* 70-7 tie O (Orange)* 70-7 tie YORS (Yellow with Orange Stripes)*
Hubbell (Chance)	96-PBG-2 (Gray) 96-PBG-2Y (Yellow) 96-PBG-2ORG (Orange) 96-FRPMR-GRY (Gray)* 96-FRPMR-YEL (Yellow)* 96-FRPMR-ORG (Orange)* 96-FRPMR-GRN (Green)*
Jabat, Inc.	BU31020YE (Yellow) ILQT2291 (Yellow)
Joslyn	J1491Y (Yellow) J1491G (Gray) J5518 (Yellow)*
Mangrum	R-8-Y
Osmose	OZ-25-18R (Yellow)
Preformed Line Products	PG-5508 (Gray)* PG-5518 (Yellow)*
Radar	6032B (Yellow)*
Vaughn	003-7140 (Gray)* 004-7140 (Yellow)* 005-7140 (White)*
Virginia Plastics	TG-137-8G (Gray)* TG-137-8Y (Yellow)* FG-8G (Gray)** FG-8Y (Yellow)**

\* For use with formed or automatic type deadends for guy strand; will not fit over bolt type guy clamps.

\*\* Available with either 1 or 2 bolt clamps.

at - Guy Marker  
(Non-Flame Retardant)  
8 Foot Length  
Plastic or Fiberglass

Manufacturer	Catalog Number
Central Moloney, Inc.	70383818 w/Cable Tie 70383819 w/Metal Clamp
Custom Plastics	CPI-100XX-PVC Series
Charles Industries	12-08GWMYC
Joslyn	J5718 (Yellow)* J1493Y (Yellow)
L. F. Manufacturing	MS-8-Y
Petroflex	P100-SDR17 Series
Preformed Line Products	PG (Poly) Series
R&M Plastics	GGY-TU-8 RMY GG-SM-8*
Radar Engineers	6034 and 6036
Virginia Plastics	TGP-16 PF

\*For use with formed or automatic type deadends for guy strand; will not fit over bolt type guy clamps.

at - Reflective Guy Marker, 8-foot length

Plastic or Fiberglass

Manufacturer	Conditions
--------------	------------

av – Conductor, ACSR

Applicable Specification: ASTM Specification B 232

Preferred Sizes:

<u>Distribution</u>	<u>Transmission</u>
4 – 6/1	1/0 – 6/1
4 – 7/1	2/0 – 6/1
2 – 6/1	3/0 – 6/1
2 – 7/1	4/0 – 6/1
1/0 – 6/1	266.8 kcmil – 26/7
2/0 – 6/1	336.4 kcmil – 26/7
3/0 – 6/1	477 kcmil – 26/7
4/0 – 6/1	556.5 kcmil – 26/7
266.8 kcmil 18/1	795 kcmil – 26/7
336.4 kcmil 18/1	954 kcmil – 54/7
477 kcmil 18/1	

NOTE: Larger sizes may be used where the engineer's study shows they are required.

The following manufacturers have shown compliance with the applicable specifications:

Alcan Cable  
Alubar  
Centelsa  
Conductores Monterrey S.A. de C.V.  
Condumex  
Encore Wire Corporation  
General Cable  
Kobrex S.A. de C.V.  
Marmon Utility LLC (Hendrix/Kerite)  
Midal Cables Ltd.  
Nehring  
Nexans Canada  
Nexans Korea  
Noranda  
Phelps Dodge  
Phelps Dodge – Honduras  
Phelps Dodge – Mexico  
Procables S.A.  
Prysmian  
Southwire  
Synergy Cables USA, Ltd.  
Taihan Electric Wire  
WTEC

NOTES:

1. Conductors with 18/1 stranding have different sag characteristics than conductors with 6/1 or 26/7 stranding. This difference in sag characteristics must be taken into consideration in the line design.
2. 266.8 kcmil 26/7, 336.4 kcmil 26/7, and 477 kcmil 26/7 may be used for distribution underbuild on transmission lines.

av - Conductor, copper

Applicable Specifications: ASTM Specification B1 for hard-drawn solid  
ASTM Specification B8 for hard drawn stranded and soft stranded  
ASTM Specification B3 for soft or annealed solid

Preferred Sizes: Hard-drawn solid - 4 and 6  
Soft or annealed solid - 4 and 6  
Hard-drawn stranded - 2x3, 1/0 x 7, 2/0 x 7  
Soft stranded - 4 and 6

The following manufacturers have shown compliance with the applicable specifications:

Alan Wire Company

Conductores Monterrey S.A. de C.V.

Condumex

Encore Wire Corporation

General Cable

Hickory Wire, Inc.

Nehring

Procables S.A.

Republic Wire

Rome Cable

Seal Wire Company

Service Wire Company

Southwire

av - Conductor, Copper and Copper-clad steel

Applicable Specification: ASTM Specification B 229

<u>Preferred Sizes</u>	
<u>Distribution</u>	<u>Transmission</u>
8A	1/0 F
6A	2/0 F
4A	3/0 F
2A	4/0 F

The following manufacturers have shown compliance with the applicable specification for the sizes indicated:

Copperweld Bimetallics, LLC	(All sizes)
Southwire	(2A and smaller)



av - Conductor, Service  
(Single Conductor)

Manufacturer	Aluminum	Copper
Alcan Cable	x	-
Conductores Monterrey	x	-
Condumex	x	x
Encore Wire Corporation	x	-
General Cable	x	x
Nehring	x	-
Nexans Canada	x	-
Prysmian	x	x
Rome Cable	x	x
Southwire	x	x

Applicable Specification: ICEA S-95-658 / NEMA WC70

Insulation: Cross-linked thermosetting polyethylene or equal.

Conductor: MHD copper or HD (Aluminum 1350) aluminum (Compact or compressed stranded conductor is acceptable.)

Marking: Manufacturer's name and type of insulation shall be clearly shown in durable markings on the surface of the insulation at intervals no greater than 24 inches.

av - Conductor, Service Cable  
(Triplex and Quadruplex)

Manufacturer	Aluminum	Copper
Alcan Cable	x	-
Conductores Monterrey	x	-
Condumex	x	x
Encore Wire Corporation	x	-
General Cable	x	x
Hendrix	x	x
Nehring	x	-
Nexans Canada	x	-
Phelps Dodge	x	x
Phelps Dodge (Honduras)	x	-
Prysmian	x	x
Rome Cable	x	x
Service Wire	-	x
Southwire	x	x

Applicable Specifications: RUS Specification D-2, Specifications for 600 Volt Neutral-Supported Secondary Service Drop Cables.

av - Conductor, Aluminum Alloy

Applicable Specification: ASTM Specification B399

Preferred Sizes:

DISTRIBUTION		TRANSMISSION	
6201	ACSR Equiv.	6201	ACSR Equiv.
48,690 cmil - 7 str.*	4	123,300 cmil - 7 str.**	1/0
77,470 cmil - 7 str.*	2	155,400 cmil - 7 str.**	2/0
123,300 cmil - 7 str.	1/0	195,700 cmil - 7 str.**	3/0
155,400 cmil - 7 str.	2/0	246,900 cmil - 7 str.	4/0
195,700 cmil - 7 str.	3/0	312,800 cmil - 19 str.	266,800 cmil
246,900 cmil - 7 str.	4/0	394,500 cmil - 19 str.	336,400 cmil
		559,500 cmil - 19 str.	477,000 cmil
		652,400 cmil - 19 str.	556,500 cmil
		927,200 cmil - 37 str.	795,000 cmil

\*Not recommended for multiphase lines with span lengths exceeding 300 ft.

\*\*Not recommended for suspension type construction.

The following manufacturers have shown compliance with the applicable specifications:

Manufacturer	Type
Alcan	6201
General Cable	6201
Midal Cables Ltd.	6201
Procables S.A.	6201
Phelps Dodge	6201
Southwire	6201
Conductores Monterrey	6201

av - conductor

Manufacturer	Conditions
<u>Alcan Cable</u> Duplex type, with ACSR or AAAC (6201) conductors using preferred conductor sizes.	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations.
<u>Copperweld Bimetallics, LLC</u> Alumoweld-aluminum 6/1 ACSR/AW, 2, 1/0, 2/0, 4/0 4/3 AWAC, 4, 2, 1/0	1. To obtain experience.
<u>General Cable</u> ACSR/TW, ACSS/TW conductors using preferred conductor sizes.	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Indicate type of steel core wire and class (if applicable) of coating.
<u>Phelps Dodge</u> ACSR/TW, ACSS/TW conductors using preferred conductor sizes.	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Indicate type of steel core wire and class (if applicable) of coating.
<u>Viakon Conductores Monterrey</u> ACSR/AW-TP conductors using preferred conductor sizes.	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Indicate type of steel core wire and class (if applicable) of coating.

Conditional List  
av(2)  
May 8, 2025

av – covered tap wire  
(for use as primary jumpers)

Manufacturer	Conditions
<u>Copperweld</u> Stingray	To obtain experience.
<u>Hendrix</u> TW#2, TW#4	To obtain experience.

Conditional List  
av(3)  
July 2009

av - Conductor, Service  
(Single and Multi-Conductor)

Manufacturer	Conditions
<u>Southwire</u> SIW (Single input wire) type construction in accordance with ASTM B 901.	1. To obtain experience.

Applicable Specification: ICEA S-95-658 / NEMA WC70

Insulation: Cross-linked thermosetting polyethylene or equal.

Conductor: HD (Aluminum 1350) aluminum

Marking: Manufacturer's name and type of insulation shall be clearly shown in durable markings on the surface of the insulation at intervals no greater than 24 inches.

av – Conductor, High Temperature

Preferred Conductor Sizes  
(equivalent in diameter to the following ACSR conductors)\*

Transmission Lines

336.4 kcmil - 26/7  
477 kcmil - 26/7  
556.5 kcmil - 26/7  
795 kcmil - 26/7  
954 kcmil - 54/7  
1272 kcmil - 54/19

Manufacturer	Conditions
<u>3M</u> ACCR – Aluminum Conductor Composite Reinforced	<ol style="list-style-type: none"><li>1. To obtain experience.</li><li>2. Conductor handling and installation shall be in accordance with the manufacturer's recommendations.</li><li>3. Use high temperature accessories approved by the manufacturer and accepted by RUS.</li></ol>
<u>CTC Global</u> ACCC – Aluminum conductor Composite Core	
<u>General Cable</u> ACSS – Aluminum Conductor Steel Support	
<u>Viakon</u> ACSS - Aluminum Conductor Steel Support	

NOTES:

1. Larger sizes may be used where the engineer's study shows they are required.
2. Conductor diameter should be within 10% of ACSR equivalent diameter size.

av – Conductor, Twisted Pair (T-2 & VR type)

Preferred Conductor Sizes  
(equivalent in diameter to the following ACSR conductors)\*

Transmission Lines

336.4 kcmil - 26/7  
477 kcmil - 26/7  
556.5 kcmil - 26/7  
795 kcmil - 26/7  
954 kcmil - 54/7  
1272 kcmil - 54/19

**T-2 type (ACSR-II)**

Aluminum Conductor Steel Reinforced- Twisted Pair  
ACSR or AAAC (6201)

<u>Manufacturer</u>	<u>Conditions</u>
General Cable	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Use accessories recommended by the manufacturer and accepted by RUS
Nexans Canada	

**VR-2 type**

Aluminum Conductor Steel Reinforced- Twisted Pair  
ACSR or AAAC (6201)  
Vibration Damping

<u>Manufacturer</u>	<u>Conditions</u>
Southwire	1. To obtain experience. 2. Conductor handling and installation shall be in accordance with manufacturer's recommendations. 3. Use accessories recommended by the manufacturer and accepted by RUS

NOTES:

1. Larger sizes may be used where the engineer's study shows they are required.
2. Conductor diameter should be within 10% of ACSR equivalent diameter size.



aw - Washer, spring

Clip  
1/4" x 1-3/4" x 3-1/2"

Manufacturer	Bolt Size		
	5/8"	3/4"	7/8"
Allied Bolt, Inc.	7013	7014	-
Hubbell (Chance)	3540	3541	-
Joslyn	J3540	J3541	J3542
Kortick	K2909	-	-
Line Hardware	SCW-58	SCW-34	SCW-78

Double Coil Lock

Manufacturer	Bolt Size			
	5/8"	3/4"	7/8"	1"
Electrical Materials Company	#MW 5/8"	#MW 3/4" #MW3/4EXT	#MW 7/8"	#MW 1"
Allied Bolt, Inc.	1108	1109	1120	1121

ax-1  
February 2011

ax - Cutout and Arrester, Combination

Nominal System Voltage		<u>For 12.5Y/7.2 kV</u>		<u>For 13.2Y/7.6 kV</u>		<u>For 24.9Y/14.4 kV</u>	
Cutout Max. Voltage Rating		<u>7.8 kV</u>		<u>15 kV</u>	<u>15 kV</u>	<u>18 kV</u>	<u>27 kV</u>
Application							
Cutout Current Rating		1ø Trans. <u>50*</u>	1ø Sect. <u>100</u>	3ø Bank 3ø Sect. <u>100</u>	1ø Trans. <u>50*</u>	1ø Sect. <u>100</u>	3ø Bank 3ø Sect. <u>100</u>
Manufacturer	Type Mounting	Catalog Numbers					
ABB	Crossarm Crossarm (L)		7.8 NCX/9 LVG 7.8 LBU-II/9 LVG	15 NCX/10 LVG 15 LBU-II/10 LVG		15 NCX/10 LVG 15 LBU-II/10 LVG	24.9 NCX/18 LVG 24.9 LBU-II/18 LVG
Eaton	Crossarm (L) Transformer Crossarm	AFZS110M010	AFZS510B Series L4B Series (Porcelain) S4B Series (Polymer)	AFZS510C Series L4B Series (Porcelain) S4B Series (Polymer)	AFZS110M010	AFZS510C Series L4B Series (Porcelain) S4B Series (Polymer)	AFZS518D Series L9C or L9d series (Porcelain) S9D Series (Polymer)
Hubbell	Crossarm Transformer Crossarm		C7 Series	C7 Series CP7 Series (Polymer)		C7 Series	C7 Series
Kearney/Eaton	Crossarm Transformer	294072		KE3AB110E-110	294073	KE4AB110E-110	294074 KE7BD109E-110

Either normal duty or heavy duty distribution class arresters listed on page ae-1 are acceptable for use with these combination units.

\*These cutouts have open links and must not be used where fault currents are high or for sectionalizing.

(L) Indicates loadbreak type is available.

az - Pole Numbers and Letters, Metal

Manufacturer	Catalog No.
Almetek Industries, Inc.	"E-Z Tags" - Order by description
Premax Products	1523
Tech Products	Everlast Tag
Electromark	EMB-1.5 EMB-3.0 HOLD-AL1 HOLD-PL1 PERMAGRAVE SLIDE-INS #ET1041-KY-1S PERMAHOLD-AL1 PERMAHOLD-PL1 SLIDE-1S

ba - Bolt, Angle Eye

Thimble Type

Applicable Specification: ANSI C135.4, "Standards for Galvanized Ferrous Eye Bolts and Nuts for Overhead Line Construction"

Applicable Sizes : 5/8 inch, 6 through 12 inch length  
3/4 inch, 8 through 12 inch length

The following manufacturers have shown compliance with the applicable specifications:

Allied Bolt, Inc.  
Hubbell (Chance)  
Joslyn Mfg. and Supply Company  
Kortick Manufacturing Company  
MacLean (Continental)

bb-1  
July 2009

bb - Brace, sidearm vertical

	<u>26" brace 24" bolt-hole spacing</u>	<u>50" brace 24" bolt-hole spacing</u>
Dixie	D6986	D6987
Kortick	K1931	K1932
MacLean (Continental)	U5249	U5250

be - Reclosers, oil and vacuum

Mfr.	Phases	Type	Circuit Voltage	Continuous Rating	Int. Rating	Oil/ Vacuum	Hydraulic/ Electronic
Eaton	1	H	12.5/7.2	5-50	1250	O	H
	1	4H	12.5/7.2	5-100	2000	O	H
	1	L	12.5/7.2	25-100	4000	O	H
	3	6H	12.5/7.2	5-100	2000	O	H
	3	W	12.5/7.2	100-560	10,000	O	H
	3	WE	12.5/7.2	560	10,000	O	H
	3	VSA-12	12.5/7.2	100-560	12,000	V	E
	1	E	24.9/14.4	5-100	2500	O	H
	(Type E available with shunt lockout solenoid for three-phase operation)						
	1	4E	24.9/14.4	50-200	4000	O	H
	3	WV	34.5/19.9	560	8000	O	H
	3	WVE	34.5/19.9	560	8000	O	E
Lexington Switch and Controls	1	A Line Model B	12.5/7.2	5-50	1250	O	H
	1	A Line Model D	12.5/7.2	25-100	2000	O	H
	1	A Line Model K	12.5/7.2	25-100	4000	O	H

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, oil circuit  
12.5/7.2 kV

Manufacturer	Conditions
<u>ABB</u>	
Three phase oil circuit recloser (Shunt trip with static or relay type controls)	
Type ES-400 (15-400 amperes)	To obtain experience.
Type ES-560 (15-560 amperes)	
Type ESM-560 (100-560 amperes)	
Type ES-105 (15-560 amperes)	
<u>Eaton</u>	
Single phase, Type D rated 100 amperes continuous, 10,000 amperes symmetrical	To obtain experience.
<u>Lexington Switch and Controls</u>	
Three phase oil circuit recloser, 50,100 and 280 ampere frames.	To obtain experience.
A Line, Model 3B (5-50 amperes)	
Model 3D (5-100 amperes)	
Model 3K (25-280 amperes)	

24.9/14.4 kV

<u>Lexington Switch and Controls</u>	
Oil circuit recloser,	
Single phase-A Line, Model M rated 100 amperes	To obtain experience.
Three phase-A Line, Model 3M rated 100 amperes	

34.5/19.9 kV

<u>Eaton</u>	
Single phase, Type DV rated 100-280 amperes continuous, 8,000 amperes symmetrical	
	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Reclosers, vacuum interrupter

Manufacturer	Conditions
<u>ABB</u>	
Three phase Type ESVA rated 560/800 amps continuous, 12,000 amps symmetrical, maximum voltage 15.5 kV for 12.5/7.2 kV	To obtain experience.
Three phase Type ESMVA rated 560 amps continuous, 16,000 amps symmetrical, maximum voltage 15.5 kV for 12.5/7.2 kV	To obtain experience.
<u>Eaton</u>	
Single Phase Type V4E rated 15 to 200 amperes continuous, 6,000 amperes symmetrical, maximum voltage 27 kV for 24.9/14.4 kV.	To obtain experience.
Single phase, Type V4H rated 5-100 amperes continuous, 2,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Single phase, Type V4L rated 50-100 amperes continuous, 6,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Three phase, Type V6H rated 5-100 amperes continuous, 2,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.



be - Recloser vacuum interrupter

Manufacturer	Conditions
<u>Eaton</u>	
Three phase, Type VW rated 560 amperes continuous, 2,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Three phase, Type VWE rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Three phase, Type VSA-16 rated 560 amperes continuous, 16,000 amperes symmetrical, maximum voltage 15.5 kV for 12.5/7.2 and 13.2/7.62 kV	To obtain experience.
Three phase, Type VWV27 rated 560 amperes continuous 12,000 amperes symmetrical, maximum voltage 27 kV for 24.9/14.4 kV	To obtain experience.
Three phase, Type VWVE27 rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 27 kV for 24.9/14.4 kV	To obtain experience.
Three phase, Type VWV38 rated 50-560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 38 kV for 34.5/19.9 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, vacuum interrupter

Manufacturer	Conditions
<u>Eaton</u> Three phase, NOVA-NXT rated 800 amperes continuous, 12,500 amperes symmetrical, maximum voltage 15 kV, 27 kV and 38 kV	To obtain experience.
Three phase, Type VWVE38 rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 38 kV for 34.5/19.9 kV	To obtain experience.
Three phase, Type VSO-12 rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 38 kV for 34.5/19.9 kV	To obtain experience.
Three phase, Type VSO-16 rated 560 amperes continuous, 12,000 amperes symmetrical, maximum voltage 38 kV for 34.5/19.9 kV	To obtain experience.
Single phase, type VXE electronically controlled, vacuum interrupting, rated 10-200 amps continuous, 8000 amperes symmetrical, maximum voltage of 15.5 kV for 12.5/7.2 kV & 27 kV for 24.9/14.4 kV systems	To obtain experience.
<u>Engineering &amp; Equipment de Mexico</u> Three phase, type, EEVW15, rated 25 to 560 amp continuous, 12000 amp interrupting, maximum voltage 15.5 kV for 12.4/7.2 kV.	To obtain experience.
<u>Hubbell Power Systems</u> Single phase, Type VERSA-TECH electronically controlled, vacuum interrupting, rated 400 amperes continuous, 8,000 amperes symmetrical, maximum voltage of 27 kV for 24.9/14.4 kV systems	To obtain experience.
<u>Joslyn</u> Three phase, Type JVR, SF6 insulation, rated 400 amps continuous, 6,000 amperes symmetrical, maximum voltage 15 kV for 12.5/7.2 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, vacuum interrupter

Manufacturer	Conditions
<u>Lexington Switch</u> Single phase, type EV627 rated 400 amp continuous, 6000 amp interrupting, maximum voltage 27 kV for 24.9/14.4 kV	To obtain experience.
Single phase, type EV815 rated 400 amp continuous, 8000 amp continuous, maximum voltage 15.5 kV for 12.9/14.4 kV	To obtain experience.
<u>S&amp;C Electric</u> Single phase, TripSaver II (cutout mounting), rated 100 amp continuous, 4000 amp and 6300 amp interrupting, maximum voltage 15.5 kV for 12.9/14.4 kV and 27 kV for 24.9/14.4 kV	To obtain experience.
<u>Whipp &amp; Bourne</u> Three-phase, Type GVR, SF6 insulation with vacuum interruption, 560 amps maximum continuous, 12000 amps RMS symmetrical interruption for 15.5 kV and 27 kV, 8000 amps RMS symmetrical for 38 kV. 15.5 kV maximum voltage for 12.5/7.2 kV, 27 kV maximum voltage for 24.9/14.4 kV, 38 kV maximum voltage for 34.5/19.9 kV.	To obtain experience.
<u>Siemens</u> Single phase, CMR rated 630 amperes continuous, 12,500 amperes symmetrical, maximum voltage 15 kV, 27 kV and 38 kV	To obtain experience.
Multi-phase, CMR rated 630 amperes continuous, 12,500 amperes symmetrical, maximum voltage 15 kV, 27 kV and 38 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, SF6 interrupter

Manufacturer	Conditions
<u>Hawker Siddeley</u> Type PMR-3/15 rated at 560 amperes continuous, 12,000 amperes symmetrical maximum, 15.5 kV Type PMR-3/27 rated at 560 amperes continuous, 12,000 amperes symmetrical maximum, 24.9 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, vacuum interruption with solid dielectric

Manufacturer	Conditions
<u>ABB</u> Single phase, Type OVR electronically controlled, vacuum interruption, solid dielectric, 800 amps maximum continuous, 10000 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Three phase, Type OVR electronically controlled, vacuum interruption, solid dielectric, 630 amps maximum continuous, 12500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Three phase, Type OVR electronically controlled, vacuum interruption, solid dielectric, 800 amps maximum continuous, 16000 amps RMS symmetrical interruption, 38 kV maximum for 34.5/19.9 kV.	
<u>Eaton</u> Three phase, Type NOVA electronically controlled, vacuum interruption, solid dielectric, 560 amps maximum continuous, 12000 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Single Phase, Type NOVA electronically controlled, vacuum interruption, solid dielectric, 400 amps maximum continuous, 8000 amps RMS symmetrical interruption, or 800 amps maximum continuous, 12500 amps RMS symmetrical interruption 15.5 kV maximum for 12.5/7.2 kV, 29.2 kV maximum for 24.9/14.4 kV.	To obtain experience.
Three phase, Type NOVA-TS Triple-Single electronically controlled, vacuum interruption, solid dielectric, 400 amps maximum continuous, 12500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 29.2 kV maximum for 24.9/14.4 kV.	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, vacuum interruption with solid dielectric

Manufacturer	Conditions
<u>G &amp; W Electric Company</u>	
Three phase, electronic, VIPER Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 16,000 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
Single phase, electronic, Viper SP, vacuum interruption, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.
<u>Joslyn Hi-Voltage</u>	
Three-phase, Type TRIMOD 300 series, vacuum interruption, solid dielectric foam, 560 amps maximum continuous, 12000 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV	To obtain experience.
Single-phase, Type TRIMOD 100 series, vacuum interruption, solid dielectric foam, 560 amps maximum continuous, 12500 amps RMS symmetrical interruption, 17.1 kV maximum for 12.5/7.2 kV, 29.3 kV maximum for 24.9/14.4 kV	To obtain experience.
<u>Schneider Electric USA, Inc.</u>	
Three phase, Type U27-12-125-630, solid dielectric insulation, 630 amps maximum continuous, 12500 amps RMS symmetrical interruption, 27 kV maximum for 24.9/14.4 kV - 125 kV BIL.	To obtain experience.
<u>Siemens</u>	
Three phase, Type SDR Recloser, rated 800A maximum continuous, electronically controlled, vacuum interruption, solid dielectric, 12500 amps RMS symmetrical interruption for 15.5 kV, 16000 amps RMS symmetrical interruption for 27 kV, (15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV)	To obtain experience.
<u>S&amp;C Electric Company</u>	
Three phase, IntelliRupter PulseCloser with vacuum interrupter, solid dielectric, 630 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, vacuum interruption with solid dielectric

Manufacturer	Conditions
<b><u>Thomas &amp; Betts</u></b>	
Three phase, electronic, MVR Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27kV maximum for 24.9/14.4 kV, 38 kV maximum for 34.5 kV/19.9 kV	To obtain experience.
Single phase, electronic, MVR Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27kV maximum for 24.9/14.4 kV, 38 kV maximum for 34.5 kV/19.9 kV	To obtain experience.
<b><u>NOJA Power</u></b>	
Three phase, Type OSM15 electronically controlled, vacuum interrupted, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5kV maximum for 12.5/7.2kV.	To obtain experience.
Three phase, Type OSM27 electronically controlled, vacuum interrupted, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 27kV maximum for 24.9/14.4kV.	To obtain experience.
Three phase, Type OSM38 electronically controlled, vacuum interrupted, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 38kV maximum for 34.5/19.9kV.	To obtain experience.
Single Phase, Type OSM38 Series electronically controlled, vacuum interrupted, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 38kV maximum for 34.5/19.9kV.	To obtain experience.
<b><u>Schneider Electric</u></b>	
Single phase, Type W27-ACR-Solid-24-6-125, solid dielectric insulation, 400 amps maximum continuous, 6000 amps RMS symmetrical interruption, 24 kV phase to ground - 125 kV BIL. PN 250010000	To obtain experience

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

be - Recloser, vacuum interruption with solid dielectric

Manufacturer	Conditions
<u>Southern States</u> Three-phase and Single-phase, Gang Operated, type SSR, rated 900A maximum continuous, electrically controlled, vacuum interruption, solid dielectric, 16,000 amps RMS symmetrical interruption for 15.5 kV, 12,500 amps RMS symmetrical interruption for 27 kV	To obtain experience.
<u>Togami Electric Mfg. Co., Ltd.</u> Single phase, electronic, FAULT CLEAR Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 16,000 amps RMS symmetrical interruption, 27 kV maximum for 24.9/14.4 kV.  Three phase, electronic, FAULT CLEAR Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 16,000 amps RMS symmetrical interruption, 27 kV maximum for 24.9/14.4 kV.	To obtain experience.  To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.



bh - Clevis, Service Deadend

Applicable Specification: "RUS Specification for Service Deadend Clevises," D-8

Manufacturer	Clevis Only*	Clevis with dry process spool	Clevis with wet process spool
Hubbell (Chance)	0341	0341-0606	0341-C909-1931
Joslyn	J0313	-	-
Kortick	K9250	K9100	K9099
MacLean (Continental)	U32136	U31136	U36136

\*Catalog number does not include spool; for spool see Page cm.

bi - Gain, Pole

For use with rectangular crossarms

Hubbell (Chance)	4092
Joslyn (Flagg)	PX252
MacLean (Continental)	CAG-44-5

For braceless crossarms (narrow profile construction)

Hubbell (Chance)	PG84XE12
Joslyn (Flagg)	PX182A
MacLean (Bethea)	GCAF-6A
MacLean (Continental)	DEA-65-10A

Transmission

Grid Gains

	Sizes in inches	
	<u>4" x 4"</u>	<u>4" x 9"</u>
Hubbell (Chance)	PG44	PG945
Hughes Brothers	I263	I260
Joslyn (Flagg)	PX122	PX260
MacLean (Bethea)	GSF-44-7	GSFT-95-7
MacLean (Continental)	GGSF-4040-7	GRF-9045-7

bj-1  
July 2009

bj - Guy Hook

Applicable Specification: Edison Electric Institute Specification TD-11- 1951, "Specifications for Guy Hooks and Guy Strain Plates."

Hubbell (Chance)	6584
Joslyn	J1019
Kortick	K4031
MacLean (Continental)	U5310

bk-1  
July 2009

bk - Guy Plate

Applicable Specifications:

Strain Type: Edison Electric Institute Specification TD-11 1951, "Specifications for Guy Hooks and Guy Strain Plates."

Lift Type: None

	Strain Type 4" x 8" x 14 gage	Lift Type 2-1/2" x 7" x 1/4", 2 hole
Almat	K45-1	-
Hubbell (Chance)	6575	7898
Joslyn	J1034	-
Kortick	K4015	K3511
Line Hardware	GSP-1	-
MacLean (Continental)	U5351	UC434

bn-1  
November 2014

bn - clamp, loop deadend

For ACSR

	3/0	2/0	1/0	2	4
AFL	-	413	413	412	411
Blackburn	DLC23	DLC2106	DLC2106	DLC2106	DLC2106
Burndy	-	-	UW25R	UW2R	UW2R
C & R	-	-	CRLD-10	CRLD-10	CRLD-10
Hubbell (Anderson)	LC-74B	LC-71B	LC-70B1	LC-70B	LC-70B
Hubbell (Fargo)	GA-145	GA-145	GA-144	GA-144	GA-144
MacLean (Bethea)	ALD-7373-U	ALD-34-U	ALD-1313-U	ALD-1313-U	ALD-1313-U

bo - Shackle, anchor

Distribution

	<u>20,000 lbs.</u> <u>5/8" Pin</u>
Hubbell (Anderson)	AS-25
Hubbell (Chance)	5801
Joslyn	J2742
Kortick	K4481
Lapp	33852
Lindsey	3260
Line Hardware	AS-1
MacLean (Bethea)	ASH-45
Sur-Loc, Inc.	5500

Transmission

	<u>30,000 lbs.</u> <u>3/4" bolt</u>	<u>50,000 lbs.</u> <u>7/8" bolt</u>
Joslyn	BT3023BNK	BT3036BNK
MacLean (Bethea)	ASH-56-BC	ASH-67-BC

br – Chain Link (End Link)

<u>Manufacturer</u>	<u>Catalog Number</u>
Joslyn	BT-3082
Lapp	6415-HT
Lindsey	3403
MacLean (Bethea)	CL-5
Preformed Line Products	CL-60

bs - Bolt, single upset

Applicable Specifications: "RUS Specifications for Single and Double Upset Spool Bolts," D-5

Diameter, inches:	5/8	5/8	5/8	5/8
Length, inches:	7	8	9	10

Manufacturer

Allied Bolt, Inc.	-	-	1712	1713
Hubbell (Chance)	-	7741	7741-1/2	7742
Joslyn	-	J2342-1/2	J2343-1/2	J2344-1/2
Kortick	K4929	K4950	K4930	K4951
MacLean (Continental)	U3105-1/2	U31053	U31053A	U31054



bt-1  
July 2009

bt - Wireholder, clevis type  
with No. 24 wood screw

(For use with triplex type service cable, Drawing K10C-A)

Hubbell (Chance)	0192*
Joslyn	J075*

\*Catalog number does not include insulator. Use secondary type spool insulator with 1-3/4 inch groove diameter. See page cm-1.

bu - Connector, grounding  
for transformer or other equipment

Manufacturer	Copper Alloy <sup>1</sup>	Plated Copper Alloy <sup>2</sup>	Aluminum Alloy <sup>3</sup>
Blackburn	TTC-4	TTC2P	-
Burndy	EQC632C	EQC632C-TN	-
Dossert	TGCL8-50	TGCL8-50-SN	-
Hubbell (Anderson)	GTCL-23A	GTCL-23A-TP	-
Hubbell (Fargo)	GC-207	GC-207P	GA-220
Line Hardware	TGL-110	TGL-110P	-
Macleam (Reliable)	BVC-207	-	-
Penn-Union	GSE-C1	GSE-C1TN	-
Richards Manufacturing, Sales Inc. (Chin Fong Co., Ltd.)	RTG512	-	-
Tanner	-	GET-1-TN	-

1 - For use with copper type ground wire.

2 - For use with both copper and aluminum type ground wire.

3 - For use with aluminum type ground wire.

bv - Rods, armor

(Includes standard, double insulator, and tapping rods)

Aluminum or aluminum alloy rods for use on ACSR

<u>Manufacturer</u>	<u>Type</u>
AFL	Formed Type
Dulmison	Formed Type
Florida Wire and Cable	Formed Type
Helical Line Products	Formed Type
Helix Uniformed Ltd.	Formed Type
Preformed Line Products	Formed Type

Copperweld rods for copper or CWC conductor

Dulmison	Formed Type
Helical Line Products	Formed Type
Preformed Line Products	Formed Type

Alumoweld rods for aluminum clad steel (Alumoweld)  
Overhead ground wire

Dulmison	Formed Type
Helical Line Products	Formed Type
Preformed Line Products	Formed Type

bx - Splice, automatic

<u>Copper</u>	<u>Hubbell (Fargo)</u>	<u>MacLean (Reliable)</u>
6	GL-111	61
4	GL-112	41
2 x 3	GL-115	-
1/10 x 7	GL-117	107
2/0 x 7	GL-118	207
3/0 x 7	GL-119	307
4/0 x 7	GL-120	407
 <u>CWC</u>		
8A	GL-112	-
6A	GL-113	47
4A	GL-115	27
2A	GL-117	-
 <u>ACSR</u>		
	GL-400A Series*	7650 Series*
<u>Aluminum Alloy (6201 and 5005)</u>	GL-400A Series	AL55 Series

\*For use on conductors 4/0 and smaller only.

bx-1.1  
May 2017

bx - Splice, automatic

Distribution				
Manufacturer	Catalog #	AAC	AAAC	ACSR
Aluma-Form, Inc.	ASC42	#2 & #4	#2 & #4	6/1
	ASC1020	1/0 & 2/0	1/0 & 2/0	1/0 & 2/0
	ASC3040	3/0 & 4/0	3/0 & 4/0	3/0 & 4/0

bx - Splice, automatic

Manufacturer	Conditions
--------------	------------

#### DISTRIBUTION

##### Blackburn

#4, #2 ACSR or 6201 (ACSR equiv.) ATS42	1. To obtain experience.
1/0, 2/0 ACSR or 6201 (ACSR equiv.) ATS1020	2. For use on distribution systems only.
3/0, 4/0 ACSR or 6201 (ACSR equiv.) ATS3040	
266.8, 336.4 kcmil ACSR ATS266336	
477 kcmil ACSR ATS397477	

##### Connector Products, Inc.

2 ACSR (S1000)	1. To obtain experience.
#1 ACSR (S1000)	2. For use on distribution systems only.
#2 AAC (S1000)	
1/0 AAC (S1000)	
2/0 AAC (S1000)	
#2 AAAC (S1000)	
1/0 AAAC (S1000)	

##### Hubbell (Fargo)

AWAC 4 - 4/3 GLA-105	Same as above.
AWAC 2 - 4/3 GLA-110	
AWAC 1/0 - 4/3 GLA-115	

266.8 kcmil ACSR 18/1 GL-410	Same as above.
336.4 kcmil ACSR 18/1 GL-411	
477 kcmil ACSR 18/1 GL-413	

##### MacLean (Reliable)

266.8 kcmil ACSR 18/1 7657	Same as above.
336.4 kcmil ACSR 18/1 7658	
477 kcmil ACSR 18/1 7659	

#### DISTRIBUTION AND TRANSMISSION

##### Hubbell (Fargo)

266.8 kcmil ACSR 26/7	To obtain experience.
336.4 kcmil ACSR 26/7	
477 kcmil ACSR 26/7	

by - Deadend, automatic and formed Type

<u>Conductor Size</u>			
<u>Cu</u>	<u>CWC</u>	<u>Hubbell (Fargo)</u>	<u>Maclean (Reliable)</u>
-	4A	GD-515	27-SDS
-	6A	GD-513	47-SDS
-	8A	GD-512	-
2 x 3	-	GD-515	271
4	-	GD-512	41LD
6	-	GD-511	61LD

#### ACSR

*Blackburn	ATD Series
*Dulmison	AWDG-0805, 0990, and 1135
*Hubbell (Fargo)	GD-400 Series
*MacLean (Reliable)	7650 Series
Preformed	DG Series

\*For use on conductors 4/0 and smaller only.

#### Aluminum Alloy (6201 and 5005)

Blackburn	ATD Series
Hubbell (Fargo)	GD-A Series
MacLean (Reliable)	AL Series
Preformed	DG Series

by - Deadends, automatic and formed type

FORMED TYPE

<u>Manufacturer</u>	<u>Conditions</u>
<u>Preformed Line Products</u>	
AWAC 4 - 4/3 DG-4560	To obtain experience.
AWAC 2 - 4/3 DG-4562	
AWAC 1/0 - 4/3 DG-4565	

AUTOMATIC TYPE

<u>Hubbell (Fargo)</u>	
AWAC 4 - 4/3 GDA-235	To obtain experience.
AWAC 2 - 4/3 GDA-240	
AWAC 1/0 - 4/3 GDA-245	
266.8 kcmil ACSR 18/1 GD-53I5A	1. To obtain experience.
336.4 kcmil ACSR 18/1 GD-53I5A	2. For use on distribution lines only.
477 kcmil ACSR 18/1 GD-5325A	
<u>MacLean (Reliable)</u>	
AWAC 4 - 4/3 5201	To obtain experience.
AWAC 2 - 4/3 5202	
AWAC 1/0 - 4/3 5204	
226.8 kcmil ACSR 18/1 7657 SDS	1. To obtain experience.
335.4 kcmil ACSR 18/1 7658 SDS	2. For use on distribution lines only.
477 kcmil ACSR 18/1 7659 SDS	



bz - Switch, oil

12.5/7.2 kV

	Type	Description
ABB	CSL**	Single-phase, manual and remote manual or elec. control, 200 amp. Three-phase, remote manual or elec. control, 200 amp.
Eaton	NR*	Single-phase, remote elec. control, 200 amp.
	VR*	Three-phase, remote elec. control, 400 amp.
General Electric	FKC-2 FKC-2*	Single and three-phase, manual, 200 amp. Single and three-phase, remote control, 200 amp.
Hubbell Trinetics	CSD	Single-phase, manual, and remote manual or elec. control, 200 amp. Three-phase, remote manual, or elec. control, 200 amp.
	VS	Single Phase 15kV, 95kV BIL, 200A vacuum under oil switch, with 11" creep bushings, manual handle, 120V motor operator, 5-pin receptacle, NEMA type pole mounting hanger, and (2) wildlife guards.

\*Control equipment should be selected in accordance with the requirements of individual installations.

\*\*This item is also available in a special design for use in areas where corrosion is a serious problem.

bz - Switch, oil

24.9/14.4 kV

	<u>Type</u>	<u>Description</u>
Hubbell Trinetics	VS	Single Phase 24kV, 95kV BIL, 200A vacuum under oil switch, with 11" creep bushings, manual handle, 120V motor operator, 5-pin receptacle, NEMA type pole mounting hanger, and (2) wildlife guards.

\*Control equipment should be selected in accordance with the requirements of individual installations.

\*\*This item is also available in a special design for use in areas where corrosion is a serious problem.

bz - Switch, oil

Manufacturer	Conditions
<u>Eaton</u> Capacitor oil switch Type TSC, 38 kV max. 100 ampere capacitor switch, 300 ampere load switch	1. To obtain experience.
Oil switch with 125 kV BIL accessory Type NR, 15 kV, single- phase, remote electric control, 200 amp. at 75 to 100 percent power factor	1. To obtain experience. 2. For use on single- phase taps of 24.9/14.4 kV multi- grounded wye systems.

bz - Switch, vacuum  
(For capacitor switching)

Manufacturer	Conditions
<u>Eaton</u> Type ECS, cycloaliphatic epoxy solid dielectric, vacuum capacitor switch, rated 200 amps, 95kV, 125kV and 150 bil, for use on 15kV, 25kV and 35kV grounded-wye systems	<ol style="list-style-type: none"> <li>1. To obtain experience</li> <li>2. The 25 kV rated switch with 150 kV external bil and 125 kV internal bil can be used in solidly grounded 35 kV applications.</li> <li>3. Bil options can accommodate normal or extra creepage needs. Available in 95/95, 95/125, 125/125, and 125/50 combinations (internal bil kV/external bil kV).</li> </ol>
<u>Joslyn</u> Capacitor vacuum switch, VerSaVac, 200 Amp, 95 or 125 kV BIL, single-phase or three-phase for use on 15 kV systems	<ol style="list-style-type: none"> <li>1. To obtain experience.</li> <li>2. Single-phase switch rated 125 kV BIL may be used on single- phase taps of 24.9/14.4 kV multi-grounded wye systems.</li> <li>3. Three-phase switch requires special mounting bracket.</li> </ol>
<u>Yaskawa</u> Types LFG-15E-K (15 kV), LFG-25E-K (25 kV), LFG-35E-K (35 kV) 3-phase SF6 capacitor switch, pole mounted type, 200 A (capacitive), 630 A (continuous)	<ol style="list-style-type: none"> <li>1. To obtain experience.</li> </ol>

cg - Switch, air, three-pole, group-operated  
NEMA standard switches for station and line structures

Manufacturer	Acceptable Mounting on Structures	Tilting Ins.		Vertical Break		Side Break		Center Break		Double Break	
		Type	kV	Type	kV	Type	kV	Type	kV	Type	kV
<u>ABB</u>	Horizontal Horizontal			TTR6 TTR8	345 15-230						
<u>G &amp; W Electric Co.</u>	Horizontal			MK-40	15-69	PMB-40A	15-69	LPC	69-230		
<u>Hubbell (Chance)</u>	Horizontal Phase over Phase Vertical			D6(L) D6(L) D6(L)	15-34.5 15-34.5 15-34.5						
<u>Johnson</u>	Horizontal			VIP	15-230	LS	15-69	M	15-230		
<u>Joslyn (Hi-Voltage)</u>	Horizontal Horizontal			RF-2(VL)	15-230	RB-1(VL) RB-1*	15-25 15-115				
<u>Kearney/Eaton</u>	Horizontal	AR 60-P	15-69								
<u>MEMCO</u>	Horizontal Horizontal	AgF AgC	15-69 15-69	EA	15-345	RI4-C	15-46	EE	69-230		
<u>MORPAC (Morgan)</u>	Horizontal Vertical Phase over Phase			VBV (VL) VBV (VL)	15-230 15-230			CBV CBV CBV	15-230 15-230 15-25		
<u>Royal Switchgear</u>	Horizontal  Phase over Phase Underhung Vertical			AVT	15-345	SBF	15-46	V CB  CB CB	15-230 34.5-230  34.5-230 34.5-230	DEB  DEV	34.5-345  69-345

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

\*These switches may be purchased with reduced voltage vacuum interrupters and may be applied for loop sectionalizing duty when peak recovery voltage does not exceed 25 kV

NOTE: Phase-over-phase mounted switches are not acceptable above 25 kV class unless equipped with full-load interrupters. Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms or poles must be supplied with insulated interphase and control rods.

cg - Switch, air, three-pole, group-operated  
NEMA standard switches for station and line structures

<u>Manufacturer</u>	Acceptable Mounting on Structures	Tilting Ins.		Vertical Break		Side Break		Center Break		Double Break	
		Type	kV	Type	kV	Type	kV	Type	kV	Type	kV
<u>S &amp; C***</u>	Horizontal			Alduti(L)	15-34.5	Alduti(L)	15-25			Alduti(L)	34.5-46
	Phase over Phase			Alduti(L)	15-25	Alduti(L)	15-25			Alduti(L)	34.5-46
	Vertical			Alduti(L)*	15-34.5	Alduti(L)	15-25			Alduti(L)*	34.5-46
<u>SEECO</u>	Phase over Phase			GOABS(VL) 15-69							
<u>Siemens-Allis</u>	Horizontal			AVB(VL)**	115-345			CB	115-230		
								CBL-2	115-230		
<u>Southern States</u>	Horizontal			EV	15-230						
<u>Turner</u>	Phase over Phase			TA(VL)	15-69	SSB-T	15-69	EC	115-230		
						(1D, 2D, 3D)(VL)					
							15-161				
<u>USCO</u>	Horizontal			AVR(VL)**	15-230	1D(VL)	15-161				
	Horizontal					TH1(VL)	15-161				
	Phase over Phase										
<u>USCO</u>	Horizontal			ASB	35-138	ASB	35-138	AGCH **	15-345		
	Horizontal							AGCH-V**	34.5-230		
	Phase over Phase					ASB-II	15-25	GCH	15-23		

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

\*These switches, except 34.5 kV Alduti vertical break, are available and accepted with the S & C type SMD substation fuse cutouts listed on page af-3.

\*\* Also available in bronze in some ratings.

\*\*\*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

NOTE: Phase-over-phase mounted switches are not acceptable above 25 kV class unless equipped with full-load interrupters. Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms or poles must be supplied with insulated interphase and control rods.

cg - Switch, air, three pole, group operated  
(Factory Preamsembled)  
(FOR USE ON STEEL SUBSTATION STRUCTURES)

<u>Manufacturer</u>	<u>Mounting</u>	<u>Vertical Type</u>	<u>kV</u>	<u>Side Break Type</u>	<u>kV</u>
<u>Hubbell (Chance)</u>	Vertical	-		D7(L) 15-27	
	Horizontal	-		D7(L) 15-27	
<u>S &amp; C*</u>	Phase-over-Phase	Alduti(L) 34.5(200 kV BIL)		Alduti(L) 34.5(200 kV BIL)	
	Vertical	Alduti (L) 34.5(200 kV BIL)			

(L) Means gas or solid material full-load interrupters are accepted and available.

\*Available with porcelain insulators. Available with "Cyposy" cycloaliphatic epoxy insulators through 34.5 kV on request.

cg - Switch, air, three-pole, group operated

(not Suitable for Substation Use)

<u>Manufacturer</u>	<u>Acceptable Mounting</u>	<u>Vertical Break</u>		<u>Side Break</u>		<u>Center Break</u>	
		Type	kV	Type	kV	Type	kV
<u>Hubbell (Chance)</u>	Horizontal			D6(L)	15-34.5		
	Phase over Phase			D6(L)	15-34.5		
	Vertical	D7(L)	15-34.5				
<u>Eaton (Kearney)</u>	Horizontal			M-FORCE(L)	15-35		
	Phase over Phase			M-FORCE(L)	15-35		
	Vertical			M-FORCE(L)	15-35		
<u>Royal Switchgear</u>	Horizontal					V	15-23
	Phase over Phase					V	15-23

(L) Means gas or solid material full-load interrupters are accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

NOTE: Phase-over-phase mounted switches are not acceptable above 25 kV class unless equipped with full-load interrupters. Switches of 15 kV and 25 kV classes with individual phases mounted on wood crossarms or poles must be supplied with insulated interphase and control rods.



cg - Switch, three-pole, group-operated  
(Factory Preassembled)

Manufacturer	Acceptable Mounting on Structures	Vertical Break Type	kV	Side Break Type	kV
<u>ABB</u>	Horizontal (A)			SLB-3(L)	15-25
<u>Siemens</u> <sup>#</sup>	Horizontal (A)			Vector(L)	15-27
	Phase over phase (A)			Vector(L)	15-27
	Vertical (A)			Vector(L)	15-27
<u>Eaton (Kearney)</u>	Horizontal (A)			M-FORCE	15-35
	Phase over phase (A)			M-FORCE	15-35
	Vertical (A)			M-FORCE	15-35
<u>Hubbell (Chance)</u>	Horizontal (A)			D7(L)	15-27
	Phase over phase (A)			D7(L)	15-27
	Vertical (A)			D7(L)	15-27
	Horizontal (B)			D7(L)	34.5
	Phase over phase (B)			D7(L)	34.5
	Vertical (B)			D7(L)	34.5
<u>Inertia Engineering</u>	Horizontal (A)			LBS(L)	15-35
	Vertical (A)			LBS(L)	15-35
	Phase over phase (A)			LBS(L)	15-35
<u>S&amp;C</u> <sup>*</sup>	Horizontal (A)			Alduti(L)	15-25
				Alduti(L)	34.5
				(200 kV BIL)	
	Phase over phase (A)			Alduti(L)	25
				Alduti(L)	34.5
				(200 kV BIL)	
	Vertical (A)			Alduti(L)	15-25
				Alduti(L)	34.5
				(200 kV BIL)	
	Phase over phase (B)	Alduti(L)	34.5	Alduti(L)	34.5
	Vertical (B)	Alduti(L)	34.5		

(L) Means gas or solid material full-load interrupters are accepted and available.

(A) Not suitable for substation use.

(B) For station and transmission use only. The steel crossarm base must be grounded with an adequate grounding connector. 200 kV BIL only.

NOTES:

Switches with factory-assembled crossarm type bases for distribution lines must have non-conducting crossarm type bases, non-conducting braces, and insulated interphase and control rods, except as otherwise noted.

\* Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5kV on request.

# Both operating shaft and hookstick versions of switch accepted. Applies to both polymer and porcelain insulators.

cg - Switch, air, three-pole, group operated

Manufacturer	Conditions
<u>Cleaveland/Price</u> Type V2-C (15-69 kV) Vertical break, horizontal or vertical mounting  Type RL-C (15-69 kV) Single side break, horizontal or vertical mounting	1. To obtain experience. 2. Insulated interphase and control rods required on wood distribution structures.
<u>G &amp; W Electric Company</u> Type MK-40A 15 kV through 345 kV(horizontal upright mounting)	1. To obtain experience. 2. Insulated interphase and control rods required on 15 kV and 23 kV models used on wood structures. 3. Steel interphase base required when mounted as in RUS Drawing TM-3.
Type LPV, 3-pole 72.5-272 kV, 1200 amp., 1600 amp., 2000 amp., center sidebreak for horizontal mounting.	To obtain experience.
<u>Hubbell (Chance)</u> Type AR Side-break, horizontal phase-over-phase, and vertical mounting, with non-conducting crossarm type base and insulated interphase and control rods, 15, 25 and 34.5 kV(grounded wye)	To obtain experience.

(L) Means full-load interrupter accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

cg - Switch, air, three-pole, group-operated

Manufacturer	Conditions
<u>PASCOR</u> VBP (15 - 230 kV) VBS (69 - 230 kV) Vertical break, vertical or horizontal mounting. Phase-over-Phase mounting(VBS, 69 - 115 kV only)	1. To obtain experience. 2. Insulated interphase and control rods required on wood distribution structures.
SB (15 - 69 kV) Side break, vertical or horizontal mounting.	1. To obtain experience. 2. Insulated interphase and control rods required on wood distribution structures.
CB (15 - 115 kV) Center break, vertical or horizontal mounting.	1. To obtain experience 2. Insulated interphase and control rods required on wood distribution structures.
CBSA (69 - 138 kV) Center Break Vee, vertical, horizontal, or phase-over-phase mounting. (Also accepted as a copper switch at 69 - 115 kV.)	To obtain experience.
<u>S &amp; C*</u> Line-rupter with SF <sub>6</sub> interrupter. Horizontal mounted 115-230 kV	To obtain experience.
Omni-Rupter #(L) Side-break, horizontal phase-over-phase, and vertical mounting, with non-conducting crossarm type base and insulated interphase and control rods, 15 kV and 25 kV #Both operating shaft and hookstick versions of switch accepted.	To obtain experience.

(L) Means full-load interrupter accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

\*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

cg - Switch, Air, Three-Pole, Group Operated

Manufacturer	Conditions
<u>SEECO</u> GOABS (VL) Vacuum interrupter type 115-169 kV	To obtain experience.
<u>Southern States</u> "Pole-Pak" 15-23 kV	To obtain experience.
Type ES; 15, 23 and 34.5 kV (horizontal upright models only)	<ol style="list-style-type: none"> <li>1. To obtain experience.</li> <li>2. For 15 kV and 23 kV distribution lines, insulated interphase and control rod spacers required. See RUS Drawings M3-15 and VM3-16.</li> <li>3. NEMA insulators and steel interphase base required for transmission line structure as in TM-3.</li> <li>4. Acceptable on steel substations 15 through 34.5 kV with NEMA insulators and uninsulated interphase rods.</li> </ol>
Type 57L sidebreak, 115-161 kV, 600 and 1200 amp., horizontal upright	To obtain experience.
Type CBL-T, 15-69 kV, 1200 amp (center break, horizontal upright mounting)	<ol style="list-style-type: none"> <li>1. To obtain experience.</li> <li>2. Insulated interphase and control rods required on 15 kV and 25 kV models used on wood structures.</li> </ol>
<u>Travis Switchgear</u> MA-32512, 25 kV, 150 kV BIL, vertical break	<ol style="list-style-type: none"> <li>1. To obtain experience.</li> <li>2. Insulated interphase and control rods required when used on wood structures.</li> </ol>

(L) Means full-load interrupter accepted and available.

(VL) Means vacuum full-load interrupters are accepted and available.

ci - Clevis, thimble

Rated Strength

Manufacturer	20,000 lbs.	40,000 lbs.	50,000 lbs.
Joslyn (Flagg)	PA271	PA272B	-

cj - Pole Ground Wire

Soft annealed iron, BB Grade, class C galvanizing  
(For pole protection only)

Size  
1.15 Ohms/1000 ft., max.

Manufacturer

Florida Wire and Cable	3-wire, 5/16 inch
Indiana Steel and Wire	3-wire, 5/16 inch
National Strand Products	3-wire, 5/16 inch
Southwire	3-wire, 5/16 inch

Copper, soft annealed solid  
ASTM Specification B3

Manufacturer  
(See page av-2)

Aluminum (for above ground use only)  
Hard-drawn

Manufacturer  
(See page av-1)

Aluminum Alloy (for above ground use only)

<u>Manufacturer</u>	<u>Type</u>
Alcan Cable	6201
American Electrical	6201
Southwire	6201

Copper-Clad Steel, Annealed 40 percent Conductivity

<u>Manufacturer</u>	<u>Sizes</u>
AFL Copperclad	No. 6, No. 4., No. 2
Copperweld Bimetallics, LLC*	No. 6 AWG No 4 AWG Stranded (7x0680") No. 4 AWG No. 2 AWG Stranded (7x0860") No. 2 AWG 7 No. 10 AWG 2/0 (19x0860" & 7x1379")

\* Theft deterrent versions, both poly-jacketed and camouflaged are acceptable.

cj - Pole Ground Wire, alternative conductor

<u>Manufacturer</u>	<u>Conditions</u>
<u>ConduGround</u> CG-7/16" CG-1" CG-1-1/2" CThor55Lb GAP55Lb GAP25Lb	To obtain experience.

ck - clamp, anchor rod bonding

For Standard and Drive Type Rods

Diam. of Rod	Type of Eye	5/8"	3/4"	1"
C & R Products	Single	CRBC-1	CRBC-1	CRBC-1
	Twin	CRBC-2	CRBC-2	CRBC-2
	Triple	-	CRBC-3	CRBC-3
Hubbell (Chance)	Single	G5060	G5060	G5060
	Twin	G5061	G5061	G5061
	Triple	-	G5063	G5063
Joslyn	Single	3230	3230	3230
	Twin	3231	3231	3231
	Triple	-	3233	3233
Kortick	Single	K3147	K3147	-
	Twin	-	K3148	K3148
	Triple	-	K3149	K3149
Line Hardware	Single	RBC-100	RBC-100	RBC-100
	Twin	RBC-200	RBC-200	RBC-200
	Triple		RBC-300	RBC-300
MacLean (Continental)	Single	UCG5060	UCG5060	-
	Twin	-	UCG5061	UCG5061
	Triple	-	UCG5063	UCG5063

For Power Installed Screw Anchors

C & R Products	Single	CRBC-4	CRBC-5	-
Hubbell (Chance)	Single	G5067	G5068	-
Joslyn	Single	J26714	J26715	-
Line Hardware	Single	RBC-400	RBC-500	-



cm - Insulator, Spool

Type:	<u>Secondary (Wet Process)</u>		<u>Wet Process</u>	<u>Service</u> <u>Dry Process</u>
Groove Diameter:	<u>1-3/4"</u>	<u>3"</u>	<u>1-3/8"</u>	<u>1-3/8"</u>
ANSI Class	53-2	53-4	53-1	NA
Eaton	DE4S3	DE5S3	DE2S2	DE2S1
Gamma Insulators Corp.	8442-70	8444-70	8441-70	-
Hughes	2102	-	-	-
ICB	ICB 532	ICB 534	ICB 531	-
Joslyn	-	J0101A	J150A	J100A
Kortick	K516	K522	K513	K514
MacLean (Continental)	U205	U31221	U208	U207
Porcelain Products (Knox)	5101	5119	5107	5207
M.D. Henry Company, Inc.	1082	-	-	-
Victor Insulators, Inc.	2012, VI 2612	2026, VI 2626	2011, VI2611	-

cm – Insulators, spool, composite/polymer

<u>Manufacturer</u>	<u>53-1</u>	<u>ANSI Class</u> <u>53-2</u>	<u>53-4</u>
Aluma-Form, Inc.		INS-53-2	
Hendrix Wire and Cable	-	HPI-53-2	-
Hubbell (Chance)	-	C909-1032P	-
Preformed Line Products	-	IP-53-2	-

cp - Deadend, Compression Type

<u>ACSR</u>			
<u>Conductor Size</u>	<u>AFL</u>	<u>Burndy</u>	
1/0	Order by Conductor Size and <u>Stranding</u>	Type Y-W	
2/0		"	
3/0		"	
4/0		"	
266.8 kcmil 18/1	2-piece alloy compression Type VES or HES "		
336.4 kcmil 18/1			
477 kcmil 18/1			
266.8 kcmil 26/7		Type Y-W	
336.4 kcmil 26/7		Type YTW	
477 kcmil 26/7		"	
556.5 kcmil 26/7		"	
795 kcmil 26/7		"	
954 kcmil 54/7		"	
<u>Conductor Size</u>	<u>Hubbell (Anderson)</u>	<u>Hubbell (Fargo)</u>	<u>Kearney/Eaton</u>
1/0	VCD-50R	SEDA-8129	104000
2/0	thru	SEDA-7729	thru
3/0	VCD-61R	SEDA-7829	104000-03
4/0	"	SEDA-7929	"
266.8 kcmil 18/1	VCD-80-R		
336.8 kcmil 18/1	VCD-80-R		
477 kcmil 18/1	VCD-812-R		
266.8 kcmil 26/7	VCD-831-1-RM	Uni-Grip	104000-05
336.4 kcmil 26/7	VCD-831-1-RM	one die	thru
477 kcmil 26/7	VCD-832-2-RM	system	104000-14
556.5 kcmil 26/7	VCD-833-3-RM	Order by	"
795 kcmil 26/7	VCD-835-4RM	conductor size	
954 kcmil 54/7	VCD-835-4RM	and stranding	

NOTE: These compression deadends are acceptable when installed using tools and dies in accordance with the deadend manufacturer's recommendations.

cp - Deadend, Compression Type

ACSR

Conductor Size	DMC Power
1/0	-
2/0	-
3/0	-
4/0	-
266.8 kcmil 18/1	Order by Conductor Size and Kit Pieces.
336.4 kcmil 18/1	
477 kcmil 18/1	
266.8 kcmil 26/7	One-piece Alloy Swage
336.4 kcmil 26/7	
477 kcmil 26/7	
556.5 kcmil 26/7	Full Tension Compression Type
795 kcmil 26/7	
954 kcmil 54/7	

NOTE: These compression deadends are acceptable when installed using tools and dies in accordance with the deadend manufacturer's recommendations.

cp - Deadend, Compression Type

ACSR  
Adjustable

Hubbell (Fargo)      Order by conductor size and  
stranding

Aluminum Alloy  
(6201 and 5005)

Conductor Size:      4 thru 4/0

Hubbell (Anderson)      Type VCD, Order by conductor size

	<u>Copper</u>		
<u>Conductor Size:</u>	<u>2 x 3</u>	<u>4</u>	<u>6</u>
National Tel. Supply	71-258/3X	71-204-P	71-162-J

	<u>Copperweld-Copper</u>	
<u>Conductor Size:</u>	<u>6A</u>	<u>8A</u>
National Tel. Supply	71-6A-P	71-8A-P

NOTE: These deadends are acceptable when installed with tools and dies in accordance with the deadend manufacturer's recommendations.

cp - Deadend, compression type

Manufacturer	Conditions
<u>Burndy</u> AWAC 4-4/3 YTW7M10T AWAC 2-4/3 YTW7M9T AWAC 1/0-4/3 YTW7M7T	To obtain experience.

NOTE: These deadends are acceptable when installed with tools and dies in accordance with the deadend manufacturer's recommendations.

cp –Dead-end, compression

For use with High Temperature Conductors

Manufacturer	Conditions
<u>AFL</u> Dead-end fitting  To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS
<u>Burndy/Hubbell</u> Dead-end Assembly  To be used with CTC Global High Temperature Conductors ACCC (Aluminum conductor Composite Core)	Same as above.
<u>Preformed Line Products (PLP)</u> Thermolign Suspension  To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	Same as above.

NOTE: These compressions are acceptable when installed using tools and dies in accordance with the conductor's manufacturer's recommendations.

cq - Deadend, Secondary  
(For use on secondary deadends only)

Copper  
Offset Compression

Conductor Size:	4	6
National Telephone Supply	91-204-P	91-162-J

Copperweld-Copper  
Offset Compression

Conductor Size:	6A	8A
National Telephone Supply	91-6A-P	91-8A-P

Copperweld-Copper  
Automatic Deadend

Conductor Size:	6A	8A
Hubbell (Fargo)	GD-113	GD-112
MacLean (Reliable)	47FD	-



cr - Bracket, Angle Suspension

Applicable Specifications: "RUS Specification for Angle Suspension Brackets," DT-4

<u>Manufacturer.</u>	<u>Distribution 5/8" Diam.</u>	<u>Transmission 3/4" Diam.</u>
Hubbell (Chance)	-	5728
Joslyn	-	J7936
Kortick	K6231	K6230
MacLean (Continental)	U545	U546

cs-1  
July 2009

cs - Bracket, Pole Top Pin

For Transmission and 24.9/14.4 kV Distribution

Applicable Specifications: "RUS Specifications for Pole Top Brackets for Channel Type Pins," D-14

Hubbell (Chance)	2157
Kortick	K8130
MacLean (Continental)	U36690

ct - Plate, Double Arming

Transmission

Manufacturer	4" x 1/2" x 24"	4" x 1/4" x 17"
Hubbell (Chance)	5844	5819
Joslyn	J1600	-
Kortick	K1454	K1465
Line Hardware	-	DAP-17
MacLean (Continental)	U4117	-

cu – 26 inch Brace, crossarm (side-mounted)

<u>Manufacturer</u>	Douglas Fir or Southern Yellow Pine	Apitong	Fiber Reinforced Plastic
Aluma-Form2	-	AF626	-
Barfield Mfg.	BAB-626	-	-
Brooks	58128	-	-
Dulmison	-	-	CAB-28
Hatheway Patterson	7026	-	
Hughes Brothers	2023	-	533
Joslyn	J5526	-	
MacLean (Continental)	-	-	CRB-28
Geotek (PUPI)	-	-	B3818SM

Note: Braces listed above have 26-inch hole spacing. They are to be used in place of the flat steel braces previously listed on page h.

cu – 60 inch Brace, crossarm (underarm)

	Span, inches:	60	60
	Drop, inches:	18	30
Manufacturer			
Aluma-Form	6018		6030
Barfield Mfg.	BAR-6018		BAR-6030
Brooks	446-60-18		446-60-30
Cox Industries	C-6018		C-6030
Dis-Tran	DT-60R		-
Hatheway Patterson	320-R		325-R
Hughes Brothers	2045-CC		2045-D
Joslyn	J4760R		J4730RW
Pennington	15018		15030
Geotek (PUPI)*	B6018BM		B6030BM
Utilities Structures Eng. Inc.	CU-60-18		CU-60-30

\*Denotes Fiber Reinforced Plastic, all others are wood

cu – Bracket, Crossarm, center mount

Manufacturer

Catalog #

Brooks Manufacturing Co.

REA Type 01 FSNP-BBA  
REA Type 02 FSNP-BBA  
REA Type 03 FSNP-BBA  
REA Type 04 FSNP-BBA  
REA Type 05 FSNP-BBA  
REA Type 14 FSNP-BBA  
REA Type 22 FSNP-BBA

cx - Splice, oval tube

Copper

Conductor Size:	0 x 7	2 x 3	4	6
National Tel. Supply	464	463	459	457

Copperweld-Copper

Conductor Size:	6A	8A
National Tel. Supply	460	459

cy - Splice, Compression

ACSR

Conductor Size	AFL	Blackburn	Burndy
4 6/1	2-piece		"Unisplice"
4 7/1	Order	Type RC	(1-piece)
2 6/1	by	1-piece	or Y-S
2 7/1	Conductor	Order	(2-piece)
1/0	Size	by	Order by
2/0	and	Conductor	Conductor
3/0	Stranding	Size	Size and
4/0	"	and	Stranding
		Stranding	
266.8 kcmil 18/1			
336.4 kcmil 18/1			
477 kcmil 18/1			
266.8 kcmil 26/7	2-piece		2-piece
336.4 kcmil 26/7	Compression		Type YTS
477 kcmil 26/7	Alloy Type		"
556.6 kcmil 26/7	CJ		"
795 kcmil 26/7			"
954 kcmil 54/7			"

Conductor Size	Hubbell(Anderson)	Hubbell (Fargo)	Kearney/Eaton	
	VC-36R		2 pc	1 pc
4 6/1	VC-36R	-	-	OH4-61-71AS
4 7/1	VC-36R	-	-	OH4-61-71AS
2 6/1	VC-36R	-	-	OH2-61-71AS
2 7/1	VC-50R	-	-	OH2-61-71AS
1/0	VC-50R	TJA-8129	OH1/0-61A	OH1/0-61AS
2/0	VC-61R	TJA-7729	OHR2/0-61A	-
3/0	VC-61R	TJA-7829	OHR3/0-61A	-
4/0	-	TJA-7929	HR4/0-61A	-
	VC-80-R			
266.8 kcmil 18/1	VC-80-R	-	-	-
336.4 kcmil 18/1	VC-90-R	-	-	-
477 kcmil 18/1	-	-	-	-
	VC-831-1-RM			
266.8 kcmil 26/7	VC-831-1-RM	Uni-grip	HR-266-267A	-
336.4 kcmil 26/7	VC-832-2-RM	one die	HR336-267A	-
477 kcmil 26/7	VC-833-3-RM	system	HR-477-267A	-
556.6 kcmil 26/7	VC-835-4RM	Order by	HR-556-267A	-
795 kcmil 26.7	VC-835-4RM	conductor size	-	-
954 kcmil 54/7	-	and stranding	-	-

NOTE: These splices are acceptable when installed with tools and dies in accordance with the splice manufacturer's recommendations.



cy - Splice, Compression

ACSR

Conductor Size	Nat. Tel. Supply	Homac	ESP
4 6/1	"Nicopress"	"Tension	FTR-4
4 7/1	(1-pc. or 2-pc.)	splicer"	FTR-4
2 6/1	Order by Conductor	(1-piece or	FTR-2
2 7/1	Size and	2-piece	FTR-2.5
1/0	Stranding	Order by	FTR-1/0
2/0	2-pc.	Conductor	FTR-2/0.5
3/0	"	Size and	FTR-3/0
4/0	"	Stranding	FTR-4/0
266.8 kcmil 26/7	"	2-pc.	-
336.4 kcmil 26/7	"	"	-
477 kcmil 26/7	"	"	-
556.5 kcmil 26/7	"	"	-
795 kcmil 26/7	-	-	-
954 kcmil 54/7	-	-	-

NOTE: These splices are acceptable when installed with tools and dies in accordance with the splice manufacturer's recommendations.

Splice, Compression

Copper and Copperweld-Copper

<u>Conductor Size</u>	<u>Burndy</u>	<u>Homac</u>	<u>Hubbell (Anderson)</u>	<u>Kearney/Eaton</u>	<u>National Tel. Supply</u>
6 cu	YDS6W	J2C3	VCC-28	OH6C	1-162/J
4 cu	YDS4W	L2C5	VCC-28	OH4C	1-204/P
2 x 3 cu	YDS2C-3	S2C7	-	OH2-3CX	1-258/3X
0 x 7 cu	YDS25	U2C9	-	OH1-7C	1-325/7F6
8A CWC	YDS8KT	L2E1	VCC-28	OHR8ACW	1-8A-P
6A CWC	YDS6KT	L2E3	VCC-28	OHR6ACW	1-6A-P
4A CWC	YDS4KT	Q2E5	VCC-37	OHR4ACW	1-4A-X
2A CWC	-	U2E7	VCC-43	-	-

NOTE: These splices are acceptable when installed with tools and dies in accordance with the splice manufacturer's recommendations.

cy - Splice, compression  
(one-piece)

(For 6201 and 5005 Aluminum Alloy Conductors)

Conductor Size	<b>Burndy</b>	<b>Blackburn</b>	<b>Homac</b>	<b>Hubbell (Anderson)</b>
#4	"Unisplice"	Type RC	"Tension Splicer"	Type VC-R
thru	Order by Conductor Size and Stranding	Order by Conductor Size and Stranding	Order by Conductor Size and Stranding	Order by Conductor Size and Stranding
4/0	<b>ESP</b>			
	Type FTR Order by Conductor Size and Stranding			
336.4	<b>DMC Power</b>			
thru	Full Tension Compression One- piece (swage) High Strength Type 6000 Series.			
2500 Kcmil	Order by Conductor Size & Kit pieces.			

**NOTE:** These splices are acceptable when installed with tools and dies in accordance with the splice manufacturer's recommendations.

cy - Splice, compression

1-piece splice for ACSR

Manufacturer	Conditions
<u>*AFL</u> "Jiffy Joint"	To obtain experience.

1-piece splice for AWAC

Burndy

AWAC 4-4/3 YDS7M10T	To obtain experience.
AWAC 2-4/3 YDS7M9T	
AWAC 1/0-4/3 YDS7M7T	

\*Satisfactory for use with 6201 and 5005 all aluminum alloy conductor through 4/0 and 19 strand conductors of sizes 266.8 kcmil and 477 kcmil.

NOTE: These splices are acceptable when installed using tools and dies in accordance with the splice manufacturer's recommendations.

cy -Splice, compression, high temperature

For use with High Temperature Conductors

Manufacturer	Conditions
<u>AFL</u> Fujikura Limited (AFL) Splice, Compression  To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS
<u>Burndy/Hubbell</u> Splice, compression  To be used with CTC Global High Temperature Conductor, ACCC (Aluminum Conductor Composite Core)	Same as above.
<u>Preformed Line Products (PLP)</u> Thermolign Full Tension Splice  To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	Same as above.

NOTE: These splices are acceptable when installed using tools and dies in accordance with the conductor's manufacturer's recommendations.

cz - Splice for Steel Strand (Overhead Ground Wire)

Compression

Single Sleeve Only

	<u>High Strength Steel</u>		<u>Extra High Strength</u>			<u>Aluminum Clad Steel</u>		
	<u>3/8"</u>	<u>7/16"</u>	<u>5/16"</u>	<u>3/8"</u>	<u>7/16"</u>	<u>7 No. 9 AWG</u>	<u>7 No. 8 AWG</u>	<u>7 No. 7 AWG</u>
AFL				4914.386	4916.453			
Burndy	YTS375E	YTS438E				YDS7M9T	YDS7M8T	YDS7M7T
Hubbell (Fargo)	811425	811630	811222	811425	811630	811425	811427	811630
Kearney	HR-3/8-3-7S							
National Tel. Supply	5-7/12OG92	5-7/145J22						
<u>Steel and Aluminum Sleeves</u>								
Homac	28414 (Two piece)							
<u>Automatic</u>								
MacLean (Reliable)	5002	5043	5041	5042	5043	5042	5042	5043
<u>Bolted Type</u>								
Electroline	GD-537							
<u>Formed Type</u>								
Helical Line Products	HS-310-3/8"	HS-311-7/16"						
Hubbell (Chance)	10SS 3/8C	16SS 7/16C	6SS 5/16C	10SS 3/8C	16SS 7/16C			

da-1  
July 2009

da - Bracket, insulated

	Bracket without Insulator	Bracket with 1-3/4" Spool Insulator	Bracket with 3" Spool Insulator
Hubbell (Chance)	0327	0327-C909-1032	0327-C909-1304
Hughes Brothers	1077LI	1077SI	1077I
Joslyn	J1300	-	-
Kortick	K9278	K9081	K9082

dh - Ground, pole

(For system grounds, see ground rods on page ai)

Manufacturer

Catalog Number

Galvanized Steel Plate With Insulated Copper Lead

(For connecting to a copper or aluminum ground wire above ground.)

Line Hardware

PGPS-56CL8

Galvanized Steel Plate with Connector

(For connecting to a galvanized iron ground wire)

Line Hardware

PGPS-56C

Copper Plate

Blackburn	GP-100
Drabco	D 101
Eritech	EGP-100
Galvan Industries, Inc.	GP-100
Homac	5575
Joslyn	J9196
Line Hardware	PGPC-56
Utilco	UGP-72*

\* Plate area exposed to the soil is at least 0.046 m<sup>2</sup> or 0.5 ft<sup>2</sup>;  
Plate thickness is at least 1.5 mm or 0.06 in.



dh - Ground, pole  
Alternative Materials

(For system grounds, see ground rods on page ai)

<u>Manufacturer</u>	<u>Catalog Number</u>	<u>Description</u>
SAE	CD-2W-12	14" ConduDisc™ with 12 ft. of #2 Copperweld
	CD-2WC-12	14" ConduDisc™ with 12 ft. of #2 Copperweld Camo
	CD-4C-12	14" ConduDisc™ with 12 ft. of #4 Copper
	CD-2C-12	14" ConduDisc™ with 12 ft. of #2 Copper
	CD-1/0C-12	14" ConduDisc™ with 12 ft. of 1/0 Copper
	CD-2/0C-12	14" ConduDisc™ with 12 ft. of 2/0 Copper
	CC25	Conducrete® 25 lb.
	CC55	Conducrete® 55 lb.
	CF7000	ConduFlow 5ga1.

dl-1  
July 2009

dl - Pipe Spacer

3/4" diameter x 1-1/2" length

<u>Manufacturer</u>	<u>Catalog Number</u>
Hubbell (Chance)	2237
Joslyn	J2031
MacLean (Continental)	U36695

dm - Bracket, transformer

(For cluster mounting of two or three transformers on pole)

Manufacturer	Transformer Size, kVA	Band Type	Through Bolt Type
Aluma-Form	3-50 75-100	6M3-6 15M3-6	3MW-24-M 11MW-24
Barfield Manufacturing Co.	3-50 75-100	BMAC-366 BMAC-3156	- -
Dixie	3-25 37-1/2-50 75-100	- - -	DW-50 DW-50 DW-167
Hubbell (Chance)	3-50 75-100	C6M3-6 C15M3-6	C3MW24M C11MW24L
Hughes	3-25 37-1/2-50 75-100	- - -	3021 3020 3020 with adapter plates and back plate
Joslyn	3-25 37-1/2-50 75-100	- - -	J6865 J6864 J6866
MacLean Power Systems	3-50 75-100	- M15M3-6	M3MW-24-M M11MW-24
Turner	3-25 37-1/2-50 75-100	- - -	305-25 305-100 305-100

For mounting of two transformers

Aluma-Form	3-100 3-50	- -	DM-4M2 DM-2M2
Hubbell (Chance)	3-100	-	C212-0001
Hughes	3-50	-	3022
MacLean Power Systems	3-50	-	MDM-2M2
Turner	3-50	-	205-25

dp - Clamp, ground wire

Transmission

For grounding steel towers and substation structures

Bolt Included

(For use with copper ground wires)

<u>Manufacturer</u>	<u>Catalog Number</u>
TE Connectivity - Energy	81416-3
Penn-Union	GH-30-C-A1
Royal Switchgear	12202-T (Type LCS)
Hubbell Power Systems	GC143AG2

For use in: Pole Grounding Assembly TM-9  
Capacitor Assemblies M9-11, M9-12 and M9-13

<u>Manufacturer</u>	<u>For 5/8" Bolt</u>	<u>For 3/4" Bolt</u>
Joslyn	J1163	J1164
MacLean (Continental)	SBL-33	-

dp – Clamp, ground wire

Transmission

For grounding steel towers and substation structures

Bolt Included

(For use with copper ground wires)

<u>Manufacturer</u>	<u>Catalog Number</u>	<u>Conditions</u>
<u>DMC Power</u>	GC910B-***T (single hole pad for copper wire)	To obtain experience.

For use in: Pole Grounding Assembly TM-6, TM-7, TG-15, TG-17, TG-25, TG-27, TG-28, TG-29, TG-35  
Capacitor Assemblies Y3.1, Y3.2, Y3.3, Y3.4

dq-1  
July 2009

dq - Eye Screw, Elliptical

For use in deadending triplex type service cable, Drawing K2.3.

Manufacturer	Catalog Number
Joslyn	J8930

dr-1  
June 2013

dr – Clevis, conduit, insulated

For use in deadending triplex service cable, Drawing K3.2.

Applicable Specifications: "RUS Specifications for Insulated Conduit Clevises and Conduit Wire-holders for Pipe Mast Deadends," D-16

<u>Manufacturer</u>	<u>Catalog No.</u>
Joslyn	J0311*
Hubbell Power Systems, Inc.	DW8M1

\*Insulator not included. See page cm for spool insulator.

ds-1  
February 2015

ds - Wireholder, conduit

For use in deadending open wire services on pipe masts, Drawing K3.1.

Applicable Specifications: "RUS Specifications for Insulated Conduit Clevises and Conduit Wireholders," D-16

Manufacturer

Catalog Number

Hubbell (Chance)

C207-0075, C2070144



Conditional List  
ds(1)  
July 2009

ds - Wireholder, conduit

<u>Manufacturer</u>	<u>Conditions</u>
<u>Joslyn</u> J0588Z (nylon alloy)	To obtain experience.

dt - Deadend, service

For deadending triplex type service cable, Drawing K2.2.

Manufacturer	ACSR Size	Catalog Number	
		Wedge Type	Formed Type
Blackburn	4	W62-1	-
Dulmison	4	-	SG0570
	2	-	SG0735
	1/0	-	SG0915
	2/0	-	SG1020
Helical Line Products	4	-	HSG-514
	2	-	HSG-518
	1/0	-	HSG-522
MacLean (Reliable)	4	7195	-
	2	7187	-
	1/0	7287	-
Penn-Union	4	WDC-2S	-
Preformed Line Products	4	-	SG-4502
	2	-	SG-4504
	1/0	-	SG-4506
	2/0	-	SG-4507
	3/0	-	SG-4508
	4/0	-	SG4509

du - Link, Extension

DISTRIBUTION

<u>Manufacturer</u>	<u>Catalog Number</u>
Joslyn (Flagg)	PA319
Hubbell (Chance)	C207-0112
MacLean (Bethea)	LCE-14
MacLean (Continental)	CEL-14

TRANSMISSION

(25,000 lbs. min. strength)

Joslyn	J26082
MacLean (Bethea)	ASM 7209-I-BC

Guy Extension Link  
(For "H" Structure)

<u>Manufacturer</u>	<u>One Guy Attachment</u>	<u>Two Guy Attachment</u>
Joslyn	J22421	J26025

NOTE: The distribution extension links may be substituted for anchor shackle (Item bo), eye bolt (Item o) and eye nut (Item aa) for both small and large conductor drawings shown in RUS Form 803 and RUS Bulletin 50-3 at the option of the owner.

du - Connecting Links for Pole Bands

Conditions - To obtain experience.in conjunction with pole bands [Item fv(1)]

For Use With Medium Duty Pole Bands

<u>Manufacturer</u>	<u>Link to Insulators</u>	<u>Size</u>	<u>Minimum Strength Rating</u>
Hughes Bros.	3176	3/8"x3"x9-1/2"	25,000 lbs.
Joslyn	J26034	3/8"x3"x9-1/2"	25,000 lbs.

Link to Guy

Hughes Bros.	3154	3/8"x2"x9-1/2"	36,000 lbs.
Joslyn	J26035	3/8"x3"x9-1/2"	36,000 lbs.

For Use With Heavy Duty Pole bands

<u>Manufacturer</u>	<u>Link to Insulators</u>	<u>Size</u>	<u>Minimum Strength Rating</u>
Hughes Bros.	3157	3/8"x3"x12"	36,000 lbs.
Joslyn	J26035 - 2	3/8"x3"x9-1/2"	36,000 lbs.

Link to Guy

Hughes Bros.	3157	3/8"x3"x12"	51,000 lbs.
Joslyn	J26037	1/2"x3"x12"	51,000 lbs.

dy - Bolt, eye, double arming

Applicable Specification: ANSI C135.4, "Standards for Galvanized Ferrous Eye Bolts and Nuts for Overhead Line Construction."

Applicable Sizes	5/8 inch, 14 through 26 inch length
	3/4 inch, 14 through 26 inch length

The following manufacturers have shown compliance with the applicable specifications:

Allied Bolt, Inc.  
Hubbell (Chance)  
Joslyn Manufacturing Company  
Kortick Manufacturing Company  
MacLean (Continental)

dz-1  
February 2011

dz - Clip, Guy Wire

Manufacturer	5/16"	3/8"	7/16"	1/2"
Hubbell (Chance)	6453	6454	6455	6456
MacLean (Continental)	U4953	U4954	U4955	U4956

ea - Insulator and Stud, line post, ceramic  
(Non-ANSI Class)

DISTRIBUTION (RUS Minimum Requirements)

System voltage, kV:	12.5/7.2	12.5/7.2	24.9/14.4
Leakage, inches:	7-1/2	10	15
Cantilever strength (pounds):	1875	1875	1875
Flashover, dry, kV:	65	70	95
Flashover, wet, kV:	40	50	65

Gamma Insulators Corp.

7" Stud	-	-	-
1-3/4" Stud	4315PX-70	4320PX-70	4327PX-70

Grupo IUSA

No Stud	P-2025	P-2025	-
---------	--------	--------	---

Lapp

7" Stud	4415P	4420P	4427P
1-3/4" Stud	4315P	4320P	4327P

Newell Porcelain

7" Stud	-	43570-7040	47101-7040
1-3/4" Stud	-	43570-7010	47101-7010

Porcelain Products (Knox)

7" Stud	5115-6510	5120-6510	5127-6510
1-3/4" Stud	5115-6500	5120-6500	5127-6500

ea - Insulator and Stud, line post, ceramic  
(ANSI Class)

DISTRIBUTION or TRANSMISSION

System voltage, kV:	12.5/7.2	12.5/7.2	24.9/14.4
Leakage, inches:	7-1/2	10	15
Cantilever strength (pounds):	1875	1875	1875
Flashover, dry, kV:	65	70	95
Flashover, wet, kV:	40	50	65

ANSI Class:	57-2	57-3	57-4
System voltage, kV:	22	34.5	46

Gamma Insulators Corp.

7" Stud	-	-	-
1-3/4" Stud	9335X-70	9345X-70	-

ICB

7" Stud	-	-	-
1-3/4" Stud	ICB 57-2	ICB 57-3	-

Lapp

7" Stud	9435	9445	9455
1-3/4" Stud	9335	9345	9355

Newell-PSN

7" Stud	37620-7040	41640-7040	41650-7040
1-3/4" Stud	37620-7010	41640-7010	41650-7010

Porcelain Products (Knox)

7" Stud	5135-6512	5145-6512	-
1-3/4" Stud	5135-6502	5145-6502	-



ea-2  
September 30, 2020

ea - Insulator, line post, ceramic  
(ANSI Class)

ANSI Class:	<u>57-1</u>	<u>57-2</u>	<u>57-3</u>	<u>57-4</u>
Eprecsa USA, LLC	13PD	22PD	33PD	-

ea - Insulators, line post, ceramic, horizontal  
Transmission

Manufacturer	34.5 kV	69 kV	115 kV
Lapp	F-4745	F-4788	F-70147
Locke	-	LS025I3	LS050I3
Newell-PSN	43740-7700	43790-7700 47043-7700	-
Victor Insulators, Inc.	62356	62359	-

Conditional List  
ea(1)  
September 30, 2020

ea - Insulator, line post, ceramic  
(non-ANSI Class)

<u>Manufacturer</u>	<u>Conditions</u>
<u>Victor Insulators, Inc.</u> 2120 (12.5/7.2 kV) 2127 (24.9/14.4 kV) 62055 (22 kV) 62056 (34.5 kV)	To obtain experience.

ea - Insulators, line post, composite, horizontal  
Transmission

Polymer for Wood and Fiberglass Transmission Poles (clamp end fittings and rigid curved base or bendable curved base for use for round poles)				
<b>Voltage:</b>	34.5 kV	46 kV	69 kV	
<b>ANSI Class:</b>	51-34	51-35	51-36	
<b>Rated SCL (lbs.):</b>	2400	2400	2400	
<b>Rod diameter (inches):</b>				
<b><u>Manufacturer</u></b>				<b><u>Conditions</u></b>
Hubbell	80S0460100	-	80S0690100	To obtain experience.
K-Line Insulators	KL46SHG12	KL69SHPG12	KL69SHP1G	

Polymer for Wood and Fiberglass Transmission Poles (clamp end fittings and rigid curved base or bendable curved base for use for round poles)				
<b>Voltage:</b>	115 kV	138 kV	138 kV	
<b>ANSI Class:</b>	250-54	250-60	250-66	
<b>Rated SCL (lbs.):</b>	2650	2300	2000	
<b>Rod diameter (inches):</b>	2-1/2	2-1/2	2-1/2	
<b><u>Manufacturer</u></b>				<b><u>Conditions</u></b>
				To obtain experience.

Notes:

1. Flat base for use with flat surface poles
2. Universal base for flat as well as curved poles
3. Two hole blade end fitting available.

ea - Insulators, line post, composite, horizontal  
Transmission

Polymer for Steel and Concrete Transmission Poles (with flat base or curved base for centrifugally spun concrete poles)						
<b>Voltage:</b>	34.5 kV and 46 kV	69 kV	115 kV	138 kV	138 kV	
<b>ANSI Class:</b>	51-36	250-41	250-60	250-66	250-75	
<b>Rated SCL (lbs.):</b>	2400	3300	2650	2300	2000	
<b>Rod diameter (inches):</b>		2-1/2	2-1/2	2-1/2	2-1/2	
<b>Manufacturer</b>						<b>Conditions</b>
						To obtain experience.

Polymer for Steel and Concrete Transmission Poles (with flat base or curved base for centrifugally spun concrete poles)				
<b>Voltage:</b>	115 kV	138 kV	138 kV	
<b>ANSI Class:</b>	250-60	250-66	250-75	
<b>Rated SCL (lbs.):</b>	4500	3900	3500	
<b>Rod diameter (inches):</b>	3.0	3.0	3.0	
<b>Manufacturer</b>				<b>Conditions</b>

\* Notes:

1. Flat base for use with flat surface poles
2. Universal base for flat as well as curved poles
3. Two hole blade end fitting available.

ea - Insulator, line post, composite

Manufacturer	ANSI Class	Conditions
<u>Advanced Rubber Products</u>		
ARP-LPCN-15SK	51-1C	To obtain experience.
ARP-LPFN-15SK	51-1F	
ARP-LPFN-25SK	51-2F	
ARP-LPFN-35SK	51-3F	
ARP-LPFN-46SK	51-4F	
<u>Hendrix Molded Products</u>		
HPI-LP-9C	51-1C	To obtain experience.
HPI-LP-9F	51-1F	
HPI-LP-11C	51-2C	
HPI-LP-11F	51-2F	
HPI-LP-14FS/FA	51-4F	
HPI-LP-16F	51-4F	
<u>Hubbell Power Systems</u>		
80S0150F09 (15kV, without Stud)		To obtain experience.
80S0250F09 (25kV, without Stud)		
80S0280F09 (35kV, without Stud)		
<u>K-Line Insulators</u>		
KL 15STFL (12.5/7.2 kV, with 7" Stud)		To obtain experience.
KL 15STFS (12.5/7.2 kV, with 1-3/4" Stud)		
KL 28STFL (24.9/14.4 kV, with 7" Stud)		
KL 28STFS (24.9/14.4 kV, with 1-3/4 Stud)		
KL 35STFL (with 7" Stud)	51-3F	
KL 35STFS (with 1-3/4" Stud)	51-3F	
KL 46STFL (with 7" Stud)	51-4F	
KL 46STFS (with 1-3/4" Stud)	51-4F	
KL 46SHG (34.5 kV)		
KL 28SKG109 (24.9/14.4kV)	51-32	
<u>EMC Pacific PTY LTD</u>		
LPI36-1100 PHCEP (15kV/ 25 kV/ 35kV, with 7" or 1-3/4" Stud)		To obtain experience.

ea - Insulator, line post, composite

Manufacturer	ANSI Class	Conditions
<u>GAMMA - Corona</u>		
PL015	51-1F	To obtain experience.
PL028	51-2F	
PL035	51-3F	
PL045	51-4F	
<u>Hendrix</u>		
HPI-CLP-15	51-12 & 22	To obtain experience.
HPI-CLP-17	51-13 & 23	
HPI-CLP-20	51-14 & 24	
<u>MacLean Power Systems</u>		
H0 Series	varies	To obtain experience.
H7 Series	varies	
<u>Preformed Line Products</u>		
IP-51-1C	51-1C	To obtain experience.
IP-51-1 F	51-1F	
IP-51-2C	51-2C	
IP-51-2F	51-2F	
IP-51-4F	51-4F	

eb - Bracket, Pole Top  
For Post type Insulators

DISTRIBUTION

Hubbell (Anderson) (14.4 or 7.2 kV)	84324-2000
Hubbell (Chance) (14.4 or 7.2 kV)	1B4
Joslyn (Flagg) (14.4 or 7.2 kV)	P526
Lapp (Line Ware) (14.4 or 7.2 kV)	304043
Line Hardware (14.4 or 7.2 kV)	PTIB-375A
MacLean (Continental) (14.4 or 7.2 kV)	PTB-55-8
M.D. Henry Company, Inc. (14.4 or 7.2 kV)	PT-8R

TRANSMISSION

Hubbell (Chance)	1B4
Joslyn (Flagg)	P532
Lapp (Line Ware)	304044
MacLean (Continental)	PTB-66H



ec-1  
July 2009

ec - Bracket, Offset Neutral

Hubbell (Chance)  
Joslyn

C206-0004  
J2352

ed - Support, overhead ground wire

Applicable Specifications: "RUS Specifications for Overhead Ground Wire Support Brackets," T-2

<u>Pole top diameter, inches</u>	<u>6-8</u>	<u>8-10</u>	<u>10-12</u>
Hubbell (Chance)	-	5432	5432
Hughes Brothers	-	2859-12	2859-14
Joslyn	-	J6394	J6395
Kortick	K3580	K3581	K3582
MacLean (Continental)	UC1238	UC1239	UC1240

ef - Bolt, clevis

Applicable Specifications: "RUS Specifications for Clevis Bolts," DT-7

	<u>Dia. (Inches)</u>	<u>8"</u>	<u>10"</u>	<u>12"</u>	<u>14"</u>
Hubbell (Chance)	5/8	15808	15810	15812	15814
	3/4	15828	15830	15832	15834
Joslyn	5/8	J7808	J7810	J7812	J7814

eg - Plate, crossarm reinforcing

TRANSMISSION

For 5-5/8" x 7-3/8" crossarm

Manufacturer	Catalog Number
Hubbell (Chance)	4047
Hughes Brothers	1113.88
MacLean (Continental)	U3838
Brooks Manufacturing Co.	REA Type 01 NP REA Type 02 NP REA Type 03 NP REA Type 04 NP REA Type 05 NP REA Type 05M NP REA Type 14 NP REA Type 22 NP
DIS-TRAN Wood Products, LLC	REA Type 01EP REA Type 02EP REA Type 03EP REA Type 04EP REA Type 05EP REA Type 05MEP REA Type 12EP REA Type 14EP REA Type 16EP REA Type 21EP REA Type 22EP REA Type 31EP REA Type 32EP REA Type 41EP REA Type 42EP

eh - Hook, ball

Manufacturer	Catalog Number
Joslyn (Flagg)	13400
Hubbell (Anderson)	HB-30
Lapp	7055
Lindsey	3310
Line Hardware	BH-30
MacLean (Bethea)	BH-5

ei - Clamps, suspension with socket eye  
ACSR with Straight or Formed Armor Rods

		AWG			<u>kcmil</u>					
		1/0 & 2/0	3/0	4/0	266.8	336.4	477	556.5	795	954
<u>Iron or Steel Clamps</u>										
Hubbell (Anderson)	MS-82-S	--		MS-104-S	MS-104-S	--	--	--	--	--
Hubbell (Chance)	FGW4S	--	--		--	--	--	--	--	--
Lapp	305743S	--	--		--	--	--	--	--	--
MacLean (Bethea)	FS-83-S	--	--		--	--	--	--	--	--

ACSR with Straight or Formed Armor Rods

	AWG		kcmil					
	1/0 & 2/0	3/0 & 4/0	266.8	336.4	477	556.5	795	954
	<u>Aluminum Alloy Clamp</u>							
C & R	CRSC-1S	CRSC-2S	CRSC-3S	CRSC-3S	--	--	--	--
Dulmison	--	HSU	HSU	HSU	HSU	HSU	HSU	HSU
Hubbell (Anderson)	HAS-85-S	HAS-104-S	HAS-104-S	HAS-118-S	HAS-139-S	HAS-147-S	HAS-182-S	HAS-182-S
Lapp	306029S	306030S	306030S	306031S	306032S	--	--	--
*Preformed	--	AGS	AGS	AGS	AGS	AGS	AGS	AGS
MacLean (Bethea)	LS-1-S	LS-2-S	LS-2-S	LS-3-S	LS-4-S	LS-6-S	LS-7-S	LS-8-S

\*Clevis type available.

ei - Clamps, suspension with socket eye - cushioned

Condition: To obtain experience

ACSR with Straight or Formed Armor Rods

	kcmil					
	266.8	336.4	477	556.5	795	954
*Preformed	CGS-1100	CGS-1102	CGS-1105	CGS-1106	CGS-1110	CGS-1112

\*Order with socket-eye fitting.

ei - Clamps, suspension with socket eye - cushioned

For use with **High Temperature Conductors**

Manufacturer	Conditions
<b><u>Preformed Line Products (PLP)</u></b> Thermolign Suspension  To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS

NOTE: These clamps are acceptable when installed using tools and dies in accordance with the conductor's manufacturer's recommendations.



ej - Clamps, deadend with socket eye

ACSR

	AWG	kcmil					
	2/0 to 4/0	266.8	336.4	477	556.5	795	954
		<u>Iron or Steel Clamps (requires armor tape or liner)</u>					
Hubbell (Anderson)	-	80445-2000	80445-2000	-	-	-	-
		<u>Aluminum Alloy Clamps (do not require armor tape or liner)</u>					
Anderson/Hubbell	SD-57-S	SD-70-S	SD-70-S	SD-86-S	SD-86S	--	--
C & R	CR-10-60S	CR-20-60S	CR-20-60S	--	--	--	--
Lapp	305757S	305758S	305759S	305760S	--	--	--
MacLean (Bethea)	ADE-21-S	ADE-22-S	ADE-23-S	ADE-24-S	ADE-24-S	ADE-2526-S	ADE-2526-S

NOTE: When used with clevis-type insulators for large conductors on distribution lines, order clamp with clevis eye.

ej - Clamps, dead-end with socket eye

For use with **High Temperature Conductors**

Manufacturer	Conditions
<b><u>Preformed Line Products (PLP)</u></b>	
Thermolign Dead-end	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS
To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	
<b><u>AFL</u></b>	
Compression Dead-end	1. To obtain experience. 2. Use high temperature accessories approved by the manufacturer and accepted by RUS
To be used with 3M High Temperature Conductors ACCR (Aluminum Conductor Composite Reinforced)	

NOTES:

1. When used with clevis-type insulators for large conductors on distribution lines, order clamp with clevis eye.
2. These clamps are acceptable when installed using tools and dies in accordance with the conductor's manufacturer's recommendations.

ek - Locknuts

For Bolt Diam., in.:	<u>MF Type</u>				
	<u>3/8</u>	<u>1/2</u>	<u>5/8</u>	<u>3/4</u>	<u>7/8</u>
Allied Bolt, Inc.	22016	22009	22012	22013	22014
Hubbell (Chance)	3510	3511	3512	3513	3514
Hughes Brothers	MF30	MF50	MF60	MF70	--
Joslyn	J8581	J8582	J8583	J8584	J8584-1/2
Kortick	K1065	K1066	K1067	K1068	--
Line Hardware	SLN38	SLN50	SLN58	SLN34	SLN78
MacLean (Continental)	U4920	U4921	U4922	U4923	U4924

el - Sectionalizer

Manufacturer	Type
Eaton	GH (with crossarm mounting bracket KA27G)

el - Sectionalizer

Manufacturer	Conditions
<u>Eaton</u> Sectionalizer, three-phase Type GN3	To obtain experience.
Sectionalizer with 125 kV BIL accessory Type GH, 15 kV, single phase	1. To obtain experience. 2. For use on single-phase taps of 24.9/14.4 kV multi-grounded wye systems.
*Sectionalizer, three-phase Type GN3E 14.4 kV, 200 amp max.	To obtain experience.
*Sectionalizer, three-phase Types GV and GVC 14.4 kV, 400 amp. max.	To obtain experience.
*Sectionalizer, three-phase Types GW and GWC 34.5 kV, 400 amp. max.	To obtain experience.
<u>General Electric</u> Sectionalizer, single-phase cutout-type - 15 kV and 25 kV Model 9F41F	To obtain experience.
<u>Hubbell</u> Sectionalizer, Single-Phase Type CRS Single-Phase, Cutout Type 15 kV, 95 kV BIL 200 amp max. 27 kV, 125 kV BIL 200 amp max. 38 kV, 150 kV BIL 200 amp max.	To obtain experience.
Sectionalizer, Single-Phase Type PRS Single-phase, Cutout Type with and without loadbreak accessory 15 kV, 110 kV BIL 300 amp max. cont. 27 kV, 125 kV BIL 300 amp max. cont. 38 kV, 150 kV BIL 300 amp max. cont. 38 kV, 170 kV BIL 300 amp max. cont.	To obtain experience.
<u>Joslyn</u> Sectionalizer, three-phase, 15 kV, 400 and 600 amperes 25 kV, 600 amperes Model VBM with VT or RS control	To obtain experience.

\*NOTE: Ratings greater than 100 ampere for 12.5/7.2 kV application and greater than 200 ampere for 24.9/14.4 kV application are acceptable only with ground trip device.

NOTE: Cutout type sectionalizers may also be used with cutout frames listed on pages af-1 and ax-1. Consult manufacturer for application.

em-1  
November 2013

em - Brace, crossarm, special  
(angle alley arm)

#### DISTRIBUTION

15" span, 14" drop; 1-1/2" x 3/16"

Kortick	K1978
MacLean (Continental)	U5514

#### TRANSMISSION

	<u>30" Span x 20" Drop</u>	<u>42" Span x 27" Drop</u>
Hubbell (Chance)	-	6999
Hughes Brothers	AS-2309-B	AS-2309-A
Kortick	K1975	K1976
MacLean (Continental)	U5509	U5510

eq - Narrow Profile Brackets and Special Arm Assemblies

METAL BRACKETS

Manufacturer	Conditions
<u>Dixie</u> Deadend bracket assembly D21142 for 12.5/7.2 kV Deadend bracket assembly D21144 for 24.9/14.4 kV	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected.
<u>Hubbell (Anderson)</u> Standoff bracket, COB-E-180-TGL	Same as above.
<u>Hubbell (Chance)</u> Single post insulator brackets C206-0209 for 12.5/7.2 kV construction only C206-0010 for 24.9/14.4 kV construction Deadend bracket assembly, C206-0179 Deadend bracket assembly, C206-0211 for 24.9/14.4 kV construction	Same as above.
<u>Joslyn (Flagg)</u> Standoff bracket, PA619B	Same as above.
<u>MacLean (Continental)</u> Standoff bracket IACB-18-5	Same as above.

eq - Narrow Profile Brackets and Special Arm Assemblies

METAL BRACKETS

<u>Manufacturer</u>	<u>Conditions</u>
<u>Joslyn</u> Single post insulator brackets 24840.1, for 12.5/7.2 kV construction only 24840.2, for 24.9/14.4 kV construction	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected.
<u>MacLean (Bethea)</u> Single post insulator bracket, HBF-10-9-GC Standoff bracket VIB3-18-GC	Same as above.
<u>M.D. Henry Company, Inc.</u> Single post insulator bracket, SAB-3-18-GC	Same as above.



eq - Narrow Profile Brackets and Special Arm Assemblies

FIBERGLASS REINFORCED PLASTIC  
For 12.5/7.2 kV

<u>Manufacturer</u>	<u>Catalog Number</u>	<u>Conditions</u>
<u>Aluma-Form</u> Single Phase	F1CA-MV-x18*	<ol style="list-style-type: none"> <li>1. To obtain experience.</li> <li>2. For use only in scenic areas and locations where right-of-way is limited.</li> <li>3. Not to be used where conductor galloping may be expected.</li> <li>4. Not to be used in contaminated atmospheres.</li> </ol>
<u>Hubbell (Chance)</u> Two-phase pin bracket Standoff insulator Deadend arm	2SBM36VV4 1SBM13H1 DEM36SP	Same as above.
<u>MacLean (Continental)</u> Two-phase pin bracket Two-phase angle bracket Standoff insulator Standoff insulator Deadend arm Suspension bracket	G2MDA x 36DV2 G2MDA X 36AX1 G1MDA x 12AS1 G1MDA x 18AS1 GDAS-36E G1MDA x 18AE	Same as above.
<u>MacLean (Joslyn)</u> Standoff bracket	G1MDA x 18AT	Same as above.

\* x = "A" for angled, 15 degrees or "H" for horizontal

eq - Narrow Profile Brackets and Special Arm Assemblies

FIBERGLASS REINFORCED PLASTIC  
For 12.5/7.2 kV

<u>Manufacturer</u>	<u>Catalog Number</u>	<u>Conditions</u>
<u>M.D. Henry Company, Inc.</u>	TPIV-1.5-36 TPIV-1.5-36-1.375 SPSS-1.5-13 SPSS-1.5-18	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used in contaminated atmospheres.
<u>Hughes Brothers</u>		
Two-phase angle bracket	761-36-8	Same as above.
Two-phase pin bracket	813-36	
Standoff insulator	560-13	
Standoff insulator	560-18	
Suspension bracket	615-18	
Deadend arm	540-36	
Standoff bracket	892-18	
<u>Fiberglass Line Hardware</u>		
	FLH Series FLHR Series	Same as above.

eq - Narrow Profile Brackets and Special Arm Assemblies

FIBERGLASS REINFORCED PLASTIC  
For 24.9/14.4 kV

<u>Manufacturer</u>	<u>Catalog Number</u>	<u>Conditions</u>
<u>Aluma-Form</u> Single Phase	F1CA-MV-x18*	<ol style="list-style-type: none"> <li>1. To obtain experience.</li> <li>2. For use only in scenic areas and locations where right-of-way is limited.</li> <li>3. Not to be used where conductor galloping may be expected.</li> <li>4. Not to be used in contaminated atmospheres.</li> </ol>
<u>Hubbell (Chance)</u> Two-phase pin bracket Standoff insulator Deadend arm	2SBM44VV4 1SBM19V4 DEM48SP	
<u>MacLean (Continental)</u> Two-phase pin bracket Two-phase pin bracket Standoff insulator Standoff insulator Standoff insulator Standoff bracket Deadend arm	G2MDA x 44DV3 G2HDA x 48DV3 G1MDA x 18DV3 G1MDA x 19DV3 G1MDA x 20DV3 G1MDA x 18AT GDAS-48E	Same as above.
<u>M.D. Henry Company, Inc.</u>	TPIV-1.5-44-1.375 TPIV-1.5-48-1.375 TPIV-2-48-1.375 SPSV-1.5-18-1.375 SPSV-1.5-19-1.375 SPSV-1.5-20-1.375 SPSV-2-20-1.375 SP3CA-1.5-18	Same as above.

\* x = "A" for angled, 15 degrees or "H" for horizontal

eq - Narrow Profile Brackets and Special Arm Assemblies

FIBERGLASS REINFORCED PLASTIC  
For 24.9/14.4 kV

<u>Manufacturer</u>	<u>Conditions</u>
<u>Hughes Brothers</u> Deadend arm, 540-48 Standoff insulator, 880-20 Two-phase pin bracket, 883-48 Standoff insulator, 870-19 Two-phase pin bracket, 862-44 Standoff bracket, 892-18	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used in contaminated atmospheres.

eq - Narrow Profile Brackets and Special Arm Assemblies

WOOD ARM ASSEMBLIES

<u>Manufacturer</u>	<u>Conditions</u>
<u>Aluma-Form</u> Arm assembly, 12.5/7.2 kV XA-3812 Arm assembly, 24.9/14.4 kV XA-4214	1. To obtain experience. 2. For use only in scenic areas and locations where right-of-way is limited. 3. Not to be used where conductor galloping may be expected. 4. Not to be used as deadend structures.
<u>Hughes Brothers</u> Deadend arm, 2890-J complete with braces and attaching hardware, fittings and bolts	1. To obtain experience. 2. For use only in scenic areas and locations right-of-way is limited. 3. Not to be used where conductor galloping may be expected.

eq - Narrow Profile Brackets and Special Arm Assemblies

COMBINATION INSULATORS AND BRACKETS

Manufacturer	Conditions
<u>Salisbury</u> Horizontal Post 12.5/7.2 kV, 9561 24.9/14.5 kV, 9562	<ol style="list-style-type: none"><li>1. To obtain experience.</li><li>2. For use only in scenic areas and locations where right-of-way is limited.</li><li>3. Not to be used where conductor galloping may be expected.</li><li>4. Not to be used in contaminated atmospheres.</li></ol>

er - Wire Guard, Plastic

See Drawing K4.1G

Manufacturer	Type orCatalog Number
Hubbell (Chance)	PFG
Hubbell (Fargo)	GM-936
Preformed Line Products (Tree Guard)	PTG

es - Splice Cover, Plastic

(For use over compression type service connections in place of tape)

<u>Manufacturer</u>	<u>Type</u>
Hubbell (Anderson)	Type SEC
Kearney/Eaton	Type 601
Plastic Engineering & Sales Co.	Wire Splice Cover
3M	PST Series 8420
Virginia Plastics	Type VP

Splice Cover and Moisture Seal for Secondary Cable Connections  
(See Drawings G312 and UM5)

<u>Manufacturer</u>	<u>Type</u>
TE Connectivity - Energy	Sealing & Dielectric Compound
Plymouth/Bishop	10 Plyseal
3M	Scotch Brand #2200

Bolted Connector Cover

(For use over bolted type service connections in place of tape)

<u>Manufacturer</u>	<u>Type</u>
Hubbell (Anderson)	PTC
Hubbell (Fargo)	GA-9000 B Series



eu - Extension Link  
(Fiberglass)  
(Distribution)

Manufacturer	Strength	Catalog Number
Dulmison	11,000 lbs.	HSB-1-12*
	15,000 lbs.	HSB-2X-12
Joslyn (Flagg)	11,000 lbs.	150-12EE
	15,000 lbs.	150-12EE
Hubbell (Anderson)	10,000 lbs.	GSB1-9*
	15,000 lbs.	GSB2-12
	16,000 lbs.	GS16012EE
K-Line	15,000 lbs.	KL Series
MacLean (Continental)	11,000 lbs.	GEE11-12*
	15,000 lbs.	GEE15-12

\*For use with 6" suspension insulators.

ex - Splice, formed type

Manufacturer	Conditions
<u>Preformed Line Products</u>	
Splice for ACSR FTS full tension splice	To obtain experience.
Splice for AWAC LS-0185 for 4-4/3 LS-0188 for 2-4/3 LS-0191 for 1/0-4/3	For repair only. To obtain experience. For repair only where alumoweld strands are not broken.

fc - Capacitors, Shunt  
12470/7200 Volts

Manufacturer	Size	1 Bushing	2 Bushing	3 Bushing
ABB	100 kvar	A10009	A10010	
	150 kvar	A15009	A15010	
	200 kvar	A20009	A20010	
	300 kvar	A30009	A30010	
	400 kvar	A40009	A40010	
Eaton	50 kvar	CEP120B6	CEP120A6	
	100 kvar	CEP131B6	CEP131A6	
	150 kvar	CEP132B6	CEP132A6	
	200 kvar	CEP140B6	CEP140A6	
	300 kvar	CEP160B6	CEP160A6	
	400 kvar	CEP170B6	CEP170A6	
	500 kvar	CEP180B6	CEP180A6	
General Electric Film/Foil Type	25 kvar	52L226RC	52L206RC	
	50 kvar	51L226RC	51L206RC	
	100 kvar	54L226RC	54L206RC	
	150 kvar	54L526RC	54L506RC	
	200 kvar	58L126RC	58L106RC	
	300 kvar	59L226RC	59L206RC	59L611RC

24900/14400 Volts

Manufacturer	Size	1 Bushing	2 Bushing	3 Bushing
ABB	100 kvar	A10031	A10032	
	150 kvar	A15031	A15032	
	200 kvar	A20041	A20042	
	300 kvar	A30031	A30032	
	400 kvar	A40031	A40032	
Eaton	50 kvar	CEP123B9		
	100 kvar	CEP130B9		
	150 kvar	CEP139B9		
	200 kvar	CEP143B9		
	300 kvar	CEP163B9		
	400 kvar	CEP173B9		
	500 kvar	CEP183B9		
General Electric Film/Foil Type	50 kvar	51L252RC		
	100 kvar	54L252RC		
	150 kvar	54L552RC		
	200 kvar	58L154RC		
	300 kvar	59L154RC		
	400 kvar	98L154RC		

fd – Hangers, Capacitor

Crossarm Mounting			
	1 unit	2 units	3 or 4 units
ABB	85B397G01	791C644G01	791C644G02
Eaton	CH1A1	CH2A2	CH4A1
General Electric	39F41G2	39F53	39F80G1

Pole Mounting			
	Single Phase	Three Phase	
		In Line	Cluster
ABB	AL30R (3 units) AL60R (6 units)	(1 Ø units)	
		AL30R	(3 units)
		AL60R	(6 units)
		AL90R	(9 units)
		(3 Ø units)	
		AL13W	(1 unit)
		AL23W	(2 units)
		AL33W	(3 units)
		AL43W	(4 units)
		AL53W	(5 units)
Aluma-Form	CR-3* thru CR-6*	CR-3/4*	3-CR-3/4*
General Electric	39F41G1 (1 unit) 39F83G1 (3 units)	39F86G1	
Hubbell Power Systems Inc.	CCR-1* Thru CCR-6*	CCR-3/4*	CCR-9/12*
MacLean Power Systems	-	MCR-3 MCR-3/4 MCR-6	

\* Available with oil switch mounting bracket.

fg - Crossarm Saddle

(3-3/4" x 4" with 1-1/4" x 1/4" flange)

Manufacturer	Catalog Number
Lapp	10369

fi - Connectors, hot line

Over Armor Rods

<u>Manufacturer</u>	<u>Catalog Number or Series (Al to Al)</u>	<u>Catalog Number or Series (Al to Cu)</u>
Blackburn	PGH	-
Hubbell (Anderson)	AC Series	AC-GP-Series
Hubbell (Fargo)	GA-100 Series	GA-100C Series

fj – Bracket, extension

(For use in mounting circuit reclosers or sectionalizers)

See Drawing VM3-10A

	Through Bolt Type	Band Type
Aluma-Form	TBRSM-1, TB2M1-9*	RSM-1
Dixie	D-2359-M	-
Joslyn	J2357	-
MacLean Power Systems	MTB2M1-9	-

\*For mounting double lug reclosers.

fk – Bracket, circuit recloser or sectionalizer

(For cluster mounting of three circuit reclosers on pole)

	Cluster Mount	Rack Mount
Aluma-Form	RSM-3, 6M3-9*	3SPR-66, 3SPR-84
MacLean Power Systems	-	M3SPR-66
Turner	695-3	-

\*Suitable for 14.4 and heavy duty 7.2 kV.

fl – Rack, primary metering

(For cluster mounting of primary metering equipment on pole)

Aluma-Form	PMM Series
Barfield Manufacturing Co.	BAPMM6
Turner	3CT-PT
MacLean Power Systems	MPMM-6

fm - Extension Bracket for Mounting Apparatus  
(Arrester, Cutouts and Potheads for Distribution Pole Mounting)

Manufacturer	Application Voltage	Single Phase	Three Phase
Aluma-Form, Inc.	12.5/7.2 kV	1HCA-18 Series 1HCA-C-18	R3CA-48 F3CA-MV-H3012 series F3CA-MV-A3012 series
	24.9/14.4 kV	WBMA-1	R3CSA-48 F3CA-MV-H4017 series F3CA-MV-A4017 series
Barfield Mfg. Co.	12.5/7.2 kV	BAC 1256	-
	24.9/14.4 kV	BAC 1710	-
	12.5/7.2 kV	BACA 126	-
	24.9/14.4 kV	(double mounting) BACA 1710 (double mounting)	-
Dixie	12.5/7.2 kV	D-1580	D27211-G
	24.9/14.4 kV	D-1583	-
Hubbell (Anderson)	12.5/7.2 kV	COB-E-120-TGL	-
	24.9/14.4 kV	ACOB-E-180	-
		COB-E-180-TGL	-
Hubbell (Chance)	24.9/14.4 kV	C653-1038	C653-1056
Hubbell Power Systems, Inc.		1SBMxxTD Series	-
		1SBMxxAM Series	-
		1SBMxxC Series	-
		1SBMxxAMT Series	-
		1SBMxxCT Series	-
		1SBMxxCL Series	-
		1SBMxxSGL Series	-
	12.5/7.2kV	C1HCAC	-
	12.5/7.2kV	C1HCA	-
	24.9/14.4kV	C1HCAC18	-
	24.9/14.4kV	C1HCA18	-
Hughes Brothers	12.5/7.2 kV	892-18	670-40
	24.9/14.4 kV		
Line Hardware	12.5/7.2 kV	CA-12-3GL	-
MacLean (Bethea)	12.5/7.2 kV	VIB3-18-R1-GC-C	-
		VIB3-12F-GC	-
	24.9/14.4 kV	VIB3-18-GC	-

Note: Above brackets are not suitable for supporting or deadending distribution line conductors.  
(See items "eq" for narrow profile bracket and special arm assemblies)



fm-1.1  
June 20, 2025

fm - Extension Bracket for Mounting Apparatus  
(Arrester, Cutouts and Potheads for Distribution Pole Mounting)

<u>Manufacturer</u>	<u>Application Voltage</u>	<u>Single Phase</u>	<u>Three Phase</u>
MacLean (Continental)	12.5/7.2 kV 24.9/14.4 kV	IACB-12-5LGE IACB-18-5LGE	G3MA013012DD G3MA014017DD
MacLean Power Systems	12.5/7.2 kV	M1HCA-C-18	MR3CA-48
M.D. Henry Company, Inc.	24.9/14.4 kV	SAB-3-18-GC	-
Fiberglass Line Hardware	12.5/7.2 kV 24.9/14.4 kV	FLHR Series FLHR Series	FLH3 Series FLH3 Series

Note: Above brackets are not suitable for supporting or deadending distribution line conductors.  
(See items "eq" for narrow profile bracket and special arm assemblies)

fn - Extension Bracket for Mounting Cutouts

Refer to item fm

fo-1  
July 2009

fo - Bracket, Transformer Secondary, Insulated

Manufacturer Insulator	Bracket Without Insulator	Bracket With 2-1/4" Diameter Spool Insulator	Bracket With 3-1/8" Diameter Spool
Hubbell (Chance)	-	9113S	9114S
Joslyn	-	J6765-A	J6765
MacLean (Continental)	U865	U865/208	U865/205

fp-1  
July 2009

fp - Oval Eye Ball  
(30,000 lbs; to be used with 52-3 and 52-5 insulators)

Manufacturer	No.
--------------	-----

(No accepted items at this time)

fq - Laminated Upswept Arms

Applicable Specification: RUS Specification DT-5B

Applicable Drawing: RUS Drawing TUS-1

Manufacturer	Conditions
<u>Hughes Brothers</u> Types: C-4080A (5-1/8" width) C-4080B (5-1/8" width) C-4113A (3-1/8" width) C-4113B (3-1/8" width)	1. To obtain experience. 2. For use only in scenic and urban areas where right- of-way is limited.

fs-1  
February 2015

fs - Pole Bearing Plate

Manufacturer	Catalog Number
Hubbell (Chance)	C1100954

fs - Pole Bearing Plate

<u>Manufacturer</u>	<u>Conditions</u>
<u>Joslyn (Flagg)</u> P325B-122	Same as above.
<u>MacLean (Continental)</u> PB-80-7	Same as above.

ft - Y-Clevis Ball

Manufacturer	Catalog Number
Joslyn	BT 3030
Preformed Line Products	BYC-30



fu - Swinging angle bracket

(TRANSMISSION)

Applicable Specification: T-8

Swinging angle bracket with hardware and fittings

<u>Manufacturer</u>	<u>2' - 0"</u>	<u>3' - 6"</u>	<u>Type #1</u>	<u>Type #2</u>
Brooks	64233A	64233B	X	
Hughes Brothers	2848	2848	X	X

fv-1  
July 2009

fv - Guying Attachments  
Transmission

Pole Eye Plates\*

25,000 lbs. @ 90°/36,000 lbs. @ 45°

Manufacturer	Single Eye		Double Eye - 7/8" Bolts
	<u>3/4" Bolts</u>	<u>7/8" Bolts</u>	
Joslyn (Flagg)	PX37D	-	PX42
MacLean (Continental)	EPR-66S-12	-	-

\*Capacity of pole eye plate

fv - Guy Attachments, Pole Bands Attachments, Pole Bands  
With Through Bolts for Transmission Lines

Medium Duty Pole Bands

25,000 lbs @ 90°/36,000 lbs @ 45°\*

<u>Manufacturer</u>	<u>Pole Band and Associated Hardware**</u>	<u>Conditions</u>
Hughes Bros.	3108.x-2718.55	To obtain experience.
Joslyn	J25968. x GL	To obtain experience.

Heavy Duty Pole Bands

36,000 lbs. @90° /51,000 lbs. @ 45°\*

<u>Manufacturer</u>	<u>Pole Band and Associated Hardware**</u>	<u>Conditions</u>
Hughes Bros.	3107.x-2718.55	To obtain experience.

\* For a guy lead greater than 1/1, capacity of pole band should be derated.

\*\* Associated hardware includes through bolt, band connecting bolts, nuts, grounding clip and lag screws (if any).  
Connecting links (Item du (1)) of the required strength should be ordered separately from the same manufacturer.

ga - Watthour and Watthour-Demand Meters  
1ø, 2 and 3 wire or 2/3 wire 120/240 volts

(Classes 100, 200, 10, and 20)

Self-Contained Types

Manufacturer	Type of Base	Watthour Meter Type	Mechanical Demand Watthour Type	Thermal Demand Watthour Type	Number of Terminals
1	2	3	4	5	6
Elster	Bottom Con. Socket	- AB1	- -	- -	- 4
General Electric	Bottom Con. Socket	I50A I70S	IM50A IM70S	- -	4 4
Landis & Gyr	Bottom Con. Socket	- MS	- BMS-2S	- TMS	- 4
Schlumberger	Bottom Con. Socket	J5SA J5S*	J5DSA J5DS	- -	- 4

Transformer Rated Types

Elster	Bottom Con. Socket	- AB1	- -	- -	- 5 or 6
General Electric	Bottom Con. Socket	I50A I70S	IM50A IM70S	- -	5 or 6 5 or 6
Landis & Gyr	Bottom Con. Socket	- MS	- BMS	- TMS	- 5 or 6
Schlumberger	Bottom Con. Socket	J5SA J5S	J5DSA J5DS	- -	- 5 or 6

\* Type J4ES for Class 320

ga - Watthour and Watthour-Demand Meters  
Polyphase 2 element - 3 wire, 240 volts - Delta and 120/208 Volts Network

(Classes 100, 200, 10, and 20)

Self-Contained Types

Manufacturer 1	Type of Base 2	Watthour Meter Type 3	Mechanical Demand Watthour Type 4	Thermal Demand Watthour Type 5	Number of Terminals 6
Elster	Bottom Con. Socket	- ABS-5	- -	- -	- -
General Electric	Bottom Con. Socket	V62A V62S	VM62A VM62S	- -	5 -
Landis & Gyr	Bottom Con. Socket	- MT012S or 13S	- BMT-12S or 13S	- TMT-12S	- 5 or 8
Schlumberger	Bottom Con. Socket	SL2A SL2S SL12S	SL2DA SL2DS SL12DS	- -	5 or 8 -

Transformer Rated Types

Elster	Bottom Con. Socket	ABA-2 ABS-2	- -	- -	- 8
General Electric	Bottom Con. Socket	V63A V63S	VM63A VM63S	- -	8 -
Landis & Gyr	Bottom Con. Socket	MT-5A MT-5S	BMT-5A BMT-5S	TMT-5A TMT-5S	8 8
Schlumberger	Bottom Con. Socket	SL3A SL3S	SL3DA SL4DS	- -	- 8

ga - Watthour and Watthour-Demand Meters  
Polyphase 2 element - 4 wire Delta - 120/240 volts

(Classes 100 or 200)

Self-Contained Types

Manufacturer	Type of Base	Watthour Meter Type	Mechanical Demand Watthour Type	Thermal Demand Watthour Type	Number of Terminals
1	2	3	4	5	6
Elster	Bottom Con. Socket	ABA-7	-	-	7 or 8
		ABS-7	-	-	-
General Electric	Bottom Con. Socket	V66A	VM66A	-	7
		V66S	VM66S	-	-
Landis & Gyr	Bottom Con. Socket	-	-	-	-
		MT-15S	BMT-15S	TMT-15S	7
Schlumberger	Bottom Con. Socket	SL6A	SL6DA	-	-
		SL6S	SL6DS	-	7 or 8

ga - Watthour and Watthour-Demand Meters  
Polyphase - 2-1/2 element - 4 wire wye - (120/208) (277/480) volt

(Classes 100, 200, 10, and 20)

Self-Contained Types

Manufacturer 1	Type of Base 2	Watthour Meter Type 3	Mechanical Demand Watthour Type 4	Thermal Demand Watthour Type 5	Number of Terminals 6
Elster	Bottom Con. Socket	ABA-8 ABS-8	- -	- -	- -
General Electric	Bottom Con. Socket	V65A V65S	VM65A VM65S	- -	7 -
Landis & Gyr	Bottom Con. Socket	- MT-14S	- BMT-14S	- TMT-14S	- 7
Schlumberger	Bottom Con. Socket	SL5A SL5S	SL5DA SL5DS	- -	- 7 or 8

Transformer  
Rated Types

Elster	Bottom Con. Socket	ABA-8 ABS-8	- -	- -	- 13
General Electric	Bottom Con. Socket	V65A V65S	VM65A VM65S	- -	7 or 13 -
Landis & Gyr	Bottom Con. Socket	MT-6A MT-7S or 6S	BMT-6A BMT-7S or 6S	TMT-6A TMT-7S or 6S	10 7 or 13
Schlumberger	Bottom Con. Socket	SL5A SL5S	SL5DA SL5DS	- -	- 13

ga - Watthour and watthour-Demand Meters

Polyphase - 3 element - 4 wire wye - (120/208) (277/480) volt

(Classes 100, 200, 10, and 20)

Self-Contained Types

Manufacturer 1	Type of Base 2	Watthour Meter Type 3	Mechanical Demand Watthour Type 4	Thermal Demand Watthour Type 5	Number of Terminals 6
Elster	Bottom Con. Socket	ABA-3 ABS-3	- -	- -	- 7 or 8
General Electric	Bottom Con. Socket	V64A V64S	VM64A VM64S	- -	- 7 or 8
Landis & Gyr	Bottom Con. Socket	- MT-16S	- BMT-16S	- -	- 7
Sangamo	Bottom Con. Socket	S4A S4S	S4DA S4DS	- -	- 7 or 8

Transformer  
Rated Types

Elster	Bottom Con. Socket	ABA-3 ABS-3	- -	- -	- -
General Electric	Bottom Con. Socket	V64A V64S	VM64A VM64S	- -	- 13
Landis & Gyr	Bottom Con. Socket	MT-9A MT-9S or 10S	BMT-9A BMT-9S or 10S	- -	12 13
Sangamo	Bottom Con. Socket	SL4A SL4S	SL4DA SL4DS	- -	- 13



ga - Meters, Min/Max Indicating

Ammeters Indicating

<u>Manufacturer</u>	<u>Type</u>	<u>Description</u>
Biddle	50,000 Series	Thermal, Max Pointer
Demico	AD121R	Digital min/max ampere demand meter
ED Electric	Max-I-Meter(all models)	Thermal Ammeter
Schlumberger	ADS	Thermal Ammeter

Voltmeter, Min/Max

<u>Manufacturer</u>	<u>Type</u>	<u>Description</u>
Bitronics	VMAMC1	Digital Demand min/max voltmeter
Demico	AV121R	Digital min/max voltmeter
Reid and Rochon Associates	LVM-100	Digital Demand min/max voltmeter

ga - Watthour and Watthour-Demand Meters

Manufacturer	Conditions
<u>Landis &amp; Gyr</u>	
Special base, 3 wire, 1 ø watthour meter, Type MS-K, Class 400 watthour and mechanical demand Type BMS-K watthour and thermal demand Type TMS-2K	1. To obtain experience. 2. To be used only where Class 400 meters are permitted by local regulatory bodies.
Socket base, 3 wire, 1 ø watthour meter, Type MS-E, Class 300	1. To obtain experience. 2. To be used only where Class 300 meters are permitted by local regulatory bodies.

ga - Watthour and Watthour-Demand Meters  
Solid State Registers

Manufacturer	Conditions
<u>Electro Industries/GaugeTech</u>	
NEXUS 1262 Form 9S, Class 20	To obtain experience.
NEXUS 1272 Form 9S, Class 20	
<u>Elster</u>	
Solid State Polyphase Watthour meter, Alpha line, A1, A and S type bases (all forms) Class 20 and 200, 120, 240, 277, and 480 V	To obtain experience.
<u>GE</u>	
kV Vector Meter	To obtain experience.
Form 10A, 36A, 45A, 48A, 3S, 9S, 36S, 45S, 56S; Class 20; 120 V to 480V or 57V to 120V	
Form 13A, 16A; Class 150; 120V to 480 V	
Form 2S, 12S, 16S; Class 200 or 320; 120V to 480V	
<u>Sensus</u>	
Socket base, single-phase watthour meters	To obtain experience.
Form 1s, 12s, 2s, Class 200 @ 120, and 240 Volts	
Form 2s Class 320 @ 240 Volts	
Form 3s & 4s Class 20 @ 120, and 240 Volts	
Socket base, poly-phase watthour meters	To obtain experience.
Form 9s Class 20 @ 120-480 Volts	
Form 16s Class 200 @ 120-480 Volts	
<u>Itron Inc.</u>	
SENTINEL	To obtain experience.
Forms 9S, 10A, 45A, 45S, 46A, 46S, 48A, 66S Class 20	
Form 16A Class 150	
Forms 2S, 12S, 16S Classes 200 and 320	

ga - Watthour and Watthour-Demand Meters  
Solid State Registers

Manufacturer	Conditions
<u>Landis+Gyr</u>	
Solid State Watthour Meter Type DDS2, Form 5S, 6S, 8S, 9S, 10S, Class 20.	To obtain experience.
<u>FOCUS</u>	
Form 1S, Class 100	
Form 25S, Class 200	
Form 2S, Class 200TA30 and 200TA50	
Form 2SE, Class 320TA30 and 320TA50	
Form 2K, Class 4800/600	
Form 3S, 4S, Class 10 and 20	
<u>Altimus Solid State Meter</u>	
Form 1S, Class 100	
Form 25S, Class 200	
Form 2S, Class 200TA30 and 200TA50	
Form 2SE, Class 320TA30 and 320TA50	
Form 2K, Class 480/600	
Form 3S, 4S, Class 10 and 20	
<u>S4 Polyphase Solid State Meter</u>	
Form 5S/45S, 6S/36S, 9S/8S, Class 20	
Form 12S, 16S, Class 200	
<u>Power Measurement</u>	
<u>ION 8300</u>	
Form 9S, 35S, 36S Class 20	To obtain experience.
<u>ION 8400</u>	
Form 9S, 35S, 36S, 39S, 76S Class 20	To obtain experience.
<u>ION 8500</u>	
Form 9S, 35S, 36S, 39S, 76S Class 20	To obtain experience.
<u>Schlumberger</u>	
<u>CENTRON</u>	
Form 2S, Class 200.	To obtain experience.
Solid State or Mechanical Register.	
<u>FULCRUM SQ400</u>	
Form 5A, 6A, 9A, 5S, 6S, 9S, 10S, Class 20	To obtain experience.
<u>FULCRUM SL300 Series</u>	
Form 5A, 6A, 8A, 9A, 5S, 6S, 8S, 9S, 10S, 12S, 14S, 15S, 16S, Class 20 and 200.	To obtain experience.
<u>QUANTUM Q200 Series</u>	
Form 5A, 6A, 8A, 9A, 5S, 6S, 8S, 9S, 10S, 26S, Class 20 and 200.	To obtain experience.
<u>QUANTUM Q300 Series</u>	
Form 6A, 9A, 6S, 9S, 10S, Class 10 and 20.	To obtain experience.
<u>VECTRON SVX</u>	
Form 5A, 6A, 8A, 10A(9A), 5S, 6S, 9S(8S), 12S, 16S(14S, 15S), 26S, Class 20 and 200.	To obtain experience.

Conditional List  
ga(2.2)  
July 2009

ga - Watthour and Watthour-Demand Meters  
Solid State Registers

Manufacturer	Conditions
<u>Transdata, Inc.</u> MARK-V EMS Form 5S, 5A, 6S, 6A, 8S, 8A, 9S, 9A Class20	To obtain experience.

gb - Meter Sockets

Type or Catalog Number				
<u>Manufacturer</u>	<u>Ring</u>	<u>Ringless</u>	<u>No. Jaws</u>	<u>Rating Amps.</u>
ABB	#S		4, 5, 6	100
	STS		5, 6	200/400** 1ø 3w
	STS-2		8	200/400** 3ø 3w
	STS-3		13	200/400** 3ø 4w Y or Delta
	STS-7		8	200/400** 3ø 4w Delta
	STS-8		8 or 13	200/400** 3ø 4w Y
		STA-2		200/400 3ø 3w
		STA-3		200/400 3ø 4W Y or Delta
		STA-7		200/400 3ø 4w Delta
		STA		200/400 1ø 3w
# Anchor	1000 Series (1003-1006)	1000 Series (1003-1006)	4, 5	100
	1100 Series (1100-1109)	1100 Series (1100-1109)	4, 5, 7	150
	1200 Series (1201-1209)	1200 Series (1201-1209)	4, 5	200
		1200/1300 Series (1275-1300)	4, 5, 7	200
	1600 Series (1600-1661)	1600 Series (1600-1661)	4, 5	320
	1500 Series (1500-1526)	1500 Series (1500-1526)	4, 5	100/125 per sta.
	1500 Series (1530-1536)	1500 Series (1530-1536)	4, 5	150 per sta.
	1500 Series (1540-1546)	1500 Series (1540-1546)	4, 5	200 per sta.
	1400 Series (1405-1473)	1400 Series (1405-1473)	4, 5, 6, 7, 8, 13	20/100
Murray	SJ Series* (Single)	RJ Series* (Single)	4, 5, 6	100
	SN Series* (Single)	RN Series* (Single)	4, 5, 6	100
	SS Series* (Single)	RS Series* (Single)	4, 5, 6	200
		RH Series* (Single)	5, 7	200 HD

#Available with UL label

\*UL label

gb-1.1  
July 2009

gb - Meter Sockets

Type or Catalog Number

<u>Manufacturer</u>	<u>Ring</u>	<u>Ringless</u>	<u>No. Jaws</u>	<u>Rating Amps.</u>
Durham	R-RS512	RS502#	4 or 5	150
	R-RS502	RS512#		
		H-4300 Series#	4, 5, 7	320
		H-5300 Series#		
		H-7300 Series#		
	RS101-RS111#	RS101-RS111#	4 or 5	100
	2R1121-6R1131#	2R1121-6R1131#		
	2R1421-6R1431#	2R1421-6R1431#		
	RS202#	RS202#	4 or 5	200
	RS212, RS213#	RS212, RS213#	4 or 5	200
Eaton Electrical	RS220-RS233#	RS220-RS233#		
	2R2332-6R2392#	2R2332-6R2392#		
	R-RS512-CH	RS502-CH #	4 or 5	150
	R-RS502-CH	RS512-CH#		
		H-4300-CH Series#	4, 5, 7	320
		H-5300-CH Series#		
		H-7300-CH Series#		
	RS101-RS111-CH #	RS101-RS111-CH #	4 or 5	100
	2R1121-6R1131-CH#	2R1121-6R1131-CH #		
	2R1421-6R1431-CH #	2R1421-6R1431-CH #		
Dyna-Tech	RS202-CH #	RS202-CH #	4 or 5	200
	RS212-CH, RS213-CH #	RS212-CH, RS213-CH #	4 or 5	200
	RS220-RS233-CH #	RS220-RS233-CH #		
	2R2332-6R2392-CH #	2R2332- 6R2392-CH #		
	<u>Overhead</u>			
	1100-C - 1107-C	1000-C - 1007-C	4 & 5	100
	1300-C - 1307-C	1200-C - 1207-C	4 & 5	100
	2100-CH-2107-CH	2000-CH-2007-CH	4 & 5	200
	2300-CH-2307-CH	2200-CH-2207-CH	4 & 5	200
	<u>Underground</u>			
General Switch		2590-CHU-2597-CHU	4 & 5	200
		2790-CHU-2797-CHU	4 & 5	200
		2090-CHU-2097-CHU	4 & 5	200
		2290-CHU-2297-CHU	4 & 5	200
	42100 Series*		4, 5, 6	100

\*UL Label

#Available with UL label

gb - Meter Sockets

Type or Catalog Number						
<u>Manufacturer</u>	<u>Ring</u>	<u>Ringless</u>	<u>No. Jaws</u>	<u>Bypass</u>	<u>Rating Amps.</u>	<u>Main Breaker</u>
<b><u>Landis &amp; Gyr</u></b>	<u>Overhead</u> AS Series	AS Series	4, 5, 6		100-200	
		A2 thru A6	4, 5		100-200	
		Series (Multiple Mounting)				
		CQ#	4, 5, 7		200	
		HQ#	4, 5, 7		200 HD	
	<u>Underground</u>	HQ-T	6, 7, 8, 13		20	
		RSU#	4, 5, 6		200	
		CQ-U#	4, 5, 7		200	
		HQ-U#	4, 5, 7		200	
<b><u>Milbank</u></b>	<u>Overhead</u>	S7462, 3,4,5,6				
		S4950-RL-200	4		200	200
		S3950-RL-100	4		100	100
		U4216-RXL	4		200	
		U5786-X-K3-K2-BL	4 or 5	Bypass		
		U7362*, 3,4,5,6	4 or 5	HD LVR	320 (400 max) (HD)	
		U7487-XL-TG-KK	4 or 5		100	
		R7486 Series*	4 or 5	Horn	125	
		S7486 Series	4 or 5		100	
		S7262 Series	4 or 5		150	
		S7021 Series	4 or 5		200	
		S9550 Series	4 or 5		200 (HD)	
		S9700 Series	7		200 (HD)	
		U9801-RRL	4 or 5	HD LVR	200	
	<u>Underground</u>	U4216-RXL	4	Bypass	200	
		U7487-XL-TG-KK	4 or 5	Horn	125	
		U5786-X-K3-K2-BL	4 or 5	HD LVR	320 (400 max) (HD)	
		S8086-XL	4 or 5		100	
		S8084-XL	4 or 5		150	
		S7040-XL	4 or 5		200	
		S9551-XL	4 or 5		200 (HD)	
		S9701-XL	7		200 (HD)	
		U9801-RRL	4 or 5	HD LVR	200	

# Available with UL label

\*UL label



gb - Meter Sockets

Type or Catalog Number						
<u>Manufacturer</u>	<u>Ring</u>	<u>Ringless</u>	<u>No. Jaws</u>	<u>Bypass</u>	<u>Rating Amps.</u>	<u>Main Breaker</u>
<b><u>Milbank</u></b>						
	<u>Underground</u>					
	<u>Pedestal</u>					
	MPAP-200-MB-78		4		200	200
	MPAPD-200-MB-78 (double sided)		4		200	200
<b><u>Superior</u></b>						
	<u>Overhead</u>					
		501	4, 5		100	
	314*	414*	4, 5		150	
	314*	414*	4, 5		200	
		452 Series	4, 5		150 per sta.	
	382 Series	482 Series*	4, 5		200 per sta.	
		492 Series	7		200 3ø 4w Y or Delta per sta.	
		RLK Series*	5, 7		200 3ø 4W Y or Delta 600 V	
	<u>Underground</u>					
<b><u>Superior</u></b>						
	314*	414*	4, 5		100	
		414*	4, 5		150	
		414	7		200 3ø 4w Y or Delta	
		"RLPK" Series	5, 7		200 3ø 4w Y or Delta 600 V	
		BRL 1915	4, 5		150 per sta.	

#Available with UL label

\* UL label

\*\* Transformer rating in first figure; maximum loading shown by second figure

gb - Meter sockets

Manufacturer	Conditions
<u>Durham</u> M-400 ampere 4 or 5 jaws for use with Class 10 meters	To obtain experience.
<u>Landis &amp; Gyr</u> Meter mounting device 400 ampere, Type K-4# for use with Type MS-K, 1 ø Duncan meters	1. To obtain experience. 2. To be used only where Class 400 meters are permitted by local regulatory bodies.
Socket type HQ-4S 4 jaws rated for Class 300 service	1. To obtain experience. 2. To be used only where Class 300 meters are permitted by regulatory bodies.
<u>Milbank</u> Type S1079-F, 4 jaws rated for Class 320 service	To obtain experience.

#Available with UL label.

gj - Crossarm Assemblies and Arm Spacers

Distribution

Wood crossarm assembly complete with braces and attaching hardware, fittings and bolts

Crossarm Assembly

<u>Manufacturer</u>	<u>Crossarm Size</u>	<u>Catalog No.</u>
Brooks	3-1/2" x 4-1/2" x 8'-0"	3103-A8
	3-3/4" x 5-3/4" x 8'-0"	3103-C8
	3-3/4" x 7-3/4" x 8'-0"	3203-A8
	3-3/4" x 7-3/4" x 10'-0"	3203-A10
Hughes Brothers	3-1/2" x 4-1/2" x 8'-0"	2890A
	3-3/4" x 5-3/4" x 8'-0"	2890B
	3-3/4" x 7-3/4" x 8'-0"	2892-A
	3-3/4" x 7-3/4" x 10'-0"	2892-B
Pennington	3-1/2" x 4-1/2" x 8'-0"	C500B
	3-3/4" x 5-3/4" x 8'-0"	C500F
	3-3/4" x 7-3/4" x 8'-0"	C500M

Twin Arm Spacer\*

To be used with standard hardware, 3-5/8" x 4-5/8" x 8'-0" crossarm, and 28" wood braces

Line Hardware                      CAS-455

\*Restricted to applications where the conductor's maximum design tension is less than 1250 lbs. and to conductor sizes 1/0 ACSR and below.

gj - Crossarm Assemblies

Braceless, wood

Manufacturer	Dimensions	Conditions
<u>Aluma-Form</u>		
HD-DEA-86-EB-REA	4-1/4" x 5-1/2" x 8'-0"	To obtain experience.
HD-2-DEA-86-EB-REA	5-3/8" x 5-1/2" x 8'-0"	
HD-DEA-108-EB-REA	4-1/4" x 5-1/2" x 10'-0"	
HD-2-DEA-108-EB-REA	5-3/8" x 5-1/2" x 10'-0"	
<u>Hughes Brothers</u>		
3377-A7.5	3-1/2" x 7-1/2" x 8'-0"	To obtain experience.
3377-A8.5	3-1/2" x 8-1/2" x 8'-0"	
3377-A9.5	3-1/2" x 9-1/2" x 8'-0"	

gj - Crossarm Assemblies

Braceless, fiberglass

Aluma-Form

FDA20-96	3-5/8" x 4 5/8" x 8'	To obtain experience.
FDA20-120	3-5/8" x 4 5/8" x 10'	
FDA25-96	3-5/8" x 4 5/8" x 8'	
FDA25-120	3-5/8" x 4 5/8" x 10'	
FDA30-96	3-5/8" x 4 5/8" x 8'	
FDA30-9120	3-5/8" x 4 5/8" x 10'	

Geotek (PUP)

DA2000096	3-5/8" x 4-5/8" x 8'-0"	To obtain experience.
DA2000120	3-5/8" x 4-5/8" x 10'-0"	
DA2500096	3-5/8" x 4-5/8" x 8'-0"	
DA2500120	3-5/8" x 4-5/8" x 10'-0"	
DA3000096	3-5/8" x 4-5/8" x 8'-0"	
DA3000120	3-5/8" x 4-5/8" x 10'-0"	
DA4000096	4" x 6" x 8'-0"	
DA4000120	4" x 6" x 10'-0"	
DA4400096	4" x 6" x 8'-0"	
DA4400120	4" X 6" X 10'-0"	

MacLean Power Systems

PZ08LD	4" x 6" x 8' – 0"	To obtain experience.
PZ10LD	4" x 6" x 10' – 0"	
PY08SD	4" x 6" x 8' – 0"	
PY10SD	4" x 6" x 10' – 0"	
PW08LD	3-5/8" x 4-5/8" x 8' – 0"	
PW10LD	3-5/8" x 4-5/8" x 10' – 0"	

Powertrusion

PSD082A1FRUS	4" x 6" x 8'-0"	To obtain experience.
PSD102A1FRUS	4" x 6" x 10'-0"	
PHD082A1FRUS	4" x 6" x 8'-0"	
PHD102A1FRUS	4" x 6" x 10'-0"	

Shakespeare

IDB096	4" x 6" x 8'-0"	To obtain experience.
XDB096	4" x 7-1/2" x 8'-0"	
HDB096	3-1/2" x 4-1/2" x 8'-0"	
IDB120	4" x 6" x 10'-0"	
XDB120	4" x 7-1/2" x 10'-0"	
TDB096	3-1/2" x 4-1/2" x 8'-0"	
HDB120	3-1/2" x 4-1/2" x 10'-0"	
TDB120	3-1/2" x 4-1/2" x 10'-0"	

Conditional List  
gj(2.1)  
April 2016

gj - Crossarm Assemblies

Braceless, fiberglass

<u>Manufacturer</u>	<u>Description</u>	<u>Conditions</u>
<u>DIS-TRAN Wood Products, LLC</u> CDL Series, CDM Series, CDH Series	8-foot and 10-foot	To Obtain experience.
<u>Creative Pultrusions, Inc.</u> SD409600K SD401200K SD609600K SD601200K SD800960K SD801200K	4"x6"x 8' 4"x6"x 10' 3-5/8"x4-5/8"x 8' 3-5/8"x4-5/8"x 10' 3-5/8"x4-5/8"x 8' 3-5/8"x4-5/8"x 10'	To obtain experience

Conditional List  
gj(3)  
May 21, 2020

gj - Crossarm Assemblies  
Composite

<u>Manufacturer</u>	<u>Description</u>	<u>Conditions</u>
<u>Hubbell Power Systems</u>		
CDA25G060D2000	4-5/8" X 3-5/8" X 5'-0"	To obtain experience
CDA25G096D2000	4-5/8" X 3-5/8" X 8'-0"	To obtain experience
CDA25G096D4000	4-5/8" X 3-5/8" X 8'-0"	To obtain experience
CDA25G120D2000	4-5/8" X 3-5/8" X 10'-0"	To obtain experience
CDA25G120D4000	4-5/8" X 3-5/8" X 10'-0"	To obtain experience
CDA25G144D2000	4-5/8" X 3-5/8" X 12'-0"	To obtain experience
CDA25G144D4000	4-5/8" X 3-5/8" X 12'-0"	To obtain experience

go – Fault Indicator, overhead

Manufacturer	Type
Smart Grid Solutions	FI-5A



gw-1  
March 2012

gw - Crossarm Assembly for H-Frame Construction

Applicable Specification: RUS Specification T-7, Revision dated November 1962  
Applicable Drawing: TH-11B Series (161 kV maximum)  
No braces (TH-11B)  
Two vee braces on outside (TH-11BVO)  
Two vee braces on inside (TH-11BVI)  
Four vee braces (TH-11BV4)

3-5/8" x 9-3/8" x 33' wood crossarm assembly complete with attaching hardware, fittings, bolts and 3-3/8" x 5-3/8" braces.

(Assemblies)	<u>Catalog Nos. or Drawing Nos.</u>			
	<u>TH-11B</u>	<u>TH-11BVO</u>	<u>TH-11BVI</u>	<u>TH-11BV4</u>
	<u>Items</u> gw	<u>Items</u> gw and vo	<u>Items</u> gw and vi	<u>Items</u> gw and vv
Brooks (1, 2)	6411	6411-1	6411-2	6411-3
DIS-TRAN Wood Products, LLC (2,3)	D3011	D3011VO	D3011VI	D3011V4
Hughes Brothers (1, 2)	C3316-B	C3316-B	C3316-B	C3316-B
Pennington (1, 2)	CCC11B72	CCC11B72-VO	CCC11B72-VI	CCC11B72-V4

- 1 - Fixed spacer fitting sizes as required  
2 - Adjustable spacers are available

gw-2  
March 2012

gw - Crossarm Assembly for H-Frame construction  
(Double Arm) 230 kV (Small Angle)

Applicable Specification: RUS Specification T-8, Drawing: TH-231B

Assembly complete with attaching hardware, fittings, bolts and braces.

Crossarm 3-5/8" x 9-3/8"

<u>Manufacturer</u>	<u>Catalog Number</u>
Brooks (1, 2)	64231
DIS-TRAN Wood Products, LLC (2,3)	D3231
Hughes Brothers (1, 2)	C-3338-B
Pennington (1, 2)	CCC231B82

Crossarm 5-1/8" x 7-1/2"

Brooks (1, 2)	64231L
Hughes Brothers (1, 2)	C-3338-BL
Pennington (1, 2)	CCC231BT

1 - Fixed spacer fitting sizes as required.

2 - Adjustable spacers are available.

gy-1  
March 2012

gy - Crossarm Assembly for H-Frame Construction  
(Double Arm)

Applicable Specification: RUS Specification T-7, Revision dated November 29, 1962

Applicable Drawing: TH-10 Series

No braces (TH-10)  
Two vee braces on outside (TH-10VO)  
Two vee braces on inside (TH-10VI)  
Four vee braces (TH-10V4)

3-5/8" x 9-3/8" x 32' wood crossarm assembly complete with attaching hardware, fittings, bolts and 3-3/8" x 5-3/8" braces.

Catalog Nos. or Drawing Nos.

	TH-10	TH-10VO	TH-10VI	TH-10V4
(Assemblies)	<u>Items</u> gy	<u>Items</u> gy and vo	<u>Items</u> gy and vi	<u>Items</u> gy and vv
Brooks (1, 2)	6410	6410-1	6410-2	6410-3
DIS-TRAN Wood Products, LLC (2,3)	D3010	D3010VO	D3010VI	D3010V4
Hughes Brothers (1, 2)	C-3316-A	C3316-A	C-3316-A	C-3316-A
Pennington (1, 2)	CCC1071	CCC1071-VO	CCC1071-VI	CCC1071-V4
Niedermeyer-Martin (1)	N-6710	N-6711	N-6712	N-6713

1 - Fixed spacer fitting sizes as required

2 - Adjustable spacers are available

gy - Crossarm Assembly for H-Frame Construction  
(Double Arm)

Applicable Specification: RUS Specification T-7, Revision dated November 29, 1962

Applicable Drawing: TH-10 Series

No braces (TH-10)  
Two vee braces on outside (TH-10VO)  
Two vee braces on inside (TH-10VI)  
Four vee braces (TH-10V4)

**3-5/8" x 9-3/8" x 32' wood crossarm assembly complete with attaching hardware, fittings, bolts and 3-3/8" x 5-3/8" braces.**

Catalog Nos. or Drawing Nos.

	TH-10	TH-10VO	TH-10VI	TH-10V4
	<u>Items</u> gy	<u>Items</u> gy and vo	<u>Items</u> gy and vi	<u>Items</u> gy and vv
(Assemblies):				
PUPI (1,2)	-	TX3020VO	-	TX3020V4
(conditions):		(To obtain experience)		(To obtain experience)
1 - Fixed spacer fitting sizes as required				
2 - Adjustable spacers are available				

**4" x 6" x 32' fiberglass crossarm assembly complete with attaching hardware, fittings, bolts and 3-5/8" x 4-5/8" fiberglass braces.**

Catalog Nos. or Drawing Nos.

	TH-10	TH-10VO	TH-10VI	TH-10V4
	<u>Items</u> gy	<u>Items</u> gy and vo	<u>Items</u> gy and vi	<u>Items</u> gy and vv
(Assemblies):				
PUPI (1,2)	TX4020	TX4020VO	TX4020VI	TX4020V4
(conditions):		(To obtain experience)		(To obtain experience)
1 - Fixed spacer fitting sizes as required				
2 - Adjustable spacers are available				

gy-2  
March 2012

gy - Crossarm Assembly for H-Frame Construction  
(Double Arm) 230 kV (Tangent)

Applicable Specification: RUS Specification T-8

Applicable Drawing: TH-230

Assembly complete with attaching hardware, fittings, bolts and braces.

Crossarm 3-5/8" x 9-3/8"

<u>Manufacturer</u>	<u>Catalog No.</u>
Brooks (1, 2)	64230
DIS-TRAN Wood Products, LLC (2,3)	D3230
Hughes Brothers (1, 2)	C-3338-A
Pennington (1, 2)	CCC23081
Niedermeyer-Martin (1)	N-6720

Crossarm 5-1/8" x 7-1/2"

Brooks (1, 2)	64230L
Hughes Brothers (1, 2)	C-3338-AL
Pennington (1, 2)	CCC230T

1 - Fixed spacer fitting sizes as required.

2 - Adjustable spacers are available.

gz-1  
July 2009

gz - Crossarm Assembly for Wishbone Construction "Z" Type  
(Single Arm)

Applicable Specification: RUS Specification T-5

Applicable Drawings: RUS Drawing TSZ-1

3-5/8' x 5-5/8" wood crossarm assembly complete with brace and attaching hardware, fittings, and bolts

The following manufacturers have shown compliance with the applicable specifications for this assembly:

<u>Manufacturer</u>	<u>Catalog Nos. or Drawing Nos.</u>
Brooks	64Z1
Hughes Brothers	C-3162-A and C-3162.10

gz - Crossarm Assembly for Wishbone Construction, "Z" Type  
(Double Arm)

Applicable Specification: RUS Specification T-5

Applicable Drawings: RUS Drawings TSZ-2

3-5/8" x 5-5/8" wood crossarm assembly complete with brace and attaching hardware, fittings and bolts

The following manufacturers have shown compliance with the applicable specifications for this assembly:

<u>Manufacturer</u>	<u>Catalog Nos. or Drawing Nos.</u>
Brooks (2)	64Z2
Hughes Brothers	C-3162-B and C-3162.10

(2) Adjustable spacers are available.

rp – Wildlife Guards

Manufacturer

---

Central Moloney, Inc.

70380330 Shedmount Guard - Standard Solid  
70380333 Shedmount Guard - FlamaGuard Solid  
70380486 Shedmount Guard - Standard Meshed  
70380489 Shedmount Guard - FlamaGuard Meshed  
70380340 Mini Shedmount Guard - Standard Solid  
70380341 Mini Shedmount Guard - FlamaGuard Solid  
70380499 Mini Shedmount Guard - Standard Meshed  
70380464 Mini Shedmount Guard - FlamaGuard Meshed  
70380463 Recloser Guard - Standard Solid  
70380459 Recloser Guard - FlamaGuard Solid  
70380483 Recloser Guard - Standard Meshed  
70380496 Recloser Guard - FlamaGuard Meshed  
70380343 Shedlock Guard  
70380349 Arrestor Bracket Cap (AB Cap)  
70380359 Arrestor Bracket Cap (AB Cap) FlamaGuard  
70380461 MegaGuard  
70380457 MegaGuard FlamaGuard  
70380473 Shedmount TI - Standard Solid  
70381422 Shedmount TI - Standard Meshed  
70380479 Shedmount TI - FlamaGuard Solid  
70381428 Shedmount TI - FlamaGuard Meshed  
70380436 Handwheel Guard  
70380438 Handwheel Guard - FlamaGuard

Hubbell Power Systems

“Greenjacket®” series

Chris Kaye (Critter Guard)

201 - "L" Bracket  
202 – Roller  
203 - Wheel

Hendrix Wire & Cable

BG-9 Bushing Cover

Hendrix (Eco Electrical Systems, Inc.)

EICG-1 Insulator/Conductor Cover  
EICG-1-WLPT Insulator/Conductor Cover  
EICG-1-20 Insulator/Conductor Cover  
EICG-1-32 Insulator/Conductor Cover



Manufacturer

---

\*Kaddas Enterprises Inc.

KE1039 Short Line Insulator Protector  
KE1045A Birdguard  
KE1049 Birdguard  
KE1053 Arrester cap  
KE1064 Bushing cover  
KE1066 Arrester cap  
KE1068 Cutout Switch Cover  
KE1077 Bushing cover  
KE1077 Rev A Transformer Bushing Cover  
KE1079 Rev B Load Break Cutout Cover  
KE1113 Dead-End Shoe Cover  
KE1165 Low Profile Birdguard  
KE1166-01 Line Protector Horizontal  
KE1182-03 Rev B Dead End Cover  
KE1198 Low Profile Line Protector, Clamp/Vise Top  
KE1203 Cutout Cover  
KE1501 Bushing Terminal Cover

Power Line Sentry, LLC

Line Covers (for C or J-neck insulators)  
CCSTT, single top tie conductor cover  
CCDTT, double top tie conductor cover  
CCDST, double side tie conductor cover

Preformed Line Products

RPC-0800 RAPTOR PROTECTOR™ (black)  
RPC-0801 RAPTOR PROTECTOR™ (grey)

NOTES: \*Specified by manufacturer as being flame-retardant

Manufacturer

---

Tripp (Eco Electrical Systems, Inc.)

- ECC-1 Cutout Cover
- ECC-2-27-150BIL-S&C-Version 10 Cutout Cover
- ECC-3-27-150BIL-S&C-Version 9 Cutout Cover
- ECC-4-27-125BIL-S&C-Kearney HX Cutout Cover
- ECC-5-ABB-LBU Cutout Cover

TE Connectivity - Energy

- BCAC Bushing Connection Animal Covers
- BCIC Bus Connection Insulating Covers
- BISG Bus Insulator Squirrel Guard
- MVLC Medium Voltage Line Cover (5-25kV)

Universal Thermography, Inc.

- TGB-50007 Bushing Cover
- TGB-65010 Bushing Cover
- TGB-82512 Bushing Cover

W. H. Salisbury & Co.

- 21116 Bushing Cover
- 21317 Tri-Port Bushing Cover
- BC512 Cone Bushing Cover
- 38-2SC Stinger Cover 3/8" IDx2'
- 38-12SC Stinger Cover 3/8" IDx12'
- 38-18SC Stinger Cover 3/8" IDx18'
- 38-50SC Stinger Cover 3/8" IDx50'
- 38-100SC Stinger Cover 3/8" IDx100'
- 58-12SC Stinger Cover 5/8" IDx12'
- 58-50SC Stinger Cover 5/8" IDx50'
- 58-100SC Stinger Cover 5/8" IDx100'
- 34-12SC Stinger Cover 3/4" IDx12'
- 34-25SC Stinger Cover 3/4" IDx25'

Utility Solutions, Inc.

- USVS Series\*

Manufacturer

---

Reliaguard®\*

C0-10005  
LA-13002  
TC-14001  
PI-12002  
RCK-12001K  
RK-11001K  
RK-11002K  
RK-11021 K  
DE-16001  
PI-12001  
PD- 04015F  
PD-0522F  
BC-15001  
BC-15002  
BB-20045-R  
BB-25045-R  
BB-40045-R  
BB-45045-R  
RW-30100  
RW-36036  
RW-36048  
EEL-02503750-50-Y  
EEL-03750500-50-Y  
EEL-05000750-50-Y  
EEL-07501000-50-Y  
EEL-10001250-50-Y  
EEL-12501500-50-Y  
EEL-15001750-25-Y  
EEL-17502000-25-Y

Midsun Group, Inc.

E/Flex Barrier\*  
E/Anti-Nesting Barrier\*  
E/Silicone Wildlife Covers\*\*

Conditional List  
rp-1.4  
April 21, 2025

rp – Wildlife Guards

Manufacturer

---

Celeco®

Wildlife Guards for Bushings and polymer Arresters (WLP) (up to 25kV)

Power Grid Pros

The C.O.P. Transformer Protector\*  
(Wildlife Guard for Bushings and polymer  
Arresters (WLP) (up to 35kV))

Hendrix Wire & Cable

HPP-24

Preformed Line Products

SDS-005

sb - Switch, disconnect (single-pole, hook operated station class)

NEMA standard switches for station or line structure use where single-pole switching is permissible

Manufacturer	Type	Voltage Ratings	System Voltages Line to Line
ABB	HPL	15 thru 69 kV	12.5 thru 69 kV
Bridges	EH EHL(L)	15 thru 69 kV 15 thru 34.5 kV	12.5 thru 69 kV 12.5 thru 34.5 kV
Cleaveland/Price	LCO-C	15 thru 69 kV	12.5 thru 69 kV
Eaton	D73P**(PL)	15.5, 25.8, 38kV	12.5 thru 35.5kV
G & W Electric	B-2M EV(PL)	15 thru 69 kV 15 thru 34.5 kV	12.5 thru 69 kV 12.5 thru 34.5 kV
Hubbell (Chance)	M3(PL)	15 thru 27 kV	12.5 thru 24.9 kV
Johnson	HPT	15 thru 69 kV	12.5 thru 69 kV
Joslyn (Hi-Voltage)	HU HI	15 thru 34.5 kV 15 thru 34.5 kV	12.5 thru 34.5 kV 12.5 thru 34.5 kV
Kearney/Eaton	M-72(PL) H-72	15 thru 69 kV 15 thru 34.5 kV	12.5 thru 69 kV 12.5 thru 34.5 kV
MEMCO	STV STU	15 thru 69 kV 15 thru 69 kV	12.5 thru 69 kV 12.5 thru 69 kV
Morgan	DHS(PL)	15 thru 69 kV	12.5 thru 69 kV
Royal Switchgear	BT BLT(PL)	15 thru 69 kV 15 and 23 kV	12.5 thru 69 kV 12.5 thru 24.9 kV
S & C*	LBD(PL) Alduti (L)	15 thru 34.5 kV 15 and 25 kV	12.5 thru 34.5 kV 12.5 thru 24.9 kV

(L) Means solid material load interrupters are available and accepted.

(LV) Means vacuum interrupters are available and accepted.

(PL) Means hooks for portable load interrupters are available for voltages 34.5 kV and below. Consult switch manufacturer concerning loop switching applications at higher voltages.

\*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

\*\*Insulators are available in Silicone Rubber, Porcelain, and Cycloaliphatic.

sb - Switch, disconnect (single-pole, hook-operated station class)

NEMA standard switches for station or line  
structure use where single-pole switching is permissible

Manufacturer	Type	Voltage Ratings	System Voltages Line-to-Line
Seeco	BT	34.5 thru 69 kV	34.5 thru 69 kV
Siemens-Allis	HA	15 thru 69 kV	12.5 thru 69 kV
	HS(PL)	15 and 25 kV	12.5 thru 24.9 kV
Southern States	PBO	15 thru 69 kV	12.5 thru 69 kV
	*PBN	15 thru 23 kV	12.5, 13.2, 24.9 kV
USCO	HH(PL)	15 thru 69 kV	12.5 thru 69 kV

(L) Means solid material load interrupters are available and accepted.

(LV) Means vacuum interrupters are available and accepted.

\* With steel base only.

(PL) Means hooks for portable load interrupters are available for voltages 34.5 kV and below. Consult switch manufacturer concerning loop switching applications at higher voltages.

sb – Switch, disconnect (single-pole, hook operated distribution class)\*

For distribution line use where power class insulation is not required and single-phase switching is permissible.

(Not suitable for substation use)

Manufacturer	Type	Voltage Rating	System Voltage Line-to-Line
Eaton	D73P*** (PL)	15.5, 25.8, 38kV	12.5 thru 35.5kV
G & W Electric Company	EV(PL)	15 kV	12.5 kV
Hubbell (Chance)	M3(PL)	15 and 27 kV	12.5 thru 24.9 kV
	M3C	15 and 27 kV	12.5 thru 24.9 kV
Kearney/Eaton	D-73(PL)	15 and 25 kV	12.5, 13.2, 24.9 kV
Morgan	DHS(PL)	15 and 23 kV	12.5, 13.2, 24.9 kV
Royal Switchgear	BLT (PL)	7.5 thru 34.5 kV	7.5 thru 34.5 kV
	BILT (PL)	7.5 thru 34.5 kV	7.5 thru 34.5 kV
	BISL(PL)	15 thru 25 kV	15 thru 25 kV
S & C**	LBD(PL)	15 and 25 kV	12.5, 13.2, 24.9 kV
Siemens-Allis	HD(PL)	15 and 25 kV	12.5 thru 24.9 kV
Siemens Energy, Inc.	LER (L)(PL)	15 and 25 kV	12.5 thru 24.9 kV
	SER (L)(PL)	15, 25, and 38 kV	12.5 thru 34.5 kV

NOTE: Switches on this page must be furnished with four bolts for double crossarm mounting.

(L) Means solid material load interrupters are available and accepted.

(PL) Means hooks for portable load interrupters are available.

(LV) Means vacuum interrupters are available and accepted.

\*Steel bases only.

\*\*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

\*\*\*Insulators are available in Silicone Rubber, Porcelain, and Cycloaliphatic.

sb - Switch, hookstick  
(line tension switches)

Manufacturer	Type	Voltage Ratings	System Voltages Line to Line	Conditions
Aluma-Form, Inc.	HDS-600A HDS-900A	15 kV thru 34.5 kV 15 kV thru 34.5 kV	12.5 kV thru 34.5 kV 12.5 kV thru 34.5 kV	To obtain experience. To obtain experience.
TE Connectivity - Energy	AMPACT (ILD-II)	15 kV	12.5/7.2 kV	To obtain experience.
Bridges	127	15 kV	12.5/7.2 kV	To obtain experience.
Hubbell (Chance)	ALTD06200R	15 kV	12.5/7.2 kV	To obtain experience.
Royal Switchgear	IL6B-H <i>(available with silicone polymer insulators as catalog number IL6NP)</i>	15 kV	12.5/7.2 kV	To obtain experience.

NOTE: All switches listed on this page have hooks for portable load interrupters.



sc - Regulators, Voltage  
12.5/7.2 kV  
13.2/7.62 kV

Applicable Specification: "RUS Specification for Substation Regulators," S-2

Type	Size	Description
<u>ABB</u>		
UTS, UTT	167-1000 kVA	(S) Three phase step type
<u>Eaton</u>		
VR-32 AB	19.1 - 833 kVA 50 amp.	(SL)Single phase - step type (L) Single-phase - step type (Auto-Booster)
<u>General Electric</u>		
VR-1	38.1 - 509 kVA	(SL) Single-phase - step type
MLT	500 - 1000 kVA	(S) Three-phase - step type
VML-32	500 - 833 kVA	(S) Single-phase - Vacuum step type
VMLT-32	1200 - 2800 kVA	(S) Three-phase - vacuum step type
<u>Siemens-Allis</u>		
JFR	38.1 - 667 kVA	(SL) Single-phase - step type

(L) Indicates line use  
(S) Indicates substation use

sc - Regulators, Voltage  
24.9/14.4 kV

Type	Size	Description
<u>Eaton</u>		
VR-32 AB.	72 - 833 kVA 50 amp	(SL) Single phase - step type (L) Single phase - step type (Auto-Booster)
<u>General Electric</u>		
VR-1	72 - 576 kVA	(SL) Single phase - step type
VML-32	500 - 833 kVA	(S) Single phase - vacuum step type
VMLT-32	1200 - 4666 kVA	(S) Three phase - vacuum step type
<u>Siemens-Allis</u>		
JFR	72 - 833	(SL) Single phase - step type

(L) Indicates line use  
(S) Indicates substation use

sc - Regulators, Voltage

<u>Manufacturer</u>	<u>Conditions</u>
<u>General Electric</u> Three-phase, step-type substation regulator Type TMLT-32 (13.2/7.62 kV)	To obtain experience.
<u>Howard Industries, Inc.</u> Single-phase, 32 step, line/substation, 50, 75, 100, 150, 219, 328, 438, 546, and 656 ampere, 7.62 kV, Type SVR-1 Single-phase, 32 step, line/substation, 50, 100, 150, 200, 231, 300, 400, 463, and 578 ampere, 14.4 kV, Type SVR-1	To obtain experience.
<u>Siemens-Allis</u> Three-phase, step-type substation regulator Type SFR (13.2/7.62 kV)	To obtain experience.

sd - Current Transformers  
Outdoor Type

Manufacturer	.6 kV	15 kV	25 kV	34.5 kV	69 kV
ABB	CSF/CMS CMF CLC/CLE	KOR-11 KON-11 KOT-11	ICT-150 KOR-I5 KOT-I5	ICT-200 KOR-20 -	ICT-350 - -
Arteche	IRH-1 IRH-5 IRH-7 IRH-10 IRH-12	CRE-17 CRB-17 ME-015 MK-15 MI-015 KM-15 KCB-17	CRF-24 CRE-24 ME-025 MK-25 MI-025 KM-25 KCB-24	CRF-36 CRF-36 (extended range) CRK-36 CE-034 ME-036 MK-36 KM-36	CRH-72 CRK-72 CE-069
G.E.C. Durham Industries (Astra)	AA&TA AB AD&AC	- - -	- - -	- - -	- - -
Electromagnetic Industries (Square D)		CO3-110	CO3-150	CO3-200	IK-350
General Electric	JCR-0 JCW-0 JAK-0 JAD-0	JKW-5 JCK-5 - -	JKW-6 JKW-150 KG-150 -	JKW-7 JKW-200 KG-200 -	JKW-350 KG-350 - -
Kuhlman Electric		BB-15-971 BB-15-972	BB-25-973 BB-25-974	BB-34-975 BB-34-976	COF-350 -
Arteche	-	CRE-17 CRB-17	CRF-24 CRE-24	CRF-36 CRF-36 (extended range)	- -
Ritz Instrument Transformers, Inc.	DCBW  DCCW  DCAB	GIFU 15-01; 0.3 B0.1-1.8  GIFU 15-01; 0.3 B0.1-0.5  GIFU 15-01; 0.3 B0.1-2.0	GIFU 25-01; 0.3 B0.1-0.9  GIFU 25-01; 0.3 B0.1-2.0  GIFU 25-01; 0.3 B0.1-2.0	GIFS 36-55; 0.3 B0.1-0.9  GIF 36-69; 0.3 B0.1-2.0  GIF 36-69; 0.3 B0.1-2.0	GIF 72.5- 68; 0.3 B0.1-2.0
Schlumberger	R6S R6SA R6M R6L	- - - -	- - - -	- - - -	- - - -

NOTE: The transformer types listed above are accepted in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

sd - Current Transformers  
Outdoor Type

Manufacturer	.6 kV	15 kV	25 kV	34.5 kV	69 kV
Instrument Transformer Equipment Corp (ITEC)		HRP-931	HRP-933	HRP-930	
		HRP-981	HRP-983	HRP-984	
		HRP-980	HRP-984		
				CTO-200	CTO-350
		CVTO-110	CVTO-150	CVTO-200	CVTO-350

NOTE: The transformer types listed above are accepted in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

Conditional List  
sd(1)  
February 2011

sd - Current Transformers  
Outdoor Type

Manufacturer	Conditions
<u>Electromagnetic Ind. (Square D)</u> Type UMCT, 0.6 kV Type UCT, 0.6 kV Type IK 4-350-69, 69 kV (cycloaliphatic resin bushings)	To obtain experience.

se - Voltage Transformers  
Outdoor Type

Manufacturer	.6 kV	15 kV	25 kV	34.5 kV	69 kV
ABB	PPM - -	VOG-II VOY-II VOZ-II	LPT-I50 VOG-I5 VOZ-I5	LPT-200 VOG-20 VOZ-20	LPT-350 - -
Arteche		VRL-17 URL-17 URJ-17 VRJ-17 ME-015 MK-15 MI-015 KM-15 KCB-17	URJ-24 VRJ-24 URN-24 VRN-24 ME-025 MK-25 MI-025 KM-25 KCB-24	VRS-36 URS-36 ME-036 MK-36 KM-36	URU-72 VRU-72
Electromagnetic Industries (Square D)		PO5-110	PO5-150	PO5-200	U3-350-69
General Electric	JVA-0 JVP-0 -	JVW-5 JVW-110 -	JVW-6 - JVT-150	JVW-7 - JVT-200	ET-350 JVT-350 -
Kuhlman Electric	-	PTT-110-977	-	-	POF-350
Ritz Instrument Transformers, Inc.	DVE-6  DVF-6	VZF 15-20; 2 Bushing 0.3WXYZ VZF 15-10; 2 Bushing 0.3WXY VEF 15-10; 1 Bushing 0.3WXY VEF 15-20; 1 Bushing 0.3WXYZ	VZF 25-10; 2 Bushing 0.3WXYZ VEF 25-10; 1 Bushing 0.3WXYZ	VZF 36-10; 2 Bushing 0.3WXY VEF 36-10; 1 Bushing 0.3WXY	VEF 72-03; 1 Bushing 0.3WXYZ
Schlumberger	T5R T6R T7R	- - -	- - -	- - -	- - -

NOTE: The transformer types listed above are acceptable in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.

se - Voltage Transformers  
Outdoor Type

Manufacturer	.6 kV	15 kV	25 kV	34.5 kV	69 kV
Instrument Transformer Equipment Corp (ITEC)			SVTO-150	SVTO-200	
		CVTO-110	CVTO-150	VTO-200 CVTO-200	VTO-350 CVTO-350 PST-350

NOTE: The transformer types listed above are acceptable in all standard ratios. Insulation class, voltages, ratios and other necessary information should be specified when ordering.



se - Voltage Transformers  
Outdoor Types

Manufacturer	Conditions
<u>G.E.C. Durham Industries (Astra)</u> Type DB, 0.6 kV Type DA, 0.6 kV Type DF, 0.6 kV	To obtain experience.
<u>Electromagnetic Industries (Square D)</u> Type U-450, 0.6 kV Type U-4-350-69, 69 kV (cycloaliphatic resin bushings)	To obtain experience.

sj - Switches, oil circuit recloser by-pass

Manufacturer	15 kV For use on 12.5/7.2 kV systems	27 kV For use on 24.9/14.4 kV systems	27 kV* For use on 34.5/19.9 kV systems	Current Rating Amperes
Eaton	D73P**-BE***	D73P**-BE***	D73P**-BE***	600, 900
Hubbell (Chance)	M3-R BP3 BPF	M3-R BP3 BPF	M3-R BP3 BPF	600 600, 900 600
Kearney/Eaton	D73RB	D73RB		600
Siemens Industry Inc.	B-2	B-2	B-2	600

\*Not For Use In Substations

\*\*Insulators are available in Silicone Rubber, Porcelain, and Cycloaliphatic.

\*\*\*Option BE means switch is equipped with bypass studs and REA 4 bolt back strap.

sk - Switch, regulator by-pass - disconnect  
For outdoor use

Manufacturer	15 kV for use on 12.5/7.2 kV Systems	27 kV for use on 24.9/14.4 kV Systems	Current Rating Amperes
Eaton	D73P3**	D73P3**	600, 900
Hubbell Power Systems, Inc.	BPR	BPR	600
Kearney/Eaton	HB-65	HB-65	600
S & C Electric*	XL	XL	600
Siemens-Allis	HR	HR	600
Siemens Industry Inc.	B-2	B-2	600
Southern States	BR	BR	400,600

NOTE: All switches should be furnished with NEMA standard insulators and with 110 kV BIL rating (15 kV systems) or 150 BIL ratings (25 kV systems) for station use.

\*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.  
\*\*Insulators are available in Silicone Rubber, Porcelain, and Cycloaliphatic.

Conditional List  
sk(1)  
July 2009

sk - Switch, regulator by-pass - disconnect  
For outdoor use

Manufacturer	Conditions
<u>Eaton</u> Type B, 15 kV, 400 amperes, 110 kV BIL for station use, 95 kV BIL for line use.	To obtain experience.

NOTE: All switches should be furnished with NEMA standard insulators and with 110 kV BIL rating for station use.

sl - Switch, Combination Power Fuse and Disconnect

(Used with an additional disconnect switch to by-pass  
oil circuit reclosers at substations)

<u>Manufacturer</u>	<u>15 kV for use on 12.5/7.2 kV systems</u>	<u>27 kV for use on 24.9/14.4 kV systems</u>
Joslyn (Hi-Voltage)	RFH	-
Kearney/Eaton	MHX	MHX
S & C Electric*	SMD/LBD XS/LBD	SMD/LBD -
Southern States	SF	-

NOTE: All switches and cutouts should be furnished with NEMA standard insulators.

\*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

sr - Steel Conductor for Substation Grounding, Copper-Clad or Galvanized

(See av-2 for copper grounding conductor)

Manufacturer	Type	Sizes
<u>AFL Copperclad</u>	copper-clad steel (dead soft annealed)	7 No. 6 AWG 7 No. 5 AWG 7 No. 4 AWG 19 No. 9 AWG 19 No. 8 AWG 19 No. 6 AWG 19 No. 5 AWG
<u>Copperweld Bimetallics, LLC*</u>	Dead Soft Annealed (DSA) Copperweld Conductors	7 no 8 AWG 2/0 (19x0860" & 7x1379") 7 no 7 AWG 7 no 6 AWG 7 no 5 AWG 7 no 4 AWG 4/0 (19x1055") 19 no 9 AWG 19 no 8 AWG 19 no 7 AWG 19 no 6 AWG 19 no 5 AWG

NOTES:

\* Theft deterrent versions, both poly-jacketed and camouflaged are acceptable.

1. Minimum 40% conductivity
2. 7-strand conductors can be supplied in 19-strand configuration and vice-versa.
3. Conductors chosen must be able to carry the required short duration fault current and must be selected based on IEEE Standard 80.
4. When used in soil with resistivity of 25 ohm-meters (2500 ohms per cubic centimeter) or less cathodic protection must be incorporated into the grounding design.

sr - Steel Conductor for Substation Grounding, Copper-Clad or Galvanized

(See av-2 for copper grounding conductor)

Manufacturer	Conditions
<u>Indiana Steel &amp; Wire</u> Steel Strand, BB Grade, Class C galvanized 5/8" (19 wire) 1/2" (7 wire) 9/16" (7 wire) 7/16" (7 wire)	1. To obtain experience. 2. When used in soil with resistivity of 25 ohm-meters (2500 ohms per centimeter cube) or less, cathodic protection must be incorporated into the grounding design.

NOTES:

1. Minimum 40% conductivity
2. 7-strand conductors can be supplied in 19-strand configuration and vice-versa.
3. Conductors chosen must be able to carry the required short duration fault current and must be selected based on IEEE Standard 80.

sr - Conductor for Substation Grounding, alternative conductor

Manufacturer	Conditions
ConduGround	To obtain experience.
CG-7/16"	
CG-1"	
CG-1-1/2"	
CThor55Lb	
GAP55Lb	
GAP25Lb	



vx - Cross Brace assembly, 3-3/8" x 5-3/8"  
with hardware and fittings (Dwg. TM-110, RUS Specification T-7)

<u>Manufacturer</u>	<u>Catalog No.</u>
<u>Brooks</u>	
Item 1-vx	6685-1
Item 2-vx	6685-2
<u>DIS-TRAN Wood Products, LLC</u>	
Item 1-vx	D2110B
<u>Hughes Brothers</u>	
Item 1-vx	1042-1
Item 2-vx	1042-2
<u>Niedermeyer-Martin</u>	
Item 1-vx	N-6714-1
Item 2-vx	N-6714-2
<u>Pennington</u>	
Item 1-vx	CCC-67-1
Item 2-vx	CCC-67-2

Cross Brace assembly, 3-5/8" x 7-1/2" Min.  
with hardware and fittings (Dwg. TM-110, RUS Specification T-8)

<u>Manufacturer</u>	<u>Catalog No.</u>
Brooks	6695
DIS-TRAN Wood Products, LLC	D2110C
Hughes Brothers	2061A
Niedermeyer-Martin	N6721
Pennington	CCC69

Conditional  
vx(1)  
August 2014

vx - Cross Brace assembly, 3-3/8" x 5-3/8"  
with hardware and fittings (Dwg. TM-110, RUS Specification T-7)

Manufacturer	Catalog No.	Conditions
<u>PUPI</u>		
Item 1-vx	XBR3020-1	To obtain experience.
Item 2-vx	XBR3020-2	

Cross Brace assembly, 3-5/8" x 7-1/2" Min.  
with hardware and fittings (Dwg. TM-110, RUS Specification T-8)

Manufacturer	Catalog No.	Conditions
--------------	-------------	------------

## PART II

### Underground Distribution Equipment

U ae - Surge Arresters, Distribution  
for Underground System Pole Risers  
(Lightning Arresters)

SiC Type					
Manufacturer	Type	Accepted Ratings - kV	Duty	Manufacturer's Classification	Housing
ABB	GLV	9, 10	Normal	Distribution	
	LVBB	18	Normal	Distribution	
General Electric	Alugard	9, 10, 18	Heavy	Distribution	

NOTE: The arresters listed on this page may be used singly or in parallel, but must be applied in accordance with paragraph VI.A., in RUS Bulletin 61-3, "Underground Rural Distribution." Other arresters listed on pages ae-1 and ae-2 may be used for underground systems when applied in accordance with this bulletin.

U ae - Arresters, Surge  
 (Shielded for Underground System Pad-Mounted Equipment)

CONDITION OF ACCEPTANCE: To Obtain Experience

ELBOW ARRESTERS

Manufacturer	Type	Ratings, kV	Type	Interface
Eaton	M.O.V.E.	9/10	MOV	15 kV
	M.O.V.E.	18	MOV	25 kV
	VariGAP	9/10	(1)	15 kV
	VariGAP	18	(1)	25 kV
	Posi-Break M.O.V.E.	3-21	MOV	25 kV
	VariGAP Posi-Break	9-15	MOV	25 kV
	M.O.V.E.			
Elastimold ESNA	167 ESA-10	10	MOV	15 kV
	273 ESA-18	18	MOV	25 kV
Hubbell	215ELA-10	10	MOV	15kV
	225ELA-18	18	MOV	25kV
Joslyn	ZE	10	MOV	15 kV
		18	MOV	25 kV

(1) MOV Type (Internally Gapped)

U ae - Arresters, Surge

(Shielded for Underground System Pad-Mounted Equipment)

CONDITION OF ACCEPTANCE: To Obtain Experience

PARKING STAND ARRESTERS

Manufacturer	Type	Ratings, kV	Type	Interface
Eaton	MOV PSA	9/10	MOV	15 kV
	MOV PSA	18	MOV	25 kV
	MOV VariGAP PSA	9/10	(1)	15 kV
	MOV VariGAP PSA	18	(1)	25 kV
Elastimold ESNA	167 PSA-10	10	MOV	15 kV
	273 PSA-18	18	MOV	25 kV
Hubbell	215PLA-10	10	MOV	15kV
	225PLA-18	18	MOV	25kV

(1) MOV Type (Internally Gapped)

U ae - Arresters, Surge

(Shielded for Underground System Pad-Mounted Equipment)

CONDITION OF ACCEPTANCE: To Obtain Experience

BUSHING ARRESTERS

<u>Manufacturer</u>	<u>Type</u>	<u>Ratings, kV</u>	<u>Type</u>	<u>Interface</u>
Elastimold ESNA	167 BSA-10	10	MOV	15 kV
	273 BSA-18	18	MOV	25 kV

(1) MOV Type (Internally Gapped)

U ae - Arresters, Surge  
(For Underground System Pole Risers)

CONDITION OF ACCEPTANCE: To Obtain Experience

Manufacturer	Type	MOV Type		Manufacturer' Classification	Housing
		Accepted Ratings - kV	Duty		
ABB	HMX	9,10,18	Heavy	Intermediate *	Polymer
	RMX	9,10,18			
	XPR	9,10,18,27	Heavy		
Eaton	CPS AZR VariSTAR	9,10,18,27	Heavy	Distribution	Porcelain
	URS UltraSIL VariSTAR	9,10,18,27	Heavy	Distribution	Polymer
General Electric	Tranquell ** U.D. II	9,10,18,27	Normal	Distribution	Porcelain
	Tranquell	9,10,18,27	Normal	Intermediate	Porcelain
Hubbell (Ohio Brass)	DynaVar-PVR	9,10,18,27	Heavy	Riser Pole	Polymer
Joslyn	ZRP	9,10,18,27	Heavy	Distribution	Polymer

\*Has intermediate class arrester characteristics but does not have intermediate class venting capability.

\*\*A non-fragmenting U.D. II Arrester is available for 9 & 10 kV designs at higher cost when specified.



U ae - Arresters, Surge  
(For Underground System Pole Risers)

CONDITION OF ACCEPTANCE: To Obtain Experience

MOV Type (Internally Gapped)

<u>Manufacturer</u>	<u>Type</u>	<u>Accepted Ratings - kV</u>	<u>Duty</u>	<u>Manufacturer's Classification</u>	<u>Housing</u>
Eaton	URT Evolution	9,10,18,27	Heavy	Distribution	Polymer

U an - Transformers, Distribution  
Pad-Mounted, Dead-Front

(For underground application)

Manufacturer	Single-Phase 5 - 167 kVA	Three-Phase 30 - 2500 kVA
ABB	"Mini-Pak U-5"	Type MTR (75-1500 kVA) "Plazapad-U5" (2000-2500 kVA)
Central Moloney	"REA-LP"	"Three Phase Pad Mount REA"
Eaton*	"REA Shrubline"	"REA Terra-Tran"
*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.		
ERMCO, INC.	"Low-Profile"	"E-PAD"
General Electric	-	"Compad IV - REA"
H. K. Porter (Delta-Star)	"Low Profile U 5-R"	"Porter U5-R3"
Magnetron S.A.S.	Pad Mount 5-167 kVA	-
Howard	"Hi Pad REA"	"Hi Pad 3 REA"
Kuhlman	"Lo-Pak ELR"	"K-PAK-3 REA"
CG Power Systems USA, Inc.	"Turf-Hugger-R"	"Turf-Hugger-R"
United (KAEC)	"Pad-Mount" 15-100 kVA (1) "Pad-Mount" 25 & 50 kVA (2)	-
VanTran	"Mini-Pad U5" (1)	"VanTran III-U5"

NOTES

All acceptances are based on RUS Specification U-5, "Specifications for Pad-Mounted Transformers (Single and Three Phase)."

All single-phase and three-phase transformers above accepted for the following voltages (kV) unless otherwise noted: 12.47/7.2; 13.2/7.6; 24.9/14.4; and 24.9/14.4 x 12.47/7.2 dual voltage

(1) Accepted for 12.47/7.2 kV and 13.2/ 7.62 kV only.

(2) Accepted for 24.9/14.4 kV only.

The enclosures for these transformers have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

Not all kVA sizes in above kVA ranges are available from all listed manufacturers.

Some of the above single-phase and three-phase transformers are available with internal under oil surge arresters. The availability and type of arresters vary with each manufacturer. The following types of under-oil arresters are acceptable: "UMX", "Tranquell" and "AZU."

U an - Transformers, Distribution  
Pad-Mounted, Dead-Front

(For unit residential underground application)  
(Single-phase, 7.2 kV and 7.6 kV)

Manufacturer	5 - 25 kVA Only
ABB	"Micro-Pak U-5"
Central Moloney	"REA-Mini-LP"
Eaton*	"Ranch Runner"
*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.	
ERMCO, INC.	"REA-MicroTrim"
Howard	"Spacesaver Pad"

NOTES

All acceptances are based on RUS Specification U-5, "Specifications for Pad-Mounted Transformers (Single and Three Phase)."

The enclosures for these transformers have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

U an - Transformers, Distribution  
 Pad-Mounted, Dead-Front

(For underground application)

Conditions for Acceptance: To Obtain Experience

Manufacturer	Type
<u>ABB</u>	"Mini-Pak U-5" - Single-phase with composite fiberglass enclosure "Mini Three Phase" (MTP) 30 - 225 kVA
<u>Cam Tran</u>	"Cam Tran" - Three-phase, 12.47/7.2 and 13.2/7.6 kV; 30-2500 kVA
<u>Carte</u>	Three-phase, 24.9/14.4 kV, 30 - 2,500 kVA
<u>Eaton*</u>	Single-phase, self-protected with "Magnex" interrupter Single-phase, self-protected with "AZU" MOV heavy-duty, under-oil arrester <p>*Optional Envirotemp™ FR3™ fluid-filled designs are available, including optimized Eaton PEAK™ transformer designs which allow reduced transformer size and/or overload capacity while providing for fire safety, environmental safety, and extended insulation life. This natural ester soybean oil based dielectric fluid is an extremely biodegradable, renewable resource that is classified as a less flammable fluid, and is non-toxic. Envirotemp™ and FR3™ are licensed trademarks of Cargill, Incorporated. PEAK™ is a trademark of Eaton.</p>
<u>General Electric</u>	"Compad -IV-REA" - Three-phase, 75-750 kVA All above with amorphous metal cores
<u>GE-Prolec</u>	Mini Padmount, Single-phase, 10-167 kVA Three-phase, 12.47/7.2 kV, 45-2,500 kVA Three-phase, 24.9/14.4 kV, 45-2,500 kVA
<u>Square D</u>	Class 7230 REA - Three-phase, 75-2500 kVA 12.47/7.2 kV and 13.2/7.62 kV
<u>Van Tran</u>	"Mini-Pad U5" - 5-167 kVA, 24.9/14.4 kV
<u>Power Partners</u>	Single-phase 5-167 kVA

NOTES

All acceptances are based on RUS Specification U-5, "Specifications for Pad-Mounted Transformers (Single and Three Phase)."

All single-phase and three-phase transformers above conditionally accepted for the following voltages (kV) unless otherwise noted: 12.47/7.2; 13.2/7.6; 24.9/14.4; and 24.9/14.4 x 12.47/7.2 dual voltage

The enclosures for these transformers have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

Not all kVA sizes are available from all listed manufacturers.

U ax - Cutout and Arrester, Combination  
for Underground System Pole Risers

Nominal System Voltage	For 12.5/7.2 kV		For 13.2/7.6 kV	For 24.9/14.4 kV
Cutout Maximum Voltage Rating	7.8 kV	15 kV	15 kV	27 kV
Application	1ø Risers	3ø Risers	1ø and 3ø Risers	1ø and 3ø Risers
Cutout Current Rating	100 amps	100 amps	100 amps	100 amps
Manufacturer	Catalog Numbers			
ABB	7.8LBU-II/10 LV	15LBU-II/10 LV	15LBU-II/10 LV	24.9LBU-II/18 LV
Eaton	AFS300B Series	AFS300C Series	AFS300C Series	AFS300D Series
General Electric	9F80	9F80	9F80	9F80
Hubbell (Chance)	C7 Series	C7 Series	C7 Series	C7 Series
Southern States	CA Series	CA Series	CA Series	CA Series

NOTE: The units listed on this page may be used with single arresters or arresters in parallel, but must be applied in accordance with paragraph VI.A. in RUS Bulletin 61-3, "Underground Rural Distribution." Other arresters listed on pages ae-1 and ae-2 may be used for underground systems when applied in accordance with this bulletin.

Cutouts used on underground riser poles should be loadbreak type or have hooks for portable load interrupters.

Either normal duty or heavy duty distribution class arresters listed on page ae-1 are acceptable for use with these combination units.

U ax - Cutout and Arrester

Combination for Underground System Pole Risers

Metal Oxide Type Arresters

Nominal System Voltage	For 12.5Y/7.2 kV		For 13.2Y/7.6 kV	For 24.9Y/14.4 kV	Conditions
Cutout Maximum Voltage Rating	7.8 kV	15 kV	15 kV	27 kV	
Application	1ø Risers	3ø Risers	1ø and 3ø Risers	1ø and 3ø Risers	
Cutout Current Rating	100 amps	100 amps	100 amps	100 amps	
<u>Manufacturer</u>	<u>Catalog Numbers</u>				
Eaton	L4A1P1A00-ECO(9kV) L4A1P1A00-EDOA(10kV)	L9C1P1A00-ECO(9kV) L9C1P1A00-EDOA(10kV)	L9C1P1A00-ECO(9kV) L9C1P1A00-EDOA(10kV)	L9D1P1A00-EGOA -	To obtain experience To obtain experience.

Note 1: Other arresters listed on pages ae-1 and ae-2 may be used for underground systems when applied in accordance with RUS Bulletin 61-3, "Underground Rural Distribution."

Note 2: Cutouts used on underground riser poles should be loadbreak type or have hooks for portable load interrupters.

U be - Reclosers, pad-mounted

Manufacturer	Conditions
<u>Eaton</u> Single phase, vacuum interrupter, Type PV4H Maximum voltage 14.4 kV for 12.5 and 13.2/7.62 kV	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.

U be - Reclosers, vacuum interruption with solid dielectric

Manufacturer	Conditions
<u>G &amp; W Electric Company</u> Three phase, electronic, VIPER Series, vacuum interruption, solid dielectric, 800 amps maximum continuous, 12,500 amps RMS symmetrical interruption, 15.5 kV maximum for 12.5/7.2 kV, 27 kV maximum for 24.9/14/4 kV.	To obtain experience.

NOTES:

1. Series trip reclosers with ratings greater than 100 amp for 12.5/7.2 kV application, greater than 200 amp for 24.9/14.4 kV application, and 280 amp for 34.5/19.9 kV application are acceptable only with ground trip device. Shunt trip reclosers without ground trip devices may not be used with trip settings higher than 200 amp for 12.5/7.2 kV application, greater than 400 amp for 24.9/14.4 kV application, and 560 amp for 34.5/19.9 kV application.
2. Reclosers are not acceptable with load current, bushing CT battery chargers.



U cg - Switch, air, three-pole, group-operated  
for pole-mounted cable risers  
(Factory Preassembled)

Manufacturer	Mounting	Vertical Break Type    kV	Side Break Type    kV
ABB	Vertical	LB3-VR(L)15	-
Hubbell (Chance)	Vertical	-	D7(L)15-27
	Horizontal	-	D7(L)15-27
Kearney/Eaton	Horizontal	SB_R(L)15-35	-
S & C*	Vertical	-	Alduti(L)15-25
	Horizontal	-	Alduti(L)15-25

(L) Means gas or solid material full-load interrupters are accepted and available.

\*Available with porcelain insulators. Available with "Cypoxy" cycloaliphatic epoxy insulators through 34.5 kV on request.

NOTE: Switches with factory-assembled crossarm type bases must have nonconducting crossarm type bases, nonconducting braces, and insulated interphase and control rods.

U cg - Switch, Air, Three-Pole, Group Operated

<u>Manufacturer</u>	<u>Conditions</u>
<u>Hubbell (Chance)</u> Type AR side-break, horizontal and vertical mounting, with non-conducting crossarm type base and insulated interphase and control rods, 15, 25 , and 34.5 kV (grounded wye)	To obtain experience.
<u>S &amp; C*</u> Omni-Rupter (L), side break horizontal and vertical mounting with non-conducting crossarm type base and insulated interphase and control rods, 15 kV and 25 kV	To obtain experience.

(L) Means full-load interrupter accepted and available.

\*Available with porcelain insulators. Available with Cypoxy insulators through 34.5 kV on request.

U fw - Secondary Tap Connector

Manufacturer	Type or Catalog No.
TE Connectivity - Energy	Compression Connectors CRSM-CT-34/10-150 CRSM-CT-53/13-200 CRSM-CT-84/20-250 Standard Split Bolt CRSM-CT-53/13-200

U fz – Transformer Connector Block, Insulated  
Multiple Cable Connectors

Watertight – For use in all locations

Manufacturer	Connection Type	Catalog Number
Blackburn	Lug	SCU, with lugs and sleeves
Burndy	Lug	Stud Mole with sealing sleeve
Polaris	Set Screw	IPLWB, SLWB, SSWB, SLOWB
Utilco	Set Screw	PTF-SS, Watertight insulated transformer connector block

Non-Watertight - For use in above grade locations only

AFL	Lug	Interchange 1 ABBD Series (Disconnectable) Use with A9 insulating boots
Alcon	Set Screw	VBTT Series with double sealing sleeve
Blackburn	Set Screw	TSB-J58C (Permanent)
	Set Screw	TSB-D58C (Disconnectable)
Burndy	Set Screw	K-D Series (Disconnectable)
		K-DF Series (Permanent)
Durham Company	Set Screw	UB Series
	Set Screw	9112212 250 Splice-n-Tap
	Lug	UT Series
Connector Mfg. Co.	Set Screw	Uni-Joint Bar Connectors, (Series RLS, NSM-C, NDS-C, NSC, ZS-C, ZSU-C, RLUS) (Permanent)
	Set Screw	Uni-Joint Bar Connectors, (Series RLSS, NSSM-C, NSSC, ZQC, ZQU-C, RLUS) (Disconnectable)
ESP	Lug	Types SUR and RDSR(Removable) (With Types LA and AL-lugs and Sleeve kits)
	Set Screw	Type UPSO-I (Permanent)
		Type UPM-I (Disconnectable)
Homac	Lug	DF Series
	Lug	FTU 125 Series(Disconnectable) with flood seal sleeve kit
	Set Screw	ABD, ABK, ABS, ABW, CLRTR, CSW, CSS, LRT, RAU, EZC, Z series; ZBK with SB covers; ZVW with boot
Hubbell (Fargo)	Bolted	GUC Series
	Set Screw	GUS-460S Series
MacLean (Reliable)	Set Screw	15912-REA (Disconnectable)
Penn Union	Lug	Type DBAT (Permanent)
	Lug	Type DBAT-LH (Disconnectable)
		Use with Series DBTB, DBTBF and DBTH lug and Sleeves kits
Polaris	Set Screw	PLTZ-CC, PSMTLCC, PSMTLSC
	Set Screw	PTLZ-CC, PSMTLCC, PSMTLSC
	Set Screw	IPCTLZ, IPCTLEZ, PSMTLECC
	Set Screw	PSMTLESC, PTLZSC, PTLZCC, IPPT
Preformed	Set Screw	SC-C series (Permanent)
	Set Screw	CSC-Q-C Series, SC-Q-C series (Disconnectable)
Utilco	Set Screw	PTF-IN (Permanent)
	Set Screw	PTF-CJNU, PSS Series (Disconnectable)
Vector Connectors Corp.	Set Screw	TQL Series (Disconnectable) (with insulating boot)

Note: Additional insulation may be required with some of the above-listed secondary terminal blocks due to the irregularity of mating surfaces between various secondary studs being supplied by the transformer manufacturers.

U gc - Shield, cable riser

Manufacturer	Dia. (Inches)	Length (Feet)
<u>Galvanized Steel</u>		
Almat Metal Limited	2 1/4	8
Electrical Materials	2 - 3 - 4 - 5*	5*
Hubbell (Chance)	2 - 3 - 3 1/2	5 - 9
Joslyn	2 - 3 - 3 1/2*	5 - 8*
Midland-Ross (Kindorf Snapduct)	2 1/2 - 3 1/2 - 5 (14 ga. galv. steel)	2 1/2 - 5 - 10
<u>Plastic and Fiberglass</u>		
Applied Extrusion Technologies (plastic) (Power Mold, I, II, III)	2 - 3 - 4 - 5 - 6*	5 - 8 - 10*
Carlton	2 - 3 - 4 - 5 - 6*	10*
Charles Industries	2 - 3 - 4 - 5**	5 and 10**
Custom Plastics	2 - 3 - 4 - 5*	5 - 10*
Electrical Materials (plastic)	1 - 2 - 3 - 4 - 5 - 6*	5 - 8 - 10*
Joslyn (plastic)	2*	10*

(Order by size and length)

\*All sizes available with back plate.

Full Round\*\*

Smith Fiberglass Products (standard wall)	2 - 3 - 4 - 5	30
--	---------------	----

\*\*Full round riser shield is to be mounted directly to the surface of the pole with no standoffs.

U gk - Terminations, Indoor

(When ordering specify conductor size, type, whether  
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Catalog No.</u>
---------------------	--------------------

PREMOLEDDED

<u>Eaton</u>	Fasterm Stress Cone (15 & 25 kV)
<u>Elastimold (ESNA)</u>	Style 35-MS (15, 25 & 35 kV)
<u>Hubbell (Chardon)</u>	Termi-Matic, Type A or G (15, 25 & 35 kV)

HEAT SHRINK

<u>DSG-Canusa</u>	CT Series (15kV, 25kV, 35kV)
<u>G&amp;W</u>	ESTS15_PLA (15 kV) ESTS25_PLA (25 kV)
<u>Hellermann</u>	MVTS15_PLA (15 kV) MVTS25_PLA (25 kV)
<u>TE Connectivity - Energy</u>	HVT (15, 25 & 35 kV)

COLD SHRINK

<u>3M</u>	QT III Series (15 kV) Quick Term II Series (25 & 35 kV)
<u>DSG Canusa</u>	TITAN-Z Series (15, 25 kV) TITAN Series (35 kV)
<u>Joslyn</u>	JIPT Series (15, 25 kV) JPT Series (25 kV)
<u>TE Connectivity - Energy</u>	TFT Series (15, 25, 35 kV)

INSULATED WRAP

<u>Plymouth/Bishop</u>	Stress-Wrap (15, 25 & 35 kV)
------------------------	------------------------------

U gk - Terminations, outdoor  
(with mounting hardware) \*

PREMOLEDDED

(When ordering, specify conductor size, type, whether copper or aluminum, insulation diameter, and type of mounting desired)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Eaton</u>	Fasterm Series (15 & 25 kV)
<u>Elastimold (ESNA)</u>	Style 16-THG (15 and 25 kV) (for bare concentric neutral cable) Style 35-MT (35 kV) (for bare concentric neutral cable) Style PCT-1 (15 kV) (for jacketed cable) Style PCT-2 (25 kV) (for jacketed cable)
<u>Hubbell (Chardon)</u>	Termi-Matic, Type G (15, 25 and 35 kV)

\*Mounting Hardware is used to attach termination to mounting bracket (U hd or U hj).

NOTE: Some of the above terminators may require ordering the mounting hardware separately.

U gk - Terminations, outdoor  
(with mounting hardware) \*

HEAT SHRINK

(When ordering, specify conductor size, type, whether copper or aluminum, insulation diameter, and type of mounting desired)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>DSG-Canusa</u>	CT Series (15kV, 25kV, 35kV)
<u>G&amp;W</u>	ESTS15_PLO (15 kV) ESTS25_PLO (25 kV)
<u>Hellermann</u>	MVTS15_PLO (15 kV) MVTS25_PLO (25 kV)
<u>Plymouth/Bishop</u>	SWO Kit (15, 25 and 35 kV)
<u>TE Connectivity - Energy</u>	HVT (15, 25 and 35 kV)

\*Mounting Hardware is used to attach termination to mounting bracket (U hd or U hj).

NOTE: Some of the above terminators may require ordering the mounting hardware separately.



U gk - Terminations, outdoor  
(with mounting hardware) \*

COLD SHRINK

(When ordering, specify conductor size, type, whether copper or aluminum, insulation diameter, and type of mounting desired)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>DSG-Canusa</u>	TITAN-Z Series (15, 25 kV) TITAN Series (35 kV)
<u>Joslyn</u>	JPT Series (15, 25, 35 kV)
<u>TE Connectivity - Energy</u>	TFT Series (15, 25, 35 kV)
<u>3M</u>	QT III Series (15, 25, & 35 kV)
<u>Prysmian</u>	PCT Series (15, 25, 35 kV)

\*Mounting Hardware is used to attach termination to mounting bracket (U hd or U hj).

NOTE: Some of the above terminators may require ordering the mounting hardware separately.

U gk-2.3  
April 27, 2021

U gk - Terminations, outdoor  
(with mounting hardware) \*

PORCELAIN

(When ordering, specify conductor size, type, whether copper or aluminum, insulation diameter, and type of mounting desired)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>G &amp; W</u>	"Eliminator" 15 kV, E 25 kV, E 35 kV, E
<u>Joslyn</u>	"Easy-On II" (15, 25 and 35 kV)

\*Mounting Hardware is used to attach termination to mounting bracket (U hd or U hj).  
NOTE: Some of the above terminators may require ordering the mounting hardware separately.

U gn - Enclosures, equipment

Applicable Specifications: "RUS Specifications for Equipment Enclosures," U-4

<u>Manufacturer</u>	<u>Catalog No.</u>
<u>Durham</u>	AT-42 Series (dead-front) AT-54 Series (dead-front)
<u>Elliott</u>	EPM-PTS (dead-front)
<u>Hoffman Enclosures, Inc.</u>	UJ Series
<u>Hubbell</u>	P134, P234, P358, P378
<u>American Padmount Systems</u>	APS Series (dead-front)
<u>Maysteel</u>	EL100 (dead-front)
<u>Nordic</u>	ND-28 and ND-33

NOTE:

1. The above enclosures are available with various multipoint terminations. The owner should specify termination points to be provided.
2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

U gn - Enclosures, Equipment

Sectionalizing Enclosures

<u>Manufacturer</u>	<u>Catalog No.</u>
<u>Aluma-Form</u>	ENC Series
<u>Brooks Utility Products Group</u>	<u>Single Phase</u> 750-7437-001, 750-7437-002, 750-7437-003, 750-7437-004 <u>Three Phase</u> 750-7438-001, 750-7438-002, 750-7438-003, 750-7438-004, 750-7438-005, 750-7438-006, 750-7438-007
<u>Eaton</u>	SecTER Series I and II (Single-Phase and Three-Phase)*
<u>Durham</u>	AM Series
<u>Highline Products</u>	FSC-29 Single Phase FSC-32 Single Phase FSC-33 Single Phase FSC-55 Three Phase FSC-62 Three Phase FSC-65 Three Phase FSC-69 Three Phase FSC-71 Three Phase FSC-79 Three Phase FSC-85 Three Phase
<u>Maysteel</u>	CW200 Series CW300 Series
<u>Nordic</u>	ND Series
<u>Power Design Inc.</u>	Type CJP series, single-phase and three-phase, 15 and 25 kV
<u>Rough Rider Industries</u>	Series RUF93
<u>Shallbetter</u>	SPMS Series (dead-front)

NOTES:

1. The above enclosures are available with various multipoint terminations. The owner should specify termination points to be provided.
2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.

\* Also available as a Cleer SecTER cabinet with the Cleer, 600 amp load break connector assemblies installed for both 15 kV and 25 kV systems.

U go - Fault Indicator  
(For Construction Unit UM 6-4)

Manufacturer	Type
Eaton	S.T.A.R. CR, DR, ER, MR, TPR
Edison Control Corporation	Series EC100 (single phase) Series EC300 (three phase) (Available with mounting kit KT5002)
E. O. Schweitzer	AutoRANGER AR-OH
Fisher Pierce	Series 1514 (current reset, single-phase) Series 1515 (current reset, three-phase) Series 1541 (time reset, single-phase) Series 1543 (time reset, three-phase) Series 1547 (adaptive trip)
Horstmann GmbH	FCI-LT Series <u>Time Reset</u> 29-6214 29-6215 <u>Current Reset</u> 29-6114 29-6115  Navigator LoadTracker (LT) 41-2001
Smart Grid Solutions	FI-3C

Note: Fault indicators that require the drilling or cutting to the enclosure for mounting are not acceptable.

U gp - Connector Blocks and Splices, Secondary

Watertight - For Use In All Locations

Manufacturer	Connection Type	Catalog Number
Alcon	Set Screw	VPB Series
Blackburn	Lug Set Screw	Series UP (with lugs and sleeves) Series USB (1000 amp bus with sleeves)
Burndy	Lug	URD Mole
Connector Mfg. Co.	Compression Set Screw Set Screw	Utilug Sure Seal Splice Kits, Series SSK, SSKL Uni-Joint Sure Seal Series SSBC Secondary Connector ULS2-350
ESP	Lug  Set Screw	Type UC (8 AWG - 500 kcmil) (with LA lug and sleeve) Type UPP
Homac	Connector Blocks: Lug  Lug  Set Screw Set Screw Splices: Compression Set Screw Set Screw Set Screw	FS-95 Series with flood seal sleeve kit (8AWG - 350 kcmil)  FS-125 Series with flood seal sleeve kit (350 - 500 kcmil)  SHC Series RAB Series  RRK Series (#2AWG - 350 kcmil) UH11L USK Series MTB Series
Hubbell (Fargo)	Set Screw	GU-600 Series
Kearney/Eaton	Compression Compression	HCR HAR
MacLean (Reliable)	Set Screw	15903-15908, 15910 with sleeve kit (4 AWG - 350 kcmil) 15911 with sleeve kit (500 - 750 kcmil)
Penn Union	Lug	DBA Series with DBTB, DBTBF and DBTH Series lug and sleeve kits
Preformed	Set Screw	HT Kit Series
TE Connectivity - Energy	Set Screw	GILS-4/0
Utilco	Set Screw Set Screw	Safety Sub Splice - USPA-350SS Safety Sub Tap Connector - PED-350SS

U gp - Secondary Connector Blocks and Splices, Insulated

Non-Watertight - For Use In Above-Grade Pedestals Only

Manufacturer	Connection Type	Catalog Number
Blackburn	Set Screw	Type PSB-C
Connector Mfg. Co.	Set Screw	Uni-Joint Series NCA
ESP	Set Screw	UPC Series
Homac	Set Screw Set Screw	CLR-350 Series PVAB Series
Hubbell (Fargo)	Set Screw	GUS-460 Series
Polaris	Set Screw	IPLC
IlSCO (Utilco)	Set Screw	PED-350CP Series PED-500CP Series
Vector Connectors Corp.	Set Screw	PC Series

U gq-1  
July 2009

U gq - Boot or sleeve, insulated\*

Manufacturer	Catalog Number
Blackburn	MPC9 MPC15
Electrical Materials	100-B (For pad-mounted transformer spade terminals)

\*Use restricted to 120/208 volt 500 kVA transformers and larger not equipped with threaded studs.



U gu - Pedestal, Power  
(Above-Grade)  
Refer to Construction Drawing UK5

Applicable Specifications: "RUS Specifications for Secondary Power Pedestals," U-6

Manufacturer	Inside Dimensions Inches	Height Inches	Catalog No.
<u>API</u>	6 x 6	32	API 6 x 6
	9 x 10	25-1/2	API 9 x 10
	10 x 11	34	API 10 x 11
	10 x 11	12-1/4	API 10 x FM
	10 x 11	72	API 10 x 11XL
	10 x 14	22-1/2	API 10 x 14
	10 x 14	26-1/2	API 10 x 14 WB
	16 x 28	38	API 16 x28
	13 Dia.	25	API 176
<u>Coil Sales</u> (Charles Industries)	8.25 Dia	31-1/2	CPLP-8
	8.25 Dia	31-1/2	CPLP-8I(Integral Stake)
	10.75 Dia	31-1/2	CPLP-10
	10.75 Dia	31-1/2	CPLP-10I(Integral Stake)
<u>Electrimold</u>	14.5 x 19.5	31.5	EFSO-111630
<u>Highline Products</u>	14 X 9	31	FSP140931AA
	15.5 X 15.5	30	FSP151530AA
	15.5 X 15.5	36	FSP151536AA
	14 X 9	36	FSP140936AA
	9 X 9	31	FSP090931AA
<u>Hubbell Power Systems, Inc.</u>	10 x 15	30	SP101530
	10 x 15	36	SP101536
	11 x 21	30	SP112130
	11 x 21	36	SP112136
<u>MacLean (Reliable)</u>	8 x 8	38	UP 8HLP
	8 x 8	46	UP 8HP
	10-1/2 x 10-1/2	26	UP 10HLP
	16-1/2 x 10-1/2	36	UP 1016HLP
	10-1/2 x 10-1/2	42	UP 10HP

U gu - Pedestal, Power  
(Above-Grade)  
Refer to Construction Drawing UK5

Applicable Specifications: "RUS Specifications for Secondary Power Pedestals," U-6

Manufacturer	Inside Dimensions Inches	Height Inches	Catalog No.
<u>API</u>	12 x 16	40	API 12 X 16
<u>Nordic Fiberglass, Inc.</u>	15 x 15	30	PSP-151530
	9 X 13	30	PSP-91330
	9 x 13	36	PSP-91336
	10 X 15	38	PSPF-101538
	15 x 15	38	PSPS-101538-MG-X
	15 x 15	44	PSPS-101544-MG-X
	8 x 8	44	PR-50, PR-55
	9 x 14	30	PR-149 (stake)
	9 x 14	30	PR-150 (stakeless)
	9 x 14	30	PRMC 150 (low profile)
	9 x 14	24	PRMC-160
	9 x 14	30	PRMC-170 (high profile)
	9 x 14	36	PRMC-190
	21 x 21	15	PHH-212115
	16 x 19	12	PHH-161912
	10 x 18	30	PSPX-101830-MG
	15 x 23	15	PHH-152315-MG
<u>PenCell Plastics, Inc.</u>	10-1/2 X13-1/2	24-1/2	AG-14 (low profile)
	10-1/2 X13-1/2	30-1/2	AG-14 (high profile)
	11X14	37	AG-15
	13X17.5	30.5	AG-18
	10-3/4X14-1/4	34	AG-20
	7-1/2 round	38	AG-8820-EWB
	17 x 30	34	AG-1730-EWB
<u>Shallbetter</u>	7.5 x 10.25	39	SUTP Series
<u>Utility Fiberglass</u>	27 x 16	40	PPFP-2700
<u>Vertex</u>	8 x 14	30	SP 814

\*Furnished with stake.

\*\*Pole mounted

U gu - Power Pedestal  
(Below-Grade)  
Refer to Drawing UK6

Applicable Specifications: "RUS Specifications for Secondary Power Pedestals," U-6

<u>Manufacturer</u>	<u>Catalog No.</u>
<u>Armorcast</u>	Polymer concrete frame and cover with fiberglass reinforced polyester skirting 6001 Series. P600XXXXA Rotocast Series, molded polyethylene with penta-head bolt
<u>Associated Plastics</u>	Molded polyethylene with galvanized steel or plastic cover Catalog Nos. 1730-1, 3; 1324-1, 3
<u>Blackburn</u>	Molded polyethylene with galvanized steel cover and ground lug. Catalog No. SDR-2PG
<u>Burndy</u>	Molded polyethylene with galvanized steel cover. Catalog No. URD20G23
<u>Carson</u>	Molded polyethylene with plastic cover Catalog No. 1324-12B and 1730-12B H910, HLW1212, H1118, H1324, H1730, H1730, H2436, H3048, HH3060
<u>CDR Systems (Homac)</u>	Fiber reinforced polymer concrete - PA Series with penta-head bolts
<u>Christy Concrete</u>	Polyester reinforced plastic - Series FL8TRCBOX, FL9TRCBOX, FL30TRCBOX, FL36TRCBOX, SYN1118TBOX, SYN1212TBOX, SYN1324TBOX, SYN1730TBOX, SYN2436TBOX, SYN3048TBOX, and SYN3660TBOX
<u>Dexol</u>	HDPE, DX-101, DX-102 ABS, DX-101HD, DX-102HD
<u>Electrimold</u>	Polymer concrete ring and cover with fiberglass reinforced skirting ECAB series.  Boxes EPBTH,EPBA series
<u>Highline Products</u>	FHH Series, Fiberglass CHA Series, Fiberglass polymer concrete hybrid

U gu - Power Pedestal  
(Below-Grade)  
Refer to Drawings UK6

Applicable Specifications: "RUS Specifications for Secondary Power Pedestals," U-6

<u>Manufacturer</u>	<u>Catalog No.</u>
<u>Hubbell (Fargo)</u>	HDPE, B-100R Series ABS, B-200R Series HL51
<u>American Padmount Systems</u>	Fiberglass secondary pedestal FSP31139, FSP301515
<u>Newbasis</u>	Fiber reinforced polymer concrete box, ring and cover – PCA Series  Fiber reinforced polymer box with polymer concrete ring and cover – FCA Series
<u>PenCell</u>	PE Series-High Density Polyethylene (HDPE) base;lid available in HDPE, fiberglass, aluminum, or stainless steel; PEM Series with modular construction, DT Series – heavy duty HDPE for vehicular traffic
<u>Quazite</u>	Power Pedestal – PV, Boxes - PX/PE Series, PR/LR Series, PC, PG, LG Series
<u>Synertech Moulded Products</u>	S1212, S1118, S1324, S1730, S2436, S3048 and S3660
<u>Thermodynamics</u>	PP91, PP92, PP94, PP96, PP97, PP98, PP03, PPV91, TEVC132415ASY, TEVC121612ASY, and TEVC122016ASY series
<u>API</u>	API MOD20, and API MOD20-FM Rotationally Molded LLDPE

U gv-1  
July 2009

U gv - Stake, Power Pedestal  
Refer to Construction Drawing UK5

Manufacturer	Length Inches	<u>Catalog No.</u>	
		For Power Pedestal Only	For Joint Pedestal
Hubbell (Fargo)	42-60-72-78	UP-530S Series	UP-530J Series
MacLean (Reliable)	72-78-84	DM Series	DM Series

U hb - Cable Accessories

(When ordering specify conductor size, type whether copper or aluminum and insulation diameter)

(Items on this page are rated for operation on three-phase systems and may be used on single-phase systems.)

200 Ampere Continuous Current Rating

<u>Manufacturer</u>	<u>Catalog No.</u>
<u>Eaton</u>	15 kV, used with loadbreak connectors LPC 215 protective cap LBI215 bushing well insert 2637869C01M rotatable two-way bushing well insert 2604231B01 bushing well plug 25 kV, used with loadbreak connectors LPC 225 protective cap LB1225 bushing well insert LB1225L (long) bushing well insert 2637881C01M rotatable two-way bushing well insert 2604231B01 bushing well plug 35 kV, used with loadbreak connectors 2637592B03M protective cap
<u>Hubbell</u>	15 kV, used with loadbreak connectors 215BI bushing well insert 215IC insulating cap 215FTI feed-thru insert  25 kV, used with loadbreak connectors 225BI bushing well insert 228IC insulating cap 228FTI feed-thru insert

U hb - Cable Accessories  
(When ordering specify conductor size, type, whether  
copper or aluminum and insulation diameter)

(Items on this page are rated for operation on three-phase systems and may be used on single-phase systems.)

200 Ampere Continuous Current Rating

Manufacturer	Catalog Number
<u>Elastimold (ESNA)</u>	15 kV, used with loadbreak connectors Style 1601-CL cable lead Style 1602A3R feed thru insert Style 1601-A3R bushing plug Style 160-DR insulating cap  25 kV, used with loadbreak connectors Style 2701-A2 bushing plug Style 270-DR deadend receptacle  35 kV, used with loadbreak connectors Style 3701A-3 bushing plug* Style 370DR(G) insulating cap
<u>TE Connectivity – Energy</u>	15 kV, used with loadbreak connectors ELB-15-210 series without jacket seal ELB-15-210-ES series with jacket seal  25 kV, used with loadbreak connectors ELB-25-210 series without jacket seal ELB-25-210-ES series with jacket seal  25 kV, used with loadbreak connectors (without test point) ELB-25-200 series without jacket seal ELB-25-200-ES series with jacket seal  15 kV, used with loadbreak connectors (without test point) ELB-15-200 series without jacket seal ELB-15-200-ES series with jacket seal

U hb - Cable Accessories

(When ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

Manufacturer	Catalog Number
<u>Hubbell</u>	15 kV, used with non-loadbreak connectors 615 Series 25 kV, used with non-loadbreak connectors 625 Series
<u>Eaton</u>	15 kV Deadbreak termination connectors Bol-T System T-OP II System Push-OP System DBA615 Bushing Adapter 25 kV Deadbreak termination connectors Bol-T System T-OP II System Push-OP System DBA625 Bushing Adapter 35 kV Deadbreak termination connectors Bol-T System T-OP II System Push-OP System Optional 200 A. loadbreak tap No. 2637449C
<u>Elastimold (ESNA)</u>	15 kV, used with non-loadbreak connectors 600, 650 Series 25 kV, used with non-loadbreak connectors K600, K650 Series 35 kV, used with non-loadbreak connectors 750LR Series



U hb - Cable Accessories

(When ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>3M</u>	15 kV, Deadbreak termination connectors 5815 Series Modular Splicing System
<u>TE Connectivity – Energy</u>	15 kV Deadbreak termination connectors ELB-15-600without test point ELB-15-600 with test point  25 kV Deadbreak termination connectors ELB-28-600without test point ELB-28-600 with test point  35 kV Deadbreak termination connectors ELB-35-600without test point ELB-35-600 with test point

U hb - Cable Accessories

(When ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

Manufacturer	Catalog Number
<u>Richards Manufacturing Co.</u>	15kV, Deadbreak Elbow LC Series System
	15kV, Deadbreak Elbow/ Cold Shrinkable Cable Entrance CSH Series   Cold Shrink Hammerhead System
	15kV, Deadbreak Elbow w/integral 15kV 200A Loadbreak Tap Plug R800 Series System
	15kV, Deadbreak Elbow w/integral 15kV 200A Loadbreak Tap Plug and Cold Shrinkable Cable Entrance CS8 Series   Cold Shrink R800 System
	25kV, Deadbreak Elbow LC Series System
	25kV, Deadbreak Elbow w/ Cold Shrinkable Cable Entrance CSH Series   Cold Shrink Hammerhead System
	25kV, Deadbreak Elbow w/integral 25kV 200A Loadbreak Tap Plug R800 Series System
	25kV, Deadbreak Elbow w/integral 25kV 200A Loadbreak Tap Plug and Cold Shrinkable Cable Entrance CS8 Series   Cold Shrink R800 System

U hb - Cable Accessories

(When ordering specify insulation diameter)

Concentric Neutral Clamps (Bonding)

<u>Manufacturer</u>	<u>Conditions</u>
<u>Harco</u> URD cable clamp	<ol style="list-style-type: none"><li>1. To obtain experience.</li><li>2. Only for bonding of anodes or other metals to the neutrals of <u>existing</u> cable installations.</li><li>3. Not to be used to connect neutral to grounding electrodes.</li></ol>

U hc - Cable Supports  
15 and 25 kV

Manufacturer	Catalog Number	Grip Dia. Range (inches)
Aluma-Form	CS-800 Series	0.75 to 2.0
Economy Cable Grip	SPJ087-U	0.87 to 1.00
	SPJ100-U	1.00 to 1.12
	SPJ113-U	1.12 to 1.25
	SPC125-S-U	1.25 to 1.50
Hubbell (Fargo)	GJ-854	0.718 to 0.919
	GJ-855	0.920 to 1.12
	GJ-856	1.12 to 1.50
Kellums	022-16-011	0.81 to 0.94
	022-16-012	0.87 to 1.00
	022-16-013	0.94 to 1.06
	022-16-014	1.00 to 1.18
	022-16-015	1.06 to 1.25
	022-01-018	1.25 to 1.50
Lewis	A-U-SW-18	0.75 to 1.25
	U-1.12	1.12 to 1.62
MacLean Power Systems	MCS-820	0.75 to 3.0
Slater	FCSD 14	0.82 to 0.95
	FCSD 15	0.88 to 1.00
	FCSD 16	0.95 to 1.06
	FCSD 17	1.01 to 1.19
	FCSD 18	1.07 to 1.26
	FC125-U	1.25 to 1.50
Woodhead	35032 (SC075-U)	0.75 to 0.99
	35033 (SC100-U)	1.00 to 1.24
	35034 (SC125-U)	1.25 to 1.49

U hd – Brackets, pothead mounting, and Brackets, combination pothead and arrester mounting

<u>Manufacturer</u>	<u>Single Phase</u>	<u>Three Phase</u>
Aluma-Form	TB-EMB-1-2PA	TB-EMB-1-6PA
MacLean Power Systems	-	MTB-EMB-1-6-PA

U he – Padmounted Switchgear

12.5/7.2 kV

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>ABB</u>	UTE, PAD-PAK pad-mounted switching device, single and three-phase, 300 amp  *ME Fused Series, single and three-phase pad mounted
<u>Durham</u>	AFSP Series, single-and three phase
<u>Federal Pacific</u>	FTDF-P Series, single and three-phase one and two fused taps, pad-mounted
<u>Elliott</u>	Type EPMR, single and three-phase, pad-mounted
<u>Howard Industries</u>	Switch-Pad pad-mounted switching and fusing cabinet, single and three-phase
<u>Shallbetter</u>	SPMD Series, single and three-phase, pad-mounted SPMC Series, 200 ampere single-pole switching

\*Furnished with current limiting fuses.

NOTES:

1. Enclosures on this page must comply with the dead-front requirements of RUS Spec. U-4.
2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.
3. Single-pole switching of three-phase underground circuits may cause ferro resonance.

U he – Padmounted Switchgear

24.9/14.4 kV

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>ABB</u>	UTE, PAD-PAK pad-mounted switching device, single and three-phase, 200 amp ME Fused Series, single and three phase, pad- mounted
<u>Durham</u>	AFSP Series, single-and three phase
<u>Elliott</u>	Type EPMR, single- and three-phase, pad-mounted
<u>Howard Industries</u>	Switch-Pad pad-mounted switching and fusing cabinet, single and three-phase
<u>Shallbetter</u>	SPMD Series, single and three-phase, pad-mounted

NOTES:

1. Enclosures on this page must comply with the dead-front requirements of RUS Specification U-4.
2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.
3. Single-pole switching of three-phase underground circuits may cause ferroresonance.

# U he – Padmounted Switchgear

(200 and 600 amp)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Eaton</u>	Type VFI*, single-phase and three phase, padmounted fault interrupters, 15-35 kV Type R-VAC*, three-phase vacuum switchgear, 15-25 kV
*Eaton Envirotemp FR3 dielectric fluid is available as an option	
<u>Elastimold</u>	Type MVS, single-phase and three phase, 200 and 600 amp, 15-38 kV Type MVI, single-phase and three phase, 200 and 600 amp, 15-38 kV
<u>Elliott</u>	Type EPMR, Single and three-phase, pad-mounted, 25 kV
<u>ERMCO, INC.</u>	Type FusePad, single-phase, 200 and 600 amp, 15-35 kV Type ECO-PAD, three-phase, 200 and 600 amp, 15-35 kV
<u>Federal Pacific</u>	Type PSI-PSI/II Series, 15 kV, 25 kV, 600 amp., three-phase switching, and 200 amp., single-phase switching. (When ordering, add suffix B-4) Type PSE Series, 15 kV, 25 kV, 600 amp switch, 200 amp fuse
<u>G &amp; W Electric Company</u>	Type PVI series, single-phase and three-phase, 200 amp and 600 amp, 15 kV and 25 kV Trident type solid dielectric switches, single-phase and three-phase, 200A, 630A, and 800A, 15 kV through 35 kV
<u>Hubbell (Chance)</u>	Type LVS (pad-mounted) single-phase and three-phase, vacuum switching equipment, fused or unfused, 200 or 600 amp, 15-25 kV Type AIS padmounted, air insulated switchgear, fused or unfused, 200 or 600 amp, 15 kV or 25 kV

## Notes:

1. Enclosures on this page must comply with the deadfront requirements of RUS Spec. U-4.
2. These enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.
3. Single-pole switching of three-phase underground circuits may cause ferroresonance.



U he – Padmounted Switchgear

(200 and 600 amp)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Kearney/Eaton</u>	Series VP - submersible, single-phase and three-phase, vacuum switching, 200 or 600 amp, 15 and 25 kV, with or without VACOP remote operator
<u>ABB</u>	MES 100 Series, pad-mounted single phase and three phase switching
<u>Scott Engineering</u>	Type SPM-REA, 15 kV, 25 kV, 600 amp., three-phase switching, and 200 amp., single-phase switching
<u>S &amp; C</u>	Mark III, Model PMH (with option G-7), 15-25 kV, 600 amp., three-phase switching and 200 amp., single-pole switching Model PME-15-25 kV, Fully enclosed live parts at all times, three-phase switching and 200 amp single pole switching
<u>Trayer</u>	800 Series, pad mounted three-phase vacuum switching equipment, 200 and 600 amp, 15-25 kV with or without fusing 501 submersible vacuum fuse 15-25 kV enclosure, deadfront 200 or 600 amp., 15-25 kV Type SSA (submersible, fused and unfused) 200 and 600 amp., 15-25 kV

Notes:

1. Enclosures on this page must comply with the deadfront requirements of RUS Spec. U-4.
2. The enclosures have been certified as meeting the requirements of ANSI C57.12.28. A copy of the certification is available from the manufacturer.
3. Single-pole switching of three-phase underground circuits may cause ferroresonance.

U hf - Jacketed Cable Restoration Kits  
(For resealing concentric neutral wires after installation of splices in jacketed underground cable)

(When ordering, specify diameter of cable over jacket)

Manufacturer	Conditions
<u>Elastimold</u> PCS-1 Power Cable Seal	To obtain experience.
<u>Homac</u> CNC Series Concentric Neutral Cover	To obtain experience.
<u>Joslyn</u> Shrinklite JRS Series	To obtain experience
<u>TE Connectivity - Energy</u> WCSM (Tubing Type) MWTM (Tubing Type) CRSM (Wraparound Type)	To obtain experience.
<u>3M</u> HSJ Series (Heat Shrink) SJ Series (Cold Shrink)	To obtain experience.

U hf - Terminator Sealing Kits

(For resealing concentric neutral wires after installation of elbows or outdoor terminations on jacketed underground cable.)

(When ordering, specify diameter of cable over jacket.)

<u>Manufacturer</u>	<u>Conditions</u>
<u>Eaton</u> JS200 Elastic Seal	To obtain experience.
<u>Elastimold</u> 200 ECS Elbow Cable Shield, Cold Shrink	To obtain experience.
<u>Homac</u> CNC Series Concentric Neutral Cover	To obtain experience.
<u>TE Connectivity - Energy</u> ESA, Heat Shrink	To obtain experience.
<u>3M</u> 8450 Series, Cold Shrink	To obtain experience.

U hf - Jacketed Cable Grounding Kits  
(For connecting a grounding lead wire to the concentric neutral wires and resealing the jacket)

(When ordering, specify diameter of cable over jacket)

Manufacturer	Conditions
<u>CANUSA-EMI</u> Model CFGK-REA Cable Grounding Kit	To obtain experience.
<u>TE Connectivity - Energy</u> Model JGK Cable Grounding Kit	To obtain experience.
<u>3M</u> Model 2252 Cable Grounding Kit	To obtain experience.

U hj - Bracket, combination arrester, cutout and pothead mounting

Applicable Drawing: UA1, UA2, UA3

Manufacturer	Single Phase	Three-Phase
Aluma-Form	1HCA-18-1PB Series	-

U hp - Terminations, Elbow  
(rated for switching on three-phase systems)

(When ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

Manufacturer	Catalog Number
<u>Eaton</u>	<u>15 kV, Loadbreak SBT IV</u> LE215T Series with test point LE215 Series without test point LEJ215T Series with integrated jacket seal; with test point LEJ215 Series with integrated jacket seal; without test point Note: LE215, LE215T manufactured in U.S.A. and Taiwan. <u>25 kV, Loadbreak SBT</u> LE225T Series with test point LE225 Series without test point LEJ225T Series with integrated jacket seal; with test point LEJ225 Series with integrated jacket seal; without test point
<u>Thomas &amp; Betts (Elastimold)</u>	<u>15 kV loadbreak</u> Style 161 LR Series, without voltage test point Style 162 LR Series, with voltage test point Style 161LRJS Series, without voltage test point, with integral jacket seal Style 162LRJS Series, with voltage test point, with integral jacket seal <u>25 kV loadbreak</u> Style 261 LR Series, without voltage test point Style 262 LR Series, with voltage test point Style 261LRJS Series, without voltage test point, with integral jacket seal Style 262LRJS Series, with voltage test point, with integral jacket seal <u>35 kV loadbreak</u> Style 375LR Series, without voltage test point Style 376LR Series, with voltage test point
<u>Hubbell</u>	<u>15 kV, Loadbreak</u> 215LE--, without test point 215LE--T, with test point 215LEJ--, integral seal without test point 215LEJ--T, integral seal with test point <u>25 kV, Loadbreak</u> 228LE--, without test point 228LE--T, with test point 228LEJ--, integral seal without test point 228LEJ--T, integral seal with test point <u>35 kV, Loadbreak</u> 236LE--, without test point 236LE--T, with test point
<u>Richards Manufacturing Co.</u>	<u>15 kV, Loadbreak</u> Style 21LBN Series, without voltage test point Style 21LBT Series, with voltage test point



U hq - Terminations, Multipoint

(Items on this page are rated for operation on three-phase systems and may be used on single-phase systems)

Manufacturer	Catalog Number
<u>Eaton</u>	15 kV 2-way, 3-way, 4-way bushings Series LJ215C---B (with bracket) Series LJ215C---U (with U-Straps) Series LJ215C--- (junction only)  25 kV 2-way, 3-way, 4-way bushings Series LJ225C---B (with bracket) Series LJ225C---U (with U-Straps) Series LJ225C--- (junction only)
<u>Elastimold (ESNA)</u>	15 kV 2-way bushing, 163J2 3-way bushing, 163J3 4-way bushing, 163J4 25 kV 2-way bushing, 271J2 3-way bushing, 271J3 4-way bushing, 271J4 35 kV 2-way bushing, 373J2 3-way bushing, 373J3 4-way bushing, 373J4
<u>G&amp;W Electric</u>	15kV JB xxx 15U JB xxx 15P, with parking stands 25kV JB xxx 25U JB xxx 25P, with parking stands 35kV JB xxx 35U JB xxx 35P, with parking stands
<u>Hubbell Power Systems</u>	15 kV 2-way bushing 215J2X 3-way bushing 215J3X 4-way bushing 215J4X 25 kV 2-way bushing 228J2X 3-way bushing 228J3X 4-way bushing 228J4X



U hq - Terminations, Feed-Through and Parking Bushings

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Eaton</u>	15 kV Grounded Standoff Bushing, GSB215 Horizontal Portable Feed-through, LPF215H Vertical Portable Feed-through, LPF215V Universal Portable Feed-through, LPF215U 25 kV Grounded Standoff Bushing, GSB225 Horizontal Portable Feed-through, LPF225H Vertical Portable Feed-through, LPF225V Universal Portable Feed-through, LPF225U
<u>Elastimold (ESNA)</u>	35 kV Feed-thru, 373FT Parking Bushing, 371SOP
<u>Hubbell</u>	15 kV 215FT feed-thru 215SB standoff bushing 25 kV 228FT feed-thru 228SB standoff bushing 228GB grounded bushing

U hq - Terminations, Multipoint

600 Ampere Continuous Current Rating

Manufacturer	Catalog Number
<u>Eaton</u>	15 kV, 25 kV Clear load break connector assembly Series LCN2DLJ615A, LCN2DLJ625A 25 kV 2-way, 3-way, and 4-way bushings Series DJ625A_ (with mounting bracket) Series DJ625A_B_ (without mounting bracket) 35 kV 2-way, 3-way, 4-way bushings Series DJ635---B (with bracket) Series DJ635---U (with U-Straps) Series DJ635--- (junction only)
<u>Elastimold (ESNA)</u>	15 kV 2-way bushing, 650J2 or 675J2 3-way bushing, 650J3 or 675J3 4-way bushing, 650J4 or 675J4 25 kV 2-way bushing, K650J2 or K675J2 3-way bushing, K650J3 or K675J3 4-way bushing, K650J4 or K675J4

U hr - Secondary tap or splice cover, submersible

<u>Manufacturer</u>	<u>Type or Catalog No.</u>
Blackburn	Type WDBS (#2 through #4/0), Type DBS (250 kcmil through 1000 kcmil)
Connector Mfg. Co.	Utilug Sure Seal
DSG-Canusa	CSS Cold Shrink Splice Kits
Elastimold (ESNA)	Style 86
ESP	TSC Series
Homac	FSS Series
Joslyn	Shrinktite JCLS Series
Kearney/Eaton	Aqua-Seal Kit
Preformed	HT Series
Plymouth/Bishop	Splice-Wrap
TE Connectivity - Energy	Rayvolve RVS Series
3M	PST Series 8420

Heat Shrink Tubing (with sealant throughout)

<u>Manufacturer</u>	<u>Type or Catalog No.</u>
TE Connectivity - Energy	Black heat-shrink tubing WCSM cable sleeves
CANUSA-EMI	CFW
ESP	HSB
Panduit	Heat shrink insulating cover and tubing
Sigmaform Corporation	Sigmaform heat-shrinkable products
3M	ITCSN tubular cable sleeve

U hv - Cable, Underground  
15 kV, 25 kV, 35 kV Cable

Applicable Specification:	7 CFR Part 1728.204
Conductor (15 kV):	Copper or Aluminum - #2 AWG through 1000 kcmil
Conductor (25 kV):	Copper or Aluminum - #1 AWG through 1000 kcmil
Conductor (35 kV):	Copper or Aluminum – 1/0 through 1000 kcmil
Insulation:	<u>Tree-retardant Crosslinked Polyethylene (XLP-TR)</u> (1) indicates Union Carbide 4202 XLP-TR (2) indicates BP H119Y XLP-TR (3) indicates BP H118Y XLP-TR (4) indicates LG XL8080 TR  <u>Ethylene Propylene Rubber (EPR)</u> (E) indicates EPR
Neutral:	Copper Concentric Neutral
Jacket:	High Molecular Weight Polyethylene

<u>Manufacturer</u>	<u>Insulation(s)</u>	<u>Flat Strap Neutral Available</u>
Conductores Monterrey, S.A. de C.V.	1, E	No
Condumex	1, E	No
General Cable	1, 3, E	Yes
Gaon Cable Co., Ltd.	4, E	No
Marmon Utility LLC (Hendrix)	1, 2, 3, E	No
Marmon Utility LLC (Kerite)	E	Yes
Nexans Canada	1, E	No
Nexans Italia	E	No
Okonite	1, E	Yes

U hv - Cable, Underground  
15 kV, 25 kV, 35 kV Cable

Applicable Specification:	7 CFR Part 1728.204
Conductor (15 kV):	Copper or Aluminum - #2 AWG through 1000 kcmil
Conductor (25 kV):	Copper or Aluminum - #1 AWG through 1000 kcmil
Conductor (35 kV):	Copper or Aluminum – 1/0 through 1000 kcmil
Insulation:	<u>Tree-retardant Crosslinked Polyethylene (XLP-TR)</u> (1) indicates Union Carbide 4202 XLP-TR (2) indicates BP H119Y XLP-TR (3) indicates BP H118Y XLP-TR (4) indicates LG XL8080 TR  <u>Ethylene Propylene Rubber (EPR)</u> (E) indicates EPR
Neutral:	Copper Concentric Neutral
Jacket:	High Molecular Weight Polyethylene

<u>Manufacturer</u>	<u>Insulation(s)</u>	<u>Flat Strap Neutral Available</u>
Phelps Dodge	1, 3, E	Yes
Prysmian	1, E	Yes
Rome	1, E	Yes
Southwire	1, E	Yes
Synergy Cables	1, E	No

U hv - Cable, Underground

600 Volt Cable

Applicable Specification: RUS Specification U-2

Conductor: Copper, #4 AWG and larger; Aluminum, #2 AWG and larger

Insulation: Cross-Linked polyethylene (XLPE)

<u>Manufacturer</u>	<u>Type Conductor</u>
Alcan	Aluminum
Centelsa	Aluminum
Conductorres Monterrey, S.A. de C.V.	Copper or Aluminum
Condumex	Copper or Aluminum
Encore Wire Corporation	Aluminum
Essex	Copper
General Cable	Copper or Aluminum
Nexans Canada	Aluminum
Okonite	Copper or Aluminum
Phelps Dodge	Copper or Aluminum
Prysmian	Copper or Aluminum
Rome Cable	Copper or Aluminum
Service Wire Company	Copper
Southwire	Copper or Aluminum

NOTE: The manufacturers shown above have indicated that their 600 volt cable is suitable for use on 480 volt corner grounded delta circuits.

The above cable may be supplied with UL label for Type USE.

U hv - Cable, Underground

600 Volt Multi-Conductor Cable

Applicable Specification: RUS Specification U-2

Conductor: Copper, #4 AWG and larger; Aluminum, #2 AWG and larger

Insulation: Cross-Linked polyethylene (XLPE)

Cable Configuration: 3 Insulated Conductors Triplexed

<u>Manufacturer</u>	<u>Type Conductor</u>
Alcan	Aluminum
Conductores Monterrey, S.A. de C.V.	Copper or Aluminum
Condumex	Copper or Aluminum
Encore Wire Corporation	Aluminum
General Cable	Copper or Aluminum
Nexans Canada	Aluminum
Okonite	Copper or Aluminum
Phelps Dodge	Copper or Aluminum
Prysmian	Copper or Aluminum
Rome Cable	Copper or Aluminum
Southwire	Copper or Aluminum

The above cable may be supplied with UL label for Type USE.

**U hv - Cable, Underground**

600 Volt Cable

(Alternative Cable Constructions)

Applicable Specification: RUS Specification U-2 (except as indicated below)

NOTE: Manufacturers listed below are accepted for alternatives A, B, C, D and/or E for the products listed on pages U hv-2 and U hv-3.

Alternative A: 8000 series aluminum alloy in accordance with ASTM B800 or B801.

Alternative B: Stranding in accordance with ASTM B786 for aluminum 1350 conductors or ASTM B787 for copper conductors.

Alternative C: Abuse resistant (ruggedized) (single or two layer) insulation in accordance with ICEA S-81-570.

Alternative D: Self-healing

Alternative E: Stranding in accordance with ASTM B 901 for Compressed Round Stranded Aluminum Conductors Using Single Input Wire Construction

Manufacturer

---

Alternative

---



U hv - Cable, Underground

15 kV, 25 kV and 35 kV Cable

(Alternative Insulation Compound)

Applicable Specification:

7 CFR Part 1728.204

Conductor (15 kV):

Copper or Aluminum - #2 AWG through 1000 kcmil

Conductor (25 kV):

Copper or Aluminum - #1 AWG through 1000 kcmil

Conductor (35 kV):

Copper or Aluminum – 1/0 through 1000 kcmil

Alternative Insulation Compound:

Tree-retardant Crosslinked Polyethylene (TR-XLPE)

(I) indicates Pirelli IE.7100 XLP-TR

(II) indicates AT Plastic PowerGuard 320TR

(III) indicates Union Carbide HFDB-4202

(IV) indicates Nova Borealis LE 4212

(V) indicates Dow HFDB 8202

(VI) indicates Dow Endurance™ HFDC 4202 EC

(VII) indicates LG XL 8080TR

(VIII) indicates Hanwha Wire and Cable Compound CLNA TR-8142EC

Ethylene Propylene Rubber (EPR)

(E) indicates EPR

(EAM) indicates General Cable EI-4000-LF

Neutral:

Copper Concentric Neutral

Jacket:

High Molecular Weight Polyethylene

Conditions:

To obtain experience

<u>Manufacturer</u>	<u>Insulation(s)</u>	<u>Flat Strap Neutral Available</u>
General Cable Industries, Inc.	II, III, IV, V, VI, VII, EAM	Yes
Marmon Utility LLC (Hendrix)	III, IV	No
Nexans Canada	II, III, IV	No
Phelps Dodge	II, III, IV, V	Yes
Prysmian	I, IV	Yes
Southwire	III, IV, VI	Yes
LS Cable & System U.S.A., Inc.	IV, VI, VII, VIII, E	No
TELE-FONIKA Kable S.A.	IV	No

U hv - Cable, Underground

600 Volt Cable

(Alternative Cable Construction)

Applicable Specification: RUS Specification U-2 (except as indicated below)

NOTE: Manufacturers listed below are conditionally accepted for alternatives A, B, C, D and/or E for the products listed on pages U hv-2 and U hv-3.

Alternative A: 8000 series aluminum alloy in accordance with ASTM B800 or B801.

Alternative B: Stranding in accordance with ASTM B786 for aluminum 1350 conductors or ASTM B787 for copper conductors.

Alternative C: Abuse resistant (ruggedized) (single or two layer) insulation in accordance with ICEA S-81-570.

Alternative D: Self-healing

Alternative E: Stranding in accordance with ASTM B 901 for Compressed Round Stranded Aluminum Conductors Using Single Input Wire Construction

Condition: To obtain experience.

<u>Manufacturer</u>	<u>Alternative</u>
Alcan	A, C, E
Conductores Monterrey, S.A. de C.V.	C
Encore Wire Corporation	A, C
General Cable	A, C
Phelps Dodge	A, C
Prysmian	A, C, D
Nexans	C
Southwire	A, B, C, D, E

U hw - Safety signs

Applicable Specifications: RUS Drawings ANSI Z535

Manufacturer	Size (inches)	Danger Sign Catalog No.	Warning Sign Catalog No.	Caution Sign Catalog No.
Almetek	7 x 10 10 x 14 14 x 20	Trident D-100-0710 Trident D-100-1014 Trident D-100-1420	Trident W-100-0710 Trident W-100-1014 Trident W-100-1420	
Brady*	7 x 10 10 x 14	46133 46131		46043 46041
Eastern Metal*	7 x 10 10 x 14 14 x 20 20 x 28	REA 12-1-710 REA 12-1-1014 REA 12-1-1420 REA 12-1-2028		REA 12-2-710 REA 12-2-1014 REA 12-2-1420 REA 12-2-2028
Electromark*	7 x 10 7 x 10 10 x 14 10 x 14 14 x 20 14 x 20 20 x 28 20 x 28	REA-1-7x10-SV REA-1-7x10-AC REA-1-10x14-SV REA-1-10x14-AC REA-1-14x20-SV REA-1-14x20-AC REA-1-20x28-SV REA-1-20x28-AC		REA-2-7x10-SV REA-2-7x10-AC REA-2-10x14-SV REA-2-10x14-AC REA-2-14x20-SV REA-2-14x20-AC REA-2-20x28-SV REA-2-20x28-AC
Lem	7 x 10 10 x 14 14 x 20	LSS-1400 LSS-1401 LSS-1402		LSS-1500 LSS-1501 LSS-1502
Lyle*	7 x 10 10 x 14 14 x 20 20 x 28	UM12-1-710 UM12-1-1014 UM12-1-1420 UM12-1-2028		UM12-2-710 UM12-2-1014 UM12-2-1420 UM12-2-2028
May Advertising	7 x 10 10 x 14 14 x 20 20 x 28	MY710C MY1014C MY1420C MY2028C		MY710B MY1014B MY1420B MY2028B
For pressure sensitive decal add "D" prefix				
Truck Sign Service*	7 x 10 10 x 14 14 x 20 20 x 28	TSD-710 TSD-1014 TSD-1420 TSD-2028		TSC-710 TSC-1014 TSC-1420 TSC-2028

\*Reflective signs also available.

The signs listed on this page are to be secured to equipment and transformer enclosures by means of an adhesive or by welding. Screws and rivets are not to be used.

U hx - Cable Route Marker

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Surface Mounted</u>	
Hubbell (Chance)	C554-0001
<u>Above Grade</u>	
Carsonite	REA-100
Electromark	REA-3-4x7-SV REA-3-4x7-AC REA-3-5x12-SV REA-3-5x12-AC
Flexstake	603, 604, 605, 606
Greenline	FLU-78 (Decal on one side) DSU-78 (Decal on both sides)
Hubbell (Chance)	C554-0183
J Miller Industries	JMI-375
Lyle	UM12-712
May Advertising (For pressure sensitive decal add "D" prefix to catalog number.)	MY45A, MY712A
Quantum	QM-375
Truck Sign Service	BCW-712
W. H. Brady	BL1 (Decal on one side) BL2 (Decal on both sides)

U hy - Splice, Underground, Permanent

(when ordering, specify conductor size, type, whether copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Eaton</u>	<u>15 kV and 25 kV</u> EZ II straight and transition splice #3 through 4/0 <u>35 kV</u> 2603934B Series straight splice
<u>Elastimold (ESNA)</u>	<u>15 kv</u> Style 1500S, straight splice, through #1/0 Style 25-S, straight splice, 2/0 through 4/0 Style I5PCJ-1, straight splice, through 4/0 Style 25-Y, Y-splice <u>25 kV</u> Style K-25-S, straight splice Style K-25-Y, Y-splice Style 25PCJ-1, straight splice, through 4/0 <u>35 kV</u> Style M-250-S, straight splice
<u>DSG-Canusa</u>	<u>15 kV</u> CJ 10 Series, heat shrinkable joints  <u>25 kV</u> CJ 10 Series, heat shrinkable joints  <u>35kV</u> CJ 10 Series, heat shrinkable joints
<u>Hubbell (Chardon)</u>	<u>15 kV</u> Straight Splice through #1/0, Model 9U16A-100 "Uni-Matic" Through #2/0, Model 9U06A <u>25 kV</u> "Uni-Matic" Through #2/0, Model 9U06A
<u>Prysmian</u>	<u>15 kV and 25 kV</u> "Elaspeed" style EPJMe straight splice, #2 through 1000 kcmil
<u>3M</u>	<u>(15, 25, 35 kV)</u> 5400 Series Quick Splice/Quick Splice II/Quick Splice III, 15 kV 5411R cable repair splice 5411R/HSJ-I cable repair splice (for jacketed cable)

U hy - Splice, Underground, Permanent

(When ordering specify conductor size, type, whether copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>TE Connectivity - Energy</u>	<u>15 kV</u> CSJU-1511 CSJU-S-1511 CSJA-1521 CSJA-1522 CSJA-1523 CSJA-1524 HVS 1510-R__ 200 Amp Splice kit CAS-15WJ-2, cold-applied splice  <u>25 kV</u> CSJU-2511 CSJU-S-2511 CSJA-2822 CSJA-2823 CSJA-2824 For Bare Concentric Neutral Cable: HVS-2510-REAX in-line joint HVS-2510E-R-REAX repair joint For Jacketed Cable: HVS-2510-JCN-REAX in-line joint HVS-2510E-RJ-REAX repair joint CAS-28WJ-2, cold-applied splice  <u>35 kV</u> CSJA-3523 CSJA-3524 CSJA-3525 For Bare Concentric Neutral Cable: HVS-3510E-REAX in-line joint For Jacketed Cable: HVS-3510E-JCN-REAX in-line joint CAS-35M, cold-applied in-line splice
<u>Sigmaform</u>	<u>15 kV</u> SSK Series (Heat Shrink)

U hy - Splice, Underground, Separable

(When ordering specify conductor size, type, whether  
copper or aluminum and insulation diameter)

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Elastimold (ESNA)</u>	<u>15 kV</u> Style 151-SR, receptacle Style 151-SP, plug Style 150-DP, deadend plug Style 150-DR, deadend receptacle Style 150-T, T-tap
	<u>25 kV</u> Style K-151-SR, receptacle Style K-151-SP, plug Style K-150-DR, deadend receptacle Style K-150-T, T-tap

U hy - Splice, Underground, Permanent

(When ordering specify conductor size, type, whether  
copper or aluminum and insulation diameter)

600 Ampere Continuous Current Rating

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Eaton</u>	15 kV 2604904B Series straight splice (MPS-600)
	25 kV 2604905B Series straight splice (MPS-600)
<u>Elastimold (ESNA)</u>	15 kV Style 650-S, straight splice Style 15PCJ-2, straight splice, through 1250 kcmil Style 650-Y, Y-Splice
	25 kV Style K650-S, straight splice Style K650-Y, Y-splice Style 25 PCJ-2, straight splice, through 1250 kcmil
	35 kV Style M650S, straight splice



U ja – Equipment Flat Pad\*

Manufacturer	Catalog Number
<u>Armorcast</u>	600 Series, Polymer Concrete P600XXXX Rotocast, LLDPE
<u>Associated Plastics</u>	API 4000 Series RPM
<u>Carolina Dielectrics</u>	Model 0502-1, Fiberglass, Size:40"x44"
<u>CDR Systems (Homac)</u>	PP Series, Fiber reinforced polymer concrete
<u>Diversitech</u>	FRC Series – Fiberglass reinforced concrete
<u>Electri-Glass</u>	Fiberglass LP-4145, 41" x 45"
<u>Electrical Materials</u>	Molded HMW Polyethylene Model 64-3BC, 42" x 41" x 4" Model 65-4BC, 52" x46"
<u>Electrimold</u>	EPPT
<u>Highline Products</u>	PBP Series, Polymer concrete hybrid HL-46B, Fiberglass, Size: approx. 42" X 42"
<u>Formex</u>	Mode1 TP-REA, Molded polyethylene
<u>Heil Rotomold, Inc.</u>	T Series, High density polyethylene
<u>Highline</u>	HL-46B, Fiberglass, Size: approx.42"x42"
<u>Hubbell (Chance)</u>	C107-0162 Fiberglass, Size: 40" x 44"
<u>Major Frame-Crete</u>	ETPP precast, cellular concrete, 42"x42"
<u>Newbasis</u>	Polymer pad – PP1P-4242
<u>Nordic</u>	TP Series, Fiberglass
<u>Parking Bumper Company – a Division of Hog Slat, Inc.</u>	7610, 7612, 7613, 7626PE, 7621
<u>PenCell Plastics</u>	TP-4220, TP-4224, TP-4227
<u>Quality Rubber Company</u>	34242 light-weight concrete
<u>Quazite Corp.</u>	Composolite - PH Series
<u>RMI-D</u>	Dwg. No. 730126-2, Molded polyethylene Size: 42" x 42"
<u>Smith Cattleguard</u>	Easi Set T. Series, Precast Reinforced Concrete
<u>Thermodynamics</u>	Poly-Pad, PR Series, Molded polyethylene YEPR031220, YEPR031226, compression molded polypropylene

\*Order by catalog number and size.

U ja – Equipment Box Pad (Sleeve)\*

<u>Manufacturer</u>	<u>Catalog Number</u>
<u>Acura Fiberglass Corp.</u>	Model AG 4532
<u>Associated Plastics</u>	Transformer pad and box assembly, API 4242 RPM Pad and 1730 Box Transformer Pads, API 16 and API 45
<u>APS</u>	FGBP Series, Fiber Glass
<u>Blue Grass Vault Company</u>	BG-PV-T, BG-PV-1, BG-PV-2
<u>Concast</u>	Fibercrete modular bases
<u>Custom Composites</u>	R Series Fiberglass
<u>DiversiTech</u>	FRC Series – Fiberglass reinforced concrete
<u>D &amp; L</u>	Fiberglass
<u>Electri-Glass, Inc.</u>	BP-2000
<u>Electrimold</u>	EFTB,EFBS,EFTG Series
<u>Fiberglas Fabricators</u>	Transformer pad and sleeve assembly, FFBP series
<u>Formex</u>	Transformer pad and box assembly - TP-REA Series Pad, 1730-A Series Box
<u>Highline</u>	Box pad HL, FBP, FSG, AND FGS Series
<u>American Padmount Systems</u>	FGS Series Fiberglass ground sleeves and box pads
<u>Maysteel</u>	CW-GS-P Series
<u>Mor-Tech Fab</u>	Transformer pad ground sleeves
<u>Nordic</u>	GS Series Fiberglass (excluding GS-37-43-15-A) CBP-37-43-15-A
<u>PenCell</u>	Transformer pad and box assembly- TPS-20-PE Pad, PE-20GS Box
<u>ProGlass, Inc.</u>	TX, SR, S, and SG Series (All without optional lids)
<u>Quality Fiberglass</u>	QF Series
<u>Synertech Moulded Products</u>	S1212, S1118, S1324, S1730, S2436, S3048 and S3660
<u>Thermodynamics</u>	Poly Pad - VC series (VCC-P series covers available) Polyethylene

\*Order by catalog number and size.

U jb-1  
July 2009

U jb - Splice Shield

Manufacturer	Catalog Number
<u>Kellems</u>	No. 014-03-1429

Conditional List

U<sub>sc</sub>(1)

July 2009

U<sub>sc</sub> - Regulators, voltage, pad-mounted  
for underground distribution

12.5/7.2 kV

Manufacturer	Conditions
<u>Siemens-Allis</u> Single-phase, step-type pad-mounted regulator Type PFR (76.2, 114.3 & 167 kVA)	To obtain experience.

U sd - Current Transformers  
600 Volt

Direct Burial Type

<u>Manufacturer</u>	<u>Type or Catalog No.</u>
General Electric	JAL-O

Indoor Type for Pad-Mounted Transformers

<u>Manufacturer</u>	<u>Type or Catalog No.</u>
ABB	CMV
G.E.C. Durham Industries (Astra)	AP
General Electric	JAB-O
Schlumberger	R6P

U si - Anodes, Sacrificial  
(Drawing M27)

Zinc Anodes\*

	<u>Pre-packaged With Connecting Wire</u>			<u>Bare Continuous Strip (Ribbon)</u>	
	<u>12 lbs.</u>	<u>30 lbs.</u>	<u>60 lbs.</u>	<u>5/8" x 7/8"</u>	<u>1/2" x 9/16"</u>
Anode Systems	S-12 packaged	S-30 packaged	S-60 packaged	-	-
Cathodic Protection Services	12HII-4A	30HII-4A	60HII-4A		
Federated Metals	S-12 packaged	S-30 packaged	S-60 packaged	Regular Size Type II	Junior size
Harco	AZC12GJ	AZC30GJ	AZC60HJ		
Mesa	S-12 packaged	S-30 packaged	S-60 packaged	Regular Size	Junior size
Stuart	SZ-12	SZ-30	SZ-60		
	-----VIBROX packaged-----				

\*When ordering, specify zinc anodes that meet ASTM B418-73 Type II Composition and RUS Specification DT-9, "RUS Specification for Zinc Sacrificial Anodes."

U si - Anodes, Sacrificial  
(Drawings UM11-1, UM26, UM27, M2-7, M2-17)

Magnesium Anodes\*\*

	Standard Potential				High Potential			
	17 lbs	20 lbs	32 lbs	50 lbs	17 lbs	20 lbs	32 lbs	48 lbs
Anode Systems	17 packaged	-	32 packaged	50 packaged	17 packaged	20 packaged	32 packaged	84 packaged
Cathodic Protection Services	AMH17A packaged	-	AMH32A packaged	AMH50A packaged	17D3 packaged	20D2 packaged	32D5 packaged	48D5 packaged
Federated Metals	17 packaged	-	32 packaged	50 packaged	-	-	-	-
Global Cathodic Protection	-	-	-	-	17D2	20D2	32D3	48D5
Harco	AMC17J	AMC20J	AMC32J	AMC50J	AMC17G	AMC20G	AMC32G	AMC48G
Kaiser Mag.	17 Vibra Pak	-	32 Vibra Pak	50 Vibra Pak	17 Electromag Vibra Pak	-	32 Electromag Vibra Pak	50 Electromag Vibra Pak
Mesa	17 packaged	-	32 packaged	50 packaged	17D Series	20D2	32D Series	48D5
Stuart	SM-17	-	SM-32	SM-50	SM-17H	-	SM-32H	SM-48H

\*\*When ordering, specify magnesium anodes that meet RUS Specification DT-10, "RUS Specification for Magnesium Sacrificial Anodes."