

Appendix H – Electric and Magnetic Fields (PSC Overview)

Electric & Magnetic Fields (EMF)



What is EMF?

Electricity produces two types of fields; an electric field and a magnetic field. These fields are also called electromagnetic fields or EMF. Since the late 1970s, concern has primarily focused on the magnetic field, so today when people talk about EMF they generally are referring only to the magnetic field.

The EMF produced when we use electricity is part of the electromagnetic spectrum. This spectrum includes all forms of electromagnetic energy. Electromagnetic energy occurs naturally or can be created by electric devices. The electromagnetic spectrum includes cosmic rays, gamma rays, x-rays, sunlight, microwaves, radio waves, heat, and the magnetic fields created by electric currents (see Figure 1).

Although gamma rays, microwaves, and magnetic fields created by electric current are part of the electromagnetic spectrum, they are very different from one another. The ionizing radiation from gamma rays can break molecular bonds. This means that gamma rays and other forms of ionizing radiation can break apart DNA. Exposure to this kind of radiation can lead to cancer.

At lower levels of the electromagnetic spectrum, the amount of energy decreases. Microwaves do not have enough energy to break molecular bonds, although direct exposure to high levels of microwave radiation can cause significant heating.

Power line magnetic fields are in the Extremely Low Frequency (ELF) range of the electromagnetic spectrum. The energy in these magnetic fields is very small. EMF from appliances and power lines does not have enough energy to break molecular bonds.

Cells can respond to exposure to these low energy fields. These responses, or biological effects, tend to be indirect. It has not been shown that these indirect effects cause health problems.

How electricity produces magnetic fields


Magnetic fields are created by charges (electrons) moving in a conductor, such as a wire. The number of electrons moving through a conductor at any given time is called the current (measured in amperes). As the current increases, so does the magnetic field. The magnetic field decreases as the distance from the source increases.

Electric fields

Electric fields are found wherever there is electricity. Electric fields are created by the presence of electric charges and are measured in volts per meter (V/m). An electric field is associated with any device or wire that is connected to a source of electricity, even when a current is not flowing. A magnetic field, on the other hand, is created only when there is a current.

Electric fields are easily shielded by common objects such as trees, fences, and walls. Scientific studies have not found any association between exposure to electric fields and human disease.

Figure 1 The Electromagnetic Spectrum



Power line voltage

and magnetic fields

The size of the magnetic field cannot be predicted from the voltage. It is not uncommon for a 69 kV (69,000 volt) line to have a higher magnetic field than a 115 kV (115,000 volt) line. This is because the current flowing in the line, not the voltage, creates the magnetic field. The size of


the magnetic field around a line is proportional to the current. This means that the magnetic field level increases as the current in the line increases. Very high voltage lines (345 kV) can carry high current and as a result produce relatively high magnetic fields.

The size of the magnetic fields from electric distribution lines

Electric distribution lines bring electricity to your home, school, and office. Figure 2 shows how distribution lines fit into the electrical system. Primary distribution lines have different voltages depending on the need. Common voltages for primary distribution are 4 kV, 12.5 kV, and 24.9 kV. Power lines with voltages of 69 kV or more are generally considered transmission lines, not distribution lines. Service lines serve your home and provide the 240/120 volts that our appliances require. Transformers, the round canisters near the top of the poles or the green metal boxes on the ground, take high voltage from the primary distribution line and transform it to low voltage for use in your home.

The size of the magnetic field coming off a distribution line depends on the amount of current flowing on that line. Primary distribution lines can produce fields similar to the larger transmission lines.

Figure 2 Simplified electrical system



Other sources of EMF

Any device that uses electric current has a magnetic field. Electric appliances such as radios, refrigerators, microwaves, electric ovens, computers, TVs, and hair dryers produce magnetic fields. The wiring that runs through floors, walls, and ceilings is also a source of magnetic fields when electricity is used (see Table 1).

Other

Levels of EMF in a home

Every home is different. Because EMF changes with the current, generally, magnetic fields increase in your home as you use more electricity. They may be higher in areas of your home where electrical use is concentrated.

A nationwide study, conducted in the 1990s, found that higher magnetic field levels are generally found in:

- Urban versus rural areas.
- Duplexes or apartments versus single-family homes.
- Old homes versus new homes.
- Houses with grounding to a metallic waterline that is connected to the city main.
- Houses with knob-and-tube wiring.
- Houses with two-prong versus three-prong outlets.
- Houses with air conditioning.
- Small residences versus large residences.
- High-density versus low-density residential areas.

Table 1 Magnetic Fields from Common Appliances

Magnetic Field Strength (Milligauss - mG)		
Appliances*	At 10 - 12 Inches	At Working Distance (19 - 22 Inches)
Microwave	17 - 236	5 - 28
Electric range	1.8 - 2.9	0.4 - 10
Refrigerator	1.3 - 15.7	0.6 - 11.4
Color TV	3.5 - 18.6	0.9 - 8.2
Fluorescent light	1.2 - 56.7	0.3 - 15
Ceiling fan	0.3 - 49.5	0.0 - 6
Power Tools	At 1 - 4 Inches	At Working Distance (12 - 20 Inches)
Cordless drill	8	5 - 8
Table saw	760 (at motor)	12
Plunge router	300	30
Power Lines**	At Center Line	At 40 Feet
46 kV (138 amps)	9.6	3.7
69 kV (167 amps)	23	7
115 kV (90 amps)	15	5.5
138 kV (300 amps)	39	17
345 kV (628 amps)	95.8	56.4

Sources:

Appliances - Survey of Residential Magnetic Field Sources, Electric Power Research Institute (EPRI), September 1993.

Power tools - Actual measurements by author.

Power lines - Data comes from actual transmission construction cases.

* For appliances, EMF measurements will vary between make and model.

** For power lines, many variables affect EMF strength: the amount of current, distance from the wires, and the line configuration (how wires are placed in relation to one another). Current flow depends on how much electricity is being used by customers on that line. Use will vary with time of day, time of year, and kind of line. For example, a 138 kV line is generally capable of carrying a maximum of 1,566 amps but normal current flow is much lower. The example in the table is for an existing 138 kV line where 300 amps is the normal current flow.

Measuring EMF

The Gauss (G) is the common unit of measure for magnetic fields. Magnetic fields are measured with a gauss meter. These meters have a small wire coil inside them that produces a voltage when exposed to a magnetic field. Many of these meters are simple to use and provide a digital readout in milligauss (mG). The fields encountered in everyday life are measured in milligauss. A milligauss is one-thousandth of a gauss. The tesla, another unit of measure for magnetic fields, is often used in scientific studies. One tesla is equal to 10,000 gauss. Because the fields we are concerned about are small, scientists often report their field measurements in microteslas (μ T). A microtesla is one-millionth of a tesla and is equal to 10 mG.

Epidemiology

The concern about exposure to power frequency EMF has developed because a number of epidemiological studies have found a weak statistical association between exposure to power-frequency magnetic fields and human health effects. Other epidemiological studies, however, have shown no such association. Because of this inconsistency in the findings of epidemiological research, this issue has been controversial for some time. It is important to know something about the science of epidemiology and statistical analysis in order to understand what the study results mean and why there is controversy.

Epidemiology is the study of patterns of disease. Epidemiologists attempt to discover statistical associations between the occurrence of disease in a population and exposure to an infectious or non-infectious agent. Bacteria is an example of an infectious agent. Examples of non-infectious agents could include pesticides, cigarette smoke, or EMF.

Epidemiological studies are field studies. Unlike laboratory research where investigators have total control over study conditions, epidemiologists must observe the world as it is, and must draw inferences from information observed or collected about a study population's life, habits, and exposure to disease agents. Because of this limitation, epidemiological studies suffer from a number of inherent weaknesses. These weaknesses include bias, misclassification, confounding, and statistical variation. Epidemiologists must take such factors into consideration when designing a study and analyzing the results. For example, we know that in-utero exposure to ionizing radiation (e.g. x-rays) is a risk factor for childhood leukemia. Scientists studying human disease and exposure to EMF must identify and acknowledge the presence of known risk factors in any study population. Unfortunately, it is not uncommon for published studies to suffer from and be criticized for weaknesses in study design or failure to account for confounding factors. Another problem that arises in studies on EMF is that it is not possible to compare exposed populations to unexposed populations. In studies on cigarette smoking for example, people either smoke cigarettes or they do not. But in EMF research everyone is exposed to power frequency magnetic fields. So scientists must find a way to measure EMF exposure and separate populations in terms of low and high exposure. This is not a simple task. As described in the section, "Other Sources of EMF", people are exposed to a wide variety of EMF sources and some of those fields can be very high.

The results of epidemiological studies are usually presented either as a relative risk (RR) or an odds ratio (OR). Relative risk is a comparison of the rates of disease between populations. It is calculated by dividing the risk of an exposed person getting a disease by the risk of an unexposed person getting the same disease. An OR compares the odds of exposure rather than rates of exposure. ORs are calculated by dividing the odds of exposure among cases by the odds of exposure among controls. Interpreting an OR is the same as interpreting the RR. An RR/OR of 1.0 means no difference between exposed and unexposed populations. An RR/OR less than one means the exposed population is at a lower risk than the unexposed population while a RR greater than one indicates an increased risk. An RR/OR of 1.5 would suggest the exposed population is 50 percent more likely to contract a disease than the unexposed population. Conversely, an RR/OR of 0.7 would mean the exposed group is 30 percent less likely to develop the disease than the unexposed.

When evaluating epidemiological research, it is important to be able to judge the strength of the results. In other words, do the statistical associations resulting from the study indicate a strong and clear measure of risk? An RR of 5 or more is generally considered strong. (For example, studies comparing smokers to non-smokers showed RRs of 10 to 30 for lung cancer in smokers.) An RR of less than 3 is usually considered weak. Relative risk values of 1.5 or less are generally considered too weak to support any meaningful conclusions.

Because the results of a study are statistical estimates, researchers must present a range over which they are confident the estimate is reliable and the result is less likely to be caused by a random statistical variation. (See footnote 1.) This is usually expressed as a 95 percent confidence interval. For example, a reported RR of 1.2 with a 95 percent confidence interval of 0.7 – 1.9 (reported as RR 1.2 (0.7-1.9)) means that the researcher is 95 percent confident that the true value for the RR is between 0.7 and 1.9. In this case the result would not be statistically significant because the 95 percent confidence interval includes a value less than one. Sample size is a key factor in the reliability of a study's results. Assuming a study is well designed and carefully conducted, the larger the sample, the more reliable are the results.

Cause and effect relationships

Because epidemiological studies result in statistical associations rather than direct evidence of cause and effect, other scientific work must be conducted before scientists can determine that statistical associations from epidemiological studies actually reflect a cause and effect relationship. Usually when epidemiological studies show a consistent and strong association to a risk factor, scientists will develop a plausible theory for how such an exposure might cause disease. This is called a biological mechanism. Then laboratory studies are conducted to test the biological mechanism. In addition, exposure studies on animals need to be conducted under controlled conditions to determine if exposure to the agent does indeed result in disease. In the case of EMF, because a number of epidemiological studies identified an association with leukemia, laboratory studies on mice exposed to EMF would need to be conducted to show if exposure to EMF does cause disease.

By combining epidemiological, biological mechanism, and animal studies scientists are able to piece together how a risk factor or agent might cause disease and how serious exposure might be to human health. The certainty that a cause and effect relationship exists is increased when all three types of studies show positive results.

Epidemiological studies

The health effects of exposure to power frequency EMF have been intensively studied for over 25 years. Much of the EMF research, especially in the early years, has focused on epidemiology. In general, these studies can be separated into two major categories: studies focusing on residential exposure and those focusing on occupational exposure.

At the root of the controversy surrounding this issue is the variability of the results. One would expect that with a serious health threat the studies would show a consistent and strong positive association with human health effects. For EMF this has not been the case. While some studies have shown an association, others have not. Overwhelmingly, those studies showing positive associations with human disease have not shown a strong association. In addition, studies with positive results have not always shown an association with the same disease or exposure measurement.

Residential exposure

Early Research

The first epidemiological study to suggest an association between EMF exposure and human health was published in 1979. The Wertheimer/Leeper study looked at birth and death certificates in Denver and related exposure to EMF by using a surrogate instead of actual field measurements. The surrogate measure used is called a “wire code” which classifies power lines in terms of physical size. The physical size of a power line was assumed to be related to the amount of current flowing on the line. It would then follow that large power lines will tend to have higher magnetic fields than smaller power lines. The homes where cases and controls lived were then classified in terms of proximity to high and low current line configurations. This study found an association between high current line configurations and childhood leukemia and reported an Odds Ratio (OR) of 2.35 for leukemia and an OR of 2.22 for all cancers. In 1980, another study, conducted in Rhode Island, was published. This study was similar in design to the Wertheimer/Leeper study. This study found no association between wire codes and leukemia (OR=1.09). Two studies conducted in England in the mid 1980s also found no association between leukemia and other cancers and exposure to power lines. However, a study conducted in Sweden and published in 1986 showed an association between central nervous system cancers (brain cancer) and electric power facilities but no association with leukemia. In 1988, Savitz *et al.* published a study that again looked at cancer and power lines in Denver. This study was the largest up to that time and was designed to eliminate some of the weaknesses found in Wertheimer and Leeper’s 1979 study. This study characterized the residential magnetic field environment by using both wire coding and actual measurement of fields in residences. This study again showed a positive association between childhood leukemia (OR=1.54) and total cancers (OR=1.53) based on a difference between low current and high current power line configurations. These findings, while positive, are generally considered weak associations because the

OR values are well below 3.0. The study found no association between measured magnetic fields and cancer.

In order to have confidence that an exposure agent is actually linked to human disease, scientists look for strong and consistent associations from the epidemiological research. In the case of EMF, the associations, while positive, are not very strong (values for OR or RR are almost always below 3). Secondly, study outcomes are not consistent between studies, with some studies showing weak associations and others showing no association at all. In the case of cigarette smoking, for example, the vast majority of epidemiological studies showed a strong positive association between cigarette smoking and lung, neck, and throat cancer.

Swedish Study — 26 years of data, small population

In addition to looking for consistency between studies, scientists are also interested in consistency of results within studies. An example of conflicting results within a study can be shown by examining research published in 1993 from Sweden. The Swedish study covered approximately 26 years. The researchers used two different measures of EMF exposure. One of the concerns about this study is that the researchers obtained different results depending on which exposure measurement they used. Since EMF measurements were not actually taken over the 26-year period reviewed by the study, the researchers estimated past EMF exposure by calculating the average EMF from power lines. They called this substitute for actual exposure measurements “historical calculated fields.” The other estimates of exposure they used were actual measured magnetic fields recorded during the study.

The study found no relationship between historical calculated fields and central nervous system cancers (brain tumors), lymphoma, or for all childhood cancers combined (including leukemia). They did find “for leukemia in children and exposure defined from historical calculated fields, ...elevated estimated relative risks, which increase with level of exposure.” The RR was estimated at 2.7 and 3.8 depending on the magnetic field cut point used.

However, when they looked at measured magnetic fields, the Swedish scientists found something different. The researchers found no increased risk for leukemia or for all childhood cancers combined but did find an increase in estimated relative risk for central nervous system tumors. For this relationship, however, the increased risk only exists for an intermediate exposure level. Higher or lower levels showed no relationship.

Measured fields did not show any link to leukemia but calculated historical fields did. Actual measurements showed an increased risk for central nervous system tumors but calculated historical fields did not. Another interesting finding was that the increased risk for leukemia only held for single-family homes. It did not hold for apartment buildings.

One concern about the study is the very small number of actual leukemia cases. This study included almost 500,000 people (a little more than 127,000 children) over a period of 26 years. There were a total of 38 childhood leukemia cases for the entire study. Twenty-seven cases occurred in the lowest exposure category and served as the standard to which all other cases were compared. The remaining 11 cases, which lead to the positive findings, were found in two higher exposure groups. While the study design helps limit the effect of small sample sizes, the statistics are still based on very small numbers. This tends to make the results less reliable.

Danish and Finnish Studies — Little leukemia risk

The results from two other epidemiological studies were also released in 1993. These studies, one conducted in Denmark and the other conducted in Finland, were published in the October 1993 edition of the British Medical Journal.

In the Danish study, researchers reported that their results were not fully compatible with the Swedish study. The Danes did not find an increased risk for leukemia but did find some evidence of an effect on a combination of cancers, including central nervous system cancers and lymphoma. However, this finding was at a much higher magnetic field level than identified in the Swedish study. The association between EMF exposure and cancer was very weak because of the small number of actual cases and was considered statistically unstable.

The Danish researchers concluded that, if there is a risk to exposure to magnetic fields, it must be very small. They also pointed out that the incidence rate of leukemia over the last 45 years has changed very little, while electrical consumption in Denmark has increased 30-fold. If EMF causes leukemia, you would expect to see an increase in leukemia that follows the increased use of electricity, but this has not happened.

In the Finnish study, researchers found no increased risk of leukemia, central nervous system cancer, or lymphoma. They also found no increased risk when they combined all cancer types. They concluded that residential magnetic fields from transmission lines do not constitute a major public health problem regarding childhood cancer.

Canadian Studies — previous studies reexamined

Two Canadian studies published in 1999 also show significant inconsistencies between studies. Green, *et. al.* looked at childhood leukemia and EMF exposure in Ontario Canada. Green's study showed an association between contemporary measured fields outside residences and childhood leukemia (RR=3.5). However, there was no association with childhood leukemia for contemporary fields inside residences (RR=1.1). In addition, when using wire codes (as with Wertheimer and Leeper, and Savitz) there was no association with cancer. This study also found a positive association when comparing fields measured with personal monitors and childhood leukemia (RR=2.4). At the same time McBride conducted a much larger study in Ontario. This study found no association with childhood leukemia for personal monitors, contemporary measured fields inside residences, historic magnetic fields or wire codes.

British Journal of Cancer — 2000

In September 2000 a pooled analysis of EMF studies was published in the British Journal of Cancer. The study pooled earlier research conducted in Europe, North America, and New Zealand. This study reported a weak association (RR = 2) between exposure to power frequency magnetic fields greater than 4 mG and childhood leukemia. While the results showed a weak positive association, the authors were careful to point out that selection bias, confounding, and a very small number of leukemia cases in high exposure groups (0.8 percent) could have accounted for some of the elevated risk. They also stated that numerous animal and laboratory studies have failed to show any association between cancer and exposure to EMF.

2005 Draper Study

In 2005 a British study of childhood leukemia and birth addresses within 600 meters of high voltage power lines was published. This study used 9,700 matched case-control pairs for leukemia. Exposure was based on the shortest distance from a power line in the year of birth. This study reported a slight increase in childhood leukemia within 600 meters of a high-voltage transmission line. However, the increase in risk extended out to distances where the magnetic field from the power lines would have been overwhelmed or replaced by ambient magnetic field levels. The authors state in the study:

“Our increased risk seems to extend to at least 200 m, and at that distance typical calculated fields from power lines are <0.1 micro T (<1 mG) and of the <0.01 micro T (<0.1 mG) – that is, less than the average fields in homes from other sources. Thus our results do not seem to be compatible with the existing data... We have no satisfactory explanation for our results in terms of causation by magnetic fields, and the findings are not supported by convincing laboratory data or any accepted biological mechanism.”

2006 Kabuto study

A Japanese study on childhood leukemia and proximity to power lines was published in 2006. This study used exposure assessments and distance from power lines in its evaluation. A pooled analysis of data was used. One limitation of this study was a relatively low response rate. Of the 781 leukemia cases identified, only 40% responded to the request for inclusion in the study. A small increase in risk was detected for leukemia at exposures over 4 mG. However, the importance of this study was limited by the small sample size and a relatively high level of statistical uncertainty.

Continued search for the cause of childhood leukemia

Childhood leukemia is a relatively rare disease and its causes are not well understood despite decades of study. Because scientists studying EMF exposure have found only inconsistent and at best weak associations between exposure and leukemia it is likely that some unidentified confounding factor or factors may be affecting study results. In 1997, a paper published in the *Lancet* proposed the hypothesis that a malfunction in a person's immune response may, for some individuals, lead to leukemia. This malfunction is thought to be related to the rate of early childhood infection. The hypothesis suggests that some children whose immune systems are not sufficiently challenged in early childhood may be predisposed to develop leukemia. To test this hypothesis epidemiological researchers began to look at ways of measuring the rate of early infection in children. Attendance in a day-care facility is one surrogate measure of early childhood infection. Children who begin attending day-care at an early age are exposed to more pathogens than children who remain in the home and so their as yet untested immune systems are challenged and strengthened. Likewise, the amount of time a child is breast-fed would also be related to the health of the child's immune system. If the hypothesis is correct, one would expect a negative correlation between day-care attendance and the occurrence of leukemia. In other words, attendance at a day-care facility and breast-feeding might impart some protection against leukemia.

Some epidemiological studies have shown just such a relationship. A study conducted in France found an inverse relationship between childhood leukemia and early common infections, day-care attendance, and prolonged breast-feeding. Other studies have also suggested some support for the challenged immune system hypothesis.

Some recent studies (2007-2008) have reported a genetic component that appears to be involved in the development of childhood leukemia. Some researchers suspect that the process which leads to childhood leukemia begins during pregnancy with the fusion of two genes into a mutant hybrid. This genetic change can lead to the creation of pre-cancerous stem cells. Those stem cells can develop into malignant stem cells that can lead to the development of cancer. However, not everyone with this genetic mutation will develop leukemia. This important new discovery may significantly increase our understanding of the causes of childhood leukemia and provide new strategies for treatment.

Occupational studies

Epidemiological studies of occupational exposure to EMF suffer from the same general weaknesses affecting residential studies. As a group, the studies show inconsistent results and weak correlations. Early occupational studies reported a higher incidence of some cancers in some electrical occupations. However, many of these studies only used job titles to classify study subjects. No attempt was made to measure exposure to EMF. Since 1994, there have been approximately 17 studies investigating occupational exposure to EMF and cancer. These later studies have also been hampered by an inability to accurately determine historic exposure. Studies generally look at cancer incidence over two or more decades. The actual long-term exposure to EMF for the cases in the study is unknown. As a surrogate for historic exposure many of these studies used short-term (measured exposure during one shift) contemporary EMF measurements for each job classification studied.

Occupational EMF studies have not been consistent in their findings. For example, Sahl *et. al.* studying EMF and cancer in utility workers in the United States, found no association between electrical occupations and the incidence of leukemia, brain cancer, and lymphoma. On the other hand, Theriault *et. al.* studied utility workers from three different utilities in Canada and France. The results showed a weak association between presumed exposure and two types of leukemia with OR values ranging from 2.25 – 3.15. The researchers did report a statistically significant association for acute nonlymphoid leukemia (OR=3.15) but not for chronic lymphoid leukemia. The OR for brain cancers was also weak (1.95) and was not statistically significant. The authors concluded: “Despite the attempts made in this study to achieve adequate power, definitive evidence of an association between exposure to magnetic fields and leukemia and brain cancer has not been obtained.” In another study, Savitz *et. al.* found a very weak association for total mortality and overall cancer mortality with an RR of 1.2 for the group with the highest estimated exposure. Leukemia mortality was not linked with estimated exposure. Brain cancer mortality was elevated, with an RR of 2.6 for the highest exposure category.

In an attempt to make sense of conflicting results from the studies described above, Kheifets *et. al.* conducted a comparative analysis of the three studies (Sahl *et. al.* 1993, Theriault *et. al.* 1994, and Savitz & Loomis. 1995). These studies looked at exposure for workers from a total of nine electric utilities. A combined analysis of the data resulted in an RR of 1.12 for brain cancer and

1.09 for leukemia. The researchers concluded these studies showed only a weak association between magnetic fields and both brain cancer and leukemia.

Biological mechanism

As stated earlier, epidemiological studies, by themselves, cannot be used to prove a cause and effect relationship between exposure and human disease. In addition to epidemiological evidence, scientists need to propose a plausible biological mechanism. The biological mechanism explains how exposure to a suspected agent, such as EMF, might actually cause disease in the human body. Laboratory tests, usually at the cellular level, can then be conducted to test the proposed mechanism. For example, if a suspected agent is believed to cause cancer by affecting a cell's DNA then researchers will expose cells, under strictly controlled conditions, to the agent. Study results that show DNA damage will then lend support to the proposed biological mechanism. Studies of this type need to be repeated a number of times by different researchers in order for scientists to have confidence that a proposed mechanism could actually work under real world conditions.

We know that cancer can be initiated when a cell's DNA is damaged. Agents that cause damage to a cell's DNA are called genotoxins. Certain non-genotoxic substances called epigenetic agents can also contribute to the development of cancer. Epigenetic agents affect carcinogenesis indirectly, by increasing the ability of genotoxins to cause injury to cells. In a paper published in 1998, Moulder reviewed nearly 100 published studies on EMF and carcinogenicity. These studies showed no repeatable evidence that power frequency fields have the potential to either cause or contribute to cancer. Studies showing some evidence of carcinogenic activity evaluated levels of EMF much higher than those associated with power lines.

Power-frequency EMFs are low energy fields. They do not have enough energy to break chemical bonds or to cause mutation in DNA. Power frequency EMF of the type found near transmission lines can induce currents in the body, but these currents are much smaller than the typical electric currents present in the body from biological activity.

Some theories on biological mechanisms suggest that a "resonance mechanism" could overcome biophysical constraints and make cells or organisms sensitive to power frequency EMF. However, scientists reviewing such theories have argued that such a mechanism is highly unlikely. A study in 1987 suggested that "ion cyclotron resonance" could affect a cell's calcium ion uptake and that this might, to some extent, explain the epidemiological associations. Liboff *et. al.* found that exposure to power frequency EMF caused changes in calcium ion uptake of cells. Subsequent studies, however, failed to replicate this effect.

Another theory for a biological mechanism involves the production of the hormone melatonin. It has been hypothesized that exposure to power-frequency EMF might suppress melatonin production and that melatonin might actually have cancer preventative properties. However, three studies on humans found that exposure to both continuous and intermittent fields at levels of 10 mG and 200 mG had no effect on nighttime melatonin production.

Although a number of possible biological mechanisms have been proposed, to date no plausible biological mechanism has been discovered that could explain how exposure to low- energy, power-frequency EMF might cause human disease.

Cosmic radiation, radon, and power lines

In the 1990s two theories were published proposing mechanisms that might explain how exposure to electric power lines might lead to human disease. These theories are based on the idea that power line electric or magnetic fields might focus or attract naturally occurring radiation in quantities large enough to lead to human health effects. If this were true, it might explain the slight increase in risk of childhood leukemia that has been reported in some epidemiological studies.

Cosmic Radiation

In 1992, Anthony Hopwood, an amateur astronomer, published an article in *Electronics World* and *Wireless World* entitled Natural Radiation Focused by Power Lines. Using a homemade radiation detector, Mr. Hopwood took radiation count measurements under and near an 11 kV power line. He reported that the counts varied as he moved away from the line. He recorded a minimum count immediately under the line. The count reached a maximum a few meters away from the centerline but then continued to decrease as he moved further away from the line. Hopwood hypothesized that the power lines somehow “focused” cosmic rays at a certain distance from the line. Exposure to these higher concentrations of cosmic rays might lead to health effects.

Shortly after Hopwood published his theory, England’s National Radiological Protection Board (NRPB) conducted a study to test his hypothesis. Researchers for the NRPB attempted to reproduce Hopwood’s experiment using more sophisticated measuring devices. They took radiation counts at the same 11 kV line tested by Hopwood and at a 440 kV line. They could not duplicate Hopwood’s results and found no significant differences in radiation measurements under or away from the line.

In 1997 and again in 2000, researchers reported additional attempts to duplicate Hopwood’s findings. In both these studies, the researchers concluded that there is little support for Hopwood’s theory that power lines could focus cosmic radiation in such concentrations as to threaten human health. Vistnes *et. al.* measured cosmic radiation under and around a 300 kV and a 420 kV power line. They found small variations in dose rates with distance from the power lines. However, no symmetrical pattern was observed. These researchers concluded that their study did not support the idea that power lines could “focus” cosmic radiation. Skedsmo and Vistnes concluded in their study that Hopwood’s hypothesis “... is neither supported by any experimental observations performed after the original finding, nor by our theoretical analyses. While in theory a small effect of electromagnetic fields on the trajectories of cosmic particles can be demonstrated, our simulations show that the effect is far too small to be of any possible health significance.”

Radon

Radon is an odorless, naturally occurring radioactive gas that comes from the soil. Radon and its radioactive decay products are found in easily measurable concentrations in all outdoor air and in higher concentrations indoors. Studies of tens of thousands of miners exposed to high concentrations of radon and its decay products show that they cause lung cancer. However, these studies found no significant increase in other forms of cancer due to exposure to radon and its decay products. The risk of lung cancer from exposure to radon and radon decay products depends on their concentration in air and the length of time a person is exposed to the radon source.

In 1996 and again in 1999, D. L. Henshaw *et al.* published papers suggesting that the electric fields created by large electric transmission lines could significantly increase the concentration and deposition of radon decay products in the vicinity of power lines. Inhaling the increased concentrations of radon decay products might increase the risk of cancer. This theory is sometimes referred to as the Henshaw hypothesis.

However, other measurement studies have not been able to show that power lines can significantly increase local concentrations of radon. Miles and Algar measured radon decay product concentrations in high and low electric fields created by a high-voltage (400kV) power line. Their results found no significant difference in outdoor radon decay product concentrations between locations with high and low electric fields.

In another study McLaughlin and Gath studied the behavior of airborne radon daughters in the vicinity of a 400 kV power line. They took measurements with the power line on and off. They found that the fields produced by the power line did not concentrate radon decay products under or near the power line. Their study also provided no support for the Henshaw hypothesis.

The Wisconsin Department of Health and Family Services - Radiation Protection Section acknowledges that if radon and radon decay product concentrations increased near power lines, there might be a small increase in the risk of lung cancer for people spending a large amount of time under or very near those lines. However, the increased risk is insignificant compared to the risk from indoor radon levels. Outdoor radon concentrations are about a quarter of average indoor levels. People spend very small amounts of time in a single location outdoors. Studies have shown that on average, people spend 70 percent of their time in their homes. So the increases found by Henshaw do not represent a significant increase in people's total radon exposure.

If the insignificant increases in radon and decay product concentrations suggested by Henshaw were responsible for significant increases in the incidence of leukemia or any other cancer, we certainly would see a more significant incidence of those cancers resulting from radon in homes. There also would have been significant increases in those cancers in the miner studies. In addition, subsequent scientific studies have not confirmed the results of Henshaw's research.

Based on the scientific research to date, and consistent with the assessments of major authoritative groups, the Wisconsin Department of Health and Family Services - Radiation Protection Section believes there is no compelling evidence indicating that power lines increase the risk of any kind of cancer by concentrating radon and radon decay products in their vicinity.

Whole animal studies

Whole animal studies involve subjecting study animals to EMF under strictly controlled conditions. When epidemiological studies suggest associations between exposure agents and disease, whole animal studies are used to determine whether or not exposure does indeed lead to disease. Until recently few studies on animal carcinogenesis and EMF have been conducted.

In 1997 a study conducted by Yasui *et. al.* exposed male and female rats to 50 Hz fields at levels of 5 and 50 Gauss. No effect was found on overall cancer rates or rates of leukemia, lymphoma, brain cancer, and breast cancer. Another 1997 study conducted by Mandeville *et. al.* exposed female rats for two years to 60Hz fields at intensities of 20 mG, 200 mG, 2 Gauss, and 20 Gauss. No effect on survival, or leukemia or solid tumor incidence was found. In 1998, Harris *et. al.* exposed lymphoma-prone mice to 50 Hz fields at 10 mG, 1 Gauss, and 10 Gauss. This study found no effect on lymphoma incidence. The U. S. National Toxicology Program supported studies by McCormick and Boorman *et. al.* These studies showed that mice and rats exposed to power-frequency EMF had no increase in mortality or cancer incidence. Exposure to intermittent (one hour on and one hour off) fields at 60 Hz and 10 Gauss had no effect on overall cancer, leukemia, brain cancer, lymphoma, or breast cancer. A recent study also looked at the impact of EMF exposure on rats with leukemia. This study exposed leukemic rats to 50 Hz fields at 1 Gauss until the test subjects died. Exposure to EMF had no effect on the progression of leukemia.

Overall, whole animal exposure studies conducted to date have not shown evidence that long-term exposure to EMF causes cancer and found no link to leukemia, brain cancer, and breast cancer.

REVIEWS and RECOMENDATIONS

National Research Council EMF Research Review

In 1991, the U.S. Congress requested the National Academy of Sciences to review the literature on the health effects from exposure to EMF. The National Research Council (NRC) was given the task of conducting the review. A 16-member committee composed of scientists and other experts reviewed more than 500 studies spanning 17 years of research. The studies covered a wide range of subject areas including cellular and molecular effects, epidemiology, and animal and tissue effects. Based on this comprehensive evaluation, the committee issued a 314-page report in October 1996. This report concluded that the current body of scientific evidence does not show that exposure to EMF presents a human health hazard. No conclusive or consistent evidence has shown that exposure to residential EMF produces cancer, neurobehavioral problems, or reproductive and development effects. The NRC review did not cover occupational exposure studies.

EMF research and public information dissemination program

In 1992, the National Energy Policy Act established a federal scientific and engineering research program to study EMF. This program is called the EMF Research and Public Information Dis-

semination (RAPID) Program. The National Institute of Environmental Health Sciences (NIEHS) is charged with evaluating the human health effects of exposure to EMF. In June 1998, a scientific working group, established to advise the NIEHS, issued a report recommending that EMF be classified as a Class 2B possible carcinogen using a classification system developed by the International Agency for Research on Cancer (IARC). This is not a determination of carcinogenicity. In the IARC classification system, a substance must be placed in Class 2B if there is inadequate epidemiological evidence and insufficient animal data supporting carcinogenicity. The report states in its conclusion:

“The NIEHS believes that the probability that ELF-EMF exposure is truly a health hazard is currently small. The weak epidemiological associations provide only marginal, scientific support that exposure to this agent is causing any degree of harm. The NIEHS concludes that ELF-EMF exposure cannot be recognized as entirely safe because of weak scientific evidence that exposure may pose a leukemia hazard. In our opinion, this finding is insufficient to warrant aggressive regulatory concern.”

The NIEHS continues to study and evaluate EMF, but the scientific support for a serious health risk is very small, even after two decades of research.

National radiation protection board report—2001

In early March of 2001, England’s National Radiological Protection Board (NRPB) issued a report on power frequency magnetic fields. The report is a comprehensive review of epidemiological and experimental studies on exposure to power frequency magnetic fields and human disease. The report concluded that at a cellular level, there is no clear evidence of power frequency EMF affecting biological processes. Animal studies of carcinogenesis also provide no support for power frequency EMF causing cancer. This includes studies of leukemia, lymphoma, brain cancers, and tumors in general. Studies of impacts on melatonin showed no changes in the timing and production of melatonin in human test subjects. In addition, the report stated that there was no evidence of any EMF link to breast cancer or to negative effects on the immune system.

The NRPB report also reviewed epidemiological studies and concluded that there is no evidence linking EMF to cancers in general or leukemia in adults. In its conclusion the report states: “In the absence of clear evidence of a carcinogenic effect in adults, or of a plausible explanation from experiments on animals or isolated cells, the epidemiological evidence is currently not strong enough to justify a firm conclusion that such fields cause leukemia in children.” While the NRPB advisory group recognized that the scientific evidence associating exposure to power frequency EMF and health effects is very weak it also suggested that there remains a possibility of a small risk of leukemia in children under the age of 15. As a result, the NRPB recommended the continued study of exposure to children.

Summary

Many scientists believe the potential for health risks for exposure to EMF is very small. This is supported, in part, by weak epidemiological evidence and the lack of a plausible biological mechanism that explains how exposure to EMF could cause disease. The magnetic fields produced by electricity are weak and do not have enough energy to break chemical bonds or to cause mutations in DNA. Without a mechanism, scientists have no idea what kind of exposure,

if any, might be harmful. In addition, whole animal studies investigating long-term exposure to power-frequency EMF have shown no connection between exposure and cancer of any kind.

While scientific consensus appears to be forming, there are still some unanswered questions about EMF exposure and human health. The Commission will continue to consider EMF in its power line siting decisions. But the Commission must balance the likelihood of health effects from exposure to power line EMF with issues of need, cost, and environmental impact. The PSC will base its EMF policy on a continuing review of scientific research.

2002 Report from the State of California

In response to a California Public Utilities Commission request, three scientists from the California Department of Health Services reviewed the studies related to possible health problems from exposure to EMF created by power lines, wiring in homes and businesses, and appliances. This panel's conclusions differed from the conclusions of other review panels (NIEHS, IARC, and the NRPB) by expressing a greater belief that exposure to EMF may lead to some degree of increased risk for certain diseases. The report's major conclusions are:

- To one degree or another, all three of the DHS scientists are inclined to believe that EMFs can cause some degree of increased risk of childhood leukemia, adult brain cancer, Lou Gehrig's Disease, and miscarriage.
- They strongly believe that EMFs do not increase the risk of birth defects, or low birth weight.
- They strongly believe that EMFs are not universal carcinogens, since there are a number of cancer types that are not associated with EMF exposure.
- To one degree or another they are inclined to believe that EMFs do not cause an increased risk of breast cancer, heart disease, Alzheimer's Disease, depression, or symptoms attributed by some to a sensitivity to EMFs. However,
- All three scientists had judgments that were "close to the dividing line between believing and not believing" that EMFs cause some degree of increased risk of suicide,
- For adult leukemia, two of the scientists are "close to the dividing line between believing or not believing" and one was "prone to believe" that EMFs cause some degree of increased risk.

The reviewers were asked to express in numbers their individual professional judgments that the range of added personal risks suggested by the epidemiological studies were "real." They did this as a numerical "degree of certainty" on a scale of 0 to 100. For two of the reviewing scientists the degree of certainty for some of their conclusions was quite large, indicating a weakness in their positive conclusions.

An internal Electric and Magnetic Field Scientific Advisory Panel (SAP) reviewed the final California report. This review panel wrote:

"The panel all agreed that the conclusions were logically supported within the range of reasonable scientific discourse... But there was consensus among the

SAP members that different evaluators with the same or different professional backgrounds may use the DHS guidelines and arrive at different numerical confidence estimates, perhaps substantially different... All three evaluators were primarily epidemiologists... Based on a sample of only three evaluators sharing a similar professional background, the conclusions drawn by these evaluators might not generalize to those from other professions.”

While the California report should not be discounted, its weaknesses must be acknowledged in the light of the conclusions reached by other review panels.

2002 report from the International Agency for Research on Cancer (IARC)

In 2002 The IARC released its report on EMF (Static and Extremely Low-frequency (ELF) Electric and Magnetic Fields). The IARC reviewed the available scientific evidence to date and reached largely the same conclusions found in the NIEHS review of magnetic fields. This report did not find reliable and consistent evidence to implicate exposure to EMF with increased risk for adult cancers or reproductive effects. However, the study also concluded that:

“The association between childhood leukemia and high levels of magnetic fields is unlikely to be due to chance, but it may be affected by bias. In particular, selection bias may account for part of the association.... It cannot be excluded that a combination of selection bias, some degree of confounding and chance could explain the results. If the observed relationship were causal, the exposure-associated risk could also be greater than what is reported.”

The IARC did classify low frequency EMF as a Class 2B carcinogen because of the lingering concern regarding childhood leukemia. Agents listed in Class 2B are considered possible carcinogens as opposed to Class 1 – definitely a carcinogen, and Class 2A – a probable carcinogen. For agents in Class 2B there is limited epidemiological evidence plus limited or inadequate evidence from animal tests. Class 2B agents include automobile exhaust, coffee, and pickled vegetables.

2007 World Health Organization (WHO) – Environmental Health Criteria (EHC) Monograph 238 – Extremely Low Frequency Fields (0-100 kHz)

The WHO monograph on extremely low frequency (ELF) electric and magnetic fields reviewed the scientific literature on exposure to ELF fields and the potential for human health impacts. The report evaluated biophysical mechanisms, neurobehavior, potential effects on the neuroendocrine system, neurodegenerative disorders, cardiovascular disorders, the immune system, reproduction and development, and cancer.

Biophysical Mechanisms:

The report reviewed scientific work on explaining the biological mechanism by which exposure to ELF fields might cause human health impacts. The biological mechanisms reviewed in this

report included direct biophysical interactions with fields. These included: breaking of chemical bonds, effects on charged particles, and narrow bandwidth or the “resonance” mechanism. The scientific evidence did not find plausible support for these mechanisms. (See page 12 for a discussion on biological mechanisms). In addition, other possible mechanisms such as neural response, radical pair, and effects on magnetite in the brain were found to be implausible.

Possible Health Effects:

The review found that scientific evidence did not support a link between ELF magnetic fields and health effects resulting in impacts to neurobehavior (hypersensitivity, depression, and insomnia), the endocrine system, neurodegenerative disease (ALS and Alzheimer’s), cardiovascular disorders, human reproduction, or the immune system. In general, studies exploring these areas of human health were inconclusive, inconsistent, or showed no support at all for health impacts.

Cancer and Childhood Leukemia:

For cancer studies, the WHO review incorporated the IARC 2002 conclusions (See above). In addition, the WHO reviewed studies conducted since the IARC released its scientific review in 2002. In terms of adult cancers, the review concluded that a consistent association between exposure to power frequency magnetic fields and adult leukemia or brain cancer has not been established.

Since the IARC review, two major epidemiological studies on childhood leukemia have been published: the Draper and Kabuto studies. (See page 9) These studies were added to the WHO epidemiological review.

The WHO review concluded that studies on the effects of ELF magnetic fields on cells have shown no evidence of genotoxicity. In addition, studies on cell proliferation, calcium signaling, intercellular communication, heat shock protein expression, and malignant transformation have not yielded positive results linking ELF exposure to changes in cellular function.

Overall, in terms of effects on the occurrence of cancer including childhood leukemia, the WHO report did not find any overwhelming evidence that would change the conclusions of the IARC 2002 report. While some concern remains, the continued lack of support from whole animal studies and a continued inability to explain the mechanism by which disease may be caused by low level ELF exposure continues to temper the final scientific judgment. The report’s final conclusion on health risk for childhood leukemia states:

“Consistent epidemiological evidence suggests that chronic low-intensity ELF magnetic field exposure is associated with an increased risk of childhood leukemia. However, the evidence for a causal relationship is limited, therefore exposure limits based upon epidemiological evidence are not recommended, but some precautionary measures are warranted.”

Pacemakers and Defibrillators—Electromagnetic Interference

Implantable medical devices are becoming increasingly common. Two such devices, pacemakers and implantable cardioverter defibrillators (ICDs), have been associated with problems arising from interference caused by magnetic and electric fields. This type of interference is often termed electromagnetic interference or EMI. EMI can cause inappropriate triggering of a device or inhibit the device from responding appropriately. Sources of EMI have been documented by medical personnel and include radio-controlled model cars, slot machines, car engines, digital cellular phones, anti-theft security systems, certain procedures conducted in a hospital environment including radiation therapy, and high-voltage electrical systems and devices. It has been estimated that up to 20 percent of all firings of ICDs are inappropriate, but only a very small percentage of those are caused by external electromagnetic interference.

Modern implantable devices are very sophisticated and are capable of a wide variety of tasks and functions.

Pacemakers and ICDs perform different tasks within the body. Pacemakers are designed to provide the heart with the appropriate electrical signal needed to stimulate regular contractions. Pacemakers are programmable and can function in a number of different modes. Commonly, pacemakers exposed to electromagnetic interference of sufficient size and frequency will revert to what is called an asynchronous mode pacing. Once the interference is removed, the pacemaker returns to its normal operating parameters. Asynchronous mode is not life threatening and will not harm a patient. However, a serious situation might occur if external electromagnetic interference is large enough to “trick” the pacemaker circuitry into interpreting the interference as normal heart behavior but is not large enough to trigger asynchronous mode. In that case, the pacemaker would be inhibited from firing and would not respond appropriately to a slow heart rate or cardiac insufficiency. This could result in a serious health threat.

Defibrillators or ICDs detect when ventricular fibrillation occurs and will then administer a shock to the heart to reestablish a normal heart rhythm. In certain circumstances it is possible for EMI to mimic electrical signals that the ICD interprets as fibrillation. In this case the ICD can inappropriately deliver a shock to the heart. This type of response has been reported in a case of prolonged exposure to fields generated by an antitheft device in the doorway of a store.

A number of researchers, primarily in England, have studied the behavior of implantable cardiac devices exposed to 50 Hz high-voltage electrical systems. The researchers found that exposure to electric fields can induce currents in the body that can interfere with the proper operation of pacemakers and ICDs. The results from these studies can be somewhat confusing because responses to electric fields will vary depending on the manufacturer and model of the devices studied. In addition, the physical attributes of study subjects, the degree of grounding, and their location (i.e. their physical orientation in space with respect to the electric field) all have an impact on the amount of body current induced and how the implanted device responds.

The first study of power-frequency EMI and implantable cardiac devices was published in 1983 by Butrous *et. al.* This study examined 35 patients with pacemakers. The pacemakers included 16 different models from 6 manufacturers. The patients were exposed to electric fields in the air

that varied from 1 kV/m to 20 kV/m. These fields induced body currents of between 10 and 337 microamperes (μA). The study showed a clear linear relationship between electric field intensity and body currents. The researchers identified four device responses to the EMI: (1) normal sensing and pacing in some units; (2) reversion to the fixed (asynchronous) rate in other units; (3) slow and irregular pacing in several units; (4) mixed behavior over a specific range of field strengths in which slow and irregular pacing preceded reversion to asynchronous or fixed rate pacing.

Reversion to asynchronous pacing occurred in 18 test subjects. This condition is generally not life threatening; the physiologic responses of patients ranged from no noticeable difference in physical well-being to a sense of discomfort or dizziness. In this study, seven of the 18 patients experiencing reversion to asynchronous pacing reported being aware of competitive pacing and described the sensation as very uncomfortable. One patient experienced dizziness. In addition, some studies have indicated that there is a small possibility that reversion to asynchronous pacing could lead to dangerous arrhythmias.'

In the Butrous study, pacemaker responses depended on the magnitude and distribution of induced body current relative to the pacemaker as well as field strength. The threshold at which an implantable device responded to an external EMI varied for each unit depending on the make and model of the device and the patient height, build, and posture (physical orientation with respect to the electric field). The results showed a wide range of responses. For example, each of the units from one manufacturer reverted to asynchronous mode at widely different body currents (37, 46, 55, and $70\mu\text{A}$). Electric currents in the range of 2-5 kV/m can cause body currents of this magnitude.

In 1988, Kaye *et. al.* studied 28 patients with pacemakers and temporary transvenous electrodes. This study induced body currents into patients in order to simulate exposure to electric fields. The minimum current producing inappropriate pacing varied widely among different pacemakers ranging from 27-246 μA . Using the linear relationship between body currents and electric fields demonstrated by Butrous *et. al.* in their 1983 study, it can be inferred that the most sensitive pacemaker studied by Kaye could have malfunctioned when exposed to a 50 Hz electric field of 1.5-2.0 kV/M. The least sensitive pacemakers would not have shown inappropriate behavior until electric fields reached nearly 20 kV/m. In this study three Medtronic pacemakers did not exhibit inappropriate behavior and were unaffected by body currents up to 600 μA .

Astridge *et. al.* exposed 22 patients with implanted dual pacemakers to body currents. Patients were selected with programmable pacemakers with interchangeable lead configurations. In all, pacemakers from four manufacturers (five different models) were studied. Because the pacemakers all had interchangeable lead configurations, the researchers were able to study differences in pacemaker behavior between monopolar and bipolar configurations. With the exception of one manufacturer (Medtronic), all pacemakers eventually malfunctioned when exposed to 50 Hz current. Dual chamber pacemakers with a monopolar lead configuration were considerably more sensitive to induced 50 Hz body currents. Inappropriate operation for dual chamber pacemakers, configured with the atrial lead monopolar, occurred for body currents ranging from 10-80 μA (electric fields in the range of 1.5-4 kV/m could, under proper conditions, induce similar body currents). For pacemakers with the ventricular lead monopolar, the onset of inappropriate behavior occurred over a range of from 40-120 μA of induced body current (3-12 kV/m).

Toivonen *et. al.* studied the behavior of pacemakers for 15 patients using 12 different models of pacemakers from four manufacturers. This study exposed patients to 50 Hz, 110 kV and 400 kV high-voltage power lines. As with other studies the results varied considerably among type and model. Results showed that for pacemakers programmed to a normal sensitivity (monopolar mode) the earliest evidence of pacing abnormalities occurred for one pacemaker in areas with electric fields ranging from 1.2 to 1.7 kV/m (near the 110 kV power line). Five pacemakers showed signs of inhibition and six signs of premature pacing when exposed to areas with electric fields in the 7 to 8 kV/m range (near the 400 kV power line). Considerable variability was found among pacemaker models. Some pacemakers maintained normal function even in 8 kV/m fields.

The effects of exposure to high-voltage power systems will vary between individual and make and model of pacemaker or ICD. Electric fields appear to be the most likely source of interference. Magnetic field levels that may cause problems with pacemakers and ICDs are generally very large. Technical data from Medtronic (a major manufacturer of pacemakers and ICDs) recommend a threshold of 1 gauss for modulated magnetic fields. This threshold level is 5 to 10 times greater than the magnetic fields likely to be produced by a high voltage power line. Electric fields, however, may be more problematic. Medtronic recommends a “two to three foot distance from the pacemaker to high voltage lines for every 10,000 volts.” Electric fields below 6 kV/m will not interfere with Medtronic ICDs.

Power lines are only one of a number of potential EMI sources that people are exposed to in their daily lives. Some examples of common sources of EMI include cellular phones, the ignition system of internal combustion engines (cars, lawnmowers, and chainsaws), slot machines, and anti-theft devices found in many retail stores. All pacemaker and ICD patients are informed of the potential problems associated with exposure to EMI and must adjust their behavior accordingly. Moving away from a source is a standard response to the effects of exposure to EMI. Electric fields are also relatively easy to shield. Buildings, cars, or the enclosed cab of a truck or tractor should provide ample shielding from external electric fields.

Reducing EMF Levels from Power Lines

Low-EMF pole design

A common method to reduce EMF is to bring the lines (conductors) closer together. This reduces the magnetic fields created by each of the three conductors because the fields interfere with one another. The overall effect is to reduce the total EMF coming from the line. There are practical limits to how close together conductors can be placed. Conductors must be far enough apart so that arcing cannot occur and so that utility employees can safely work around them.

The benefit of using a structure design that reduces EMF will diminish as you move away from the power line. Generally, EMF levels for most modern transmission pole designs are nearly the same at a distance of between 150 to 200 feet.

Magnetic fields can also be reduced with a double-circuit pole. A double-circuit pole has two circuits on one structure. When a double circuit is built, the magnetic fields from each of the phase conductors will interact with one another. This often results in a reduction in magnetic

fields over what would be experienced with just one transmission line in place. In addition, double-circuit poles are often taller and therefore raise the wires farther overhead.

Disadvantages of low-EMF poles

The closer the conductors are to one another, the shorter the distance between poles. This means that a power line using low-EMF poles will tend to have more poles per mile. Increasing the number of poles increases the cost of the line. It may also increase environmental impacts. For example, using more poles may make farming more difficult.

Why don't the utilities use low-EMF poles for all their projects?


- Using all low-EMF poles usually increases the total cost of the project because there are more poles per mile.
- Other types of construction may be necessary to reduce environmental impacts. For example, poles capable of supporting the conductors over larger spans can be used to cross rivers, small wetlands, or farm fields.

Figure 3 compares magnetic fields between a low-EMF pole (V-string design) and a higher EMF pole (Davit Arm design). At 150 feet, the magnetic fields are very nearly the same for each structure. In this example, it would seem reasonable to use low-EMF poles when the line is within 150 feet of a residence, school, or hospital. However, the extra cost would not be justified if the line were further than 150 feet from these buildings because it would not reduce exposure to the inhabitants.

Underground lines decrease magnetic fields

Analysis shows that underground power lines, especially on transmission systems, reduce magnetic fields. Underground lines bring the conductors closer together than is possible with an overhead line. While the magnetic field directly over an underground transmission line can be very high, the closeness of the conductors increases the cancellation effect. This means that the magnetic fields from an underground line will diminish much more rapidly with distance from the line. A study conducted by the State of Rhode Island indicated that at a distance of as little as 25 feet, an underground transmission line can reduce EMF by more than 99 percent when compared to overhead lines.

Figure 3 EMF for two types of transmission structures



Today, some high voltage transmission lines in heavily developed urban areas are built underground. This is because adequate clearances may not be possible for overhead lines on congested city streets. Typically, lines are buried 3.5 to 4 feet deep.

Some problems with underground transmission lines:

- They are more expensive. Because there are many project specific variables that affect the cost of any transmission line, the relative difference in cost between overhead and underground construction can vary. In most cases, however, underground construction costs range between four and ten times more than equivalent overhead construction costs. Occasionally unusual circumstances, (i.e., an underground crossing of a major river with a high capacity line), could drive costs higher than ten times overhead construction.
- While outages are rare, they are difficult and time-consuming to repair, possibly resulting in longer power outages.
- They can cause serious environmental problems, depending on their location. (Buried cables require digging trenches which disturbs the soil. Oil-filled cables present the danger of fluid leaks that can result in soil and water contamination.)

Commission Activity

Orders to the Wisconsin utilities

Since 1989, the Commission has periodically reviewed the science on EMF and has held hearings (as part of its Advance Plan process) to consider the topic of EMF and human health effects. The most recent hearings on EMF were held in July 1998. As a result of these hearings, the Commission has ordered Wisconsin utilities to:

- Contribute to the national EMF research effort.
- Provide information to the public on EMF, perform EMF measurements for customers upon request, and develop (with Commission staff guidance) a uniform EMF measurement protocol.
- Evaluate and include information on how magnetic fields differ for alternative power line configurations in construction applications.
- Consider the number of persons exposed to EMF along proposed transmission line routes and the intensity and duration of exposure.
- Submit a list of homes, workplaces, hospitals, nursing homes, day-care centers, and schools near proposed and alternate transmission line routes.

Certification requirements for construction projects

Magnetic field estimates for proposed utility projects

A utility must provide information on EMF when it applies to the Commission for permission to build a transmission line. Each application must include estimates of the magnetic field created by the proposed new line. Utility engineers calculate the EMF for any given voltage, pole design, and current flow based on criteria established by Commission staff.

The Commission requires utilities to provide information about the types of buildings along any route: residences, hospitals, nursing homes, day-care centers, schools, and workplaces. In its application, a utility must report the number and type of buildings within 300 feet of a proposed centerline. EMF fields also calculated out to a minimum of 300 feet. In situations where a proposed line would replace an existing line or be built as a double circuit with an existing line, the utility is also required to provide estimates of the magnetic fields that are being produced by the existing facility. During the review process, Commission staff calculates the changes in EMF levels likely to occur as a result of the new line. Estimates are created for a new line using the expected loads (current flow) at the time the line would go into service and for estimated loads ten years in the future.

Commission staff checks the utility's calculations of the estimated magnetic fields and then analyzes each route for potential exposure to magnetic fields. This information is then provided to the public and considered in route selection decisions made by the Commission. When selecting transmission line routes, the Commission seeks to balance environmental and social impacts with need, performance, and cost.

The Public Service Commission of Wisconsin is an independent state agency that oversees more than 1,100 Wisconsin public utilities that provide natural gas, electricity, heat, steam, water and telecommunication services.



Public Service Commission of Wisconsin

P.O. Box 7854

Madison, WI 53707-7854

Telephone: 608-266-5481

Toll free: 888-816-3831

Consumer affairs: 608-266-2001 / 800-225-7729

TTY: 608-267-1479 / 800-251-8345

Fax: 608-266-3957

Website: <http://psc.wi.gov>

Electric12 (10/10)

Appendix I – Agricultural Mitigation Plan

AGRICULTURAL IMPACT MITIGATION PLAN
CapX2020 345 kV Electric Transmission Projects in Minnesota

CapX2020

June 2009

AGRICULTURAL IMPACT MITIGATION PLAN

CapX2020

Table of Contents

Purpose.....	1
General Provisions	2
Mitigative Actions	3
1. Pole Placement.....	3
2. Soil and Rock Removal for Bored Holes.....	3
3. Damaged and Adversely Affected Tile.....	3
4. Installation of Additional Tiles	4
5. Construction Debris	4
6. Compaction, Rutting, Fertilization, Liming, and Soil Restoration	4
7. Damaged Soil Conservation Practices	5
8. Weed Control	5
9. Irrigation Systems	5
10. Temporary Roads.....	5
11. Construction in Wet Conditions.....	6
12. Procedures for Determining Construction-Related Damages and Providing Compensation	6
13. Advance Notice of Access to Private Property	6
14. Role and Responsibilities of Agricultural Monitor.....	6
15. Qualifications and Selection of Agricultural Monitor	7
16. Role of the Utilities Inspector	7
Appendix A: Definitions.....	A-1
Appendix B: Mitigative Actions for Organic Agricultural Land.....	B-1

AGRICULTURAL IMPACT MITIGATION PLAN

CapX2020

Purpose

This Agricultural Impact Mitigation Plan ("AIMP" or 'the plan') was developed by Northern States Power Company, a Minnesota corporation and wholly-owned subsidiary of Xcel Energy Inc., and Great River Energy, a Minnesota generation and transmission cooperative (together, referred to as "the Utilities"), representing the CapX2020 utility consortium and with the Minnesota Department of Agriculture ("MDA"). The overall objective of this AIMP is to identify measures the Utilities will take to avoid, mitigate, repair and/or provide compensation for impacts that may result from 345 kV electric transmission line construction of the CapX2020 projects on Agricultural Land in Minnesota.

CapX2020 ("CapX2020") is a joint initiative of 11 transmission-owning utilities in Minnesota and the surrounding region. The purpose of CapX2020 is to study, develop, permit and construct electric transmission infrastructure as needed to implement long-term and cost-effective solutions for customers to meet the growth in energy use expected by the year 2020. The three CapX2020 projects included in this AIMP are described as:

- 1) the 345 kV transmission line from Brookings County, South Dakota to Hampton, Minnesota;
- 2) the 345 kV transmission line from Monticello, Minnesota to St. Cloud to the Fargo area, North Dakota; and
- 3) the 345 kV transmission line from Hampton, Minnesota to Rochester to La Crosse, Wisconsin.

Collectively, these three transmission lines are referred to as the "CapX2020 Projects".

The construction standards and policies in this plan apply only to construction activities occurring partially or wholly on privately owned Agricultural Land. The measures do not apply to construction activities occurring entirely on public rights-of-way, railroad rights-of-way, publicly owned land, or private land that is not Agricultural Land. The Utilities will, however, adhere to the same construction standards relating to the repair of agricultural tile (Item No. 3 in the AIMP) when Tiles are encountered on public highway rights-of-way, railroad rights-of-way, or publicly or privately owned land.

Appendix B of this AIMP applies only to Organic Agricultural Land as described in the National Organic Program Rules, 7 CFR Parts 205.100, 205.202, and 205.101.

Unless the Easement or other agreement, regardless of nature, between the Utilities and the Landowner or Tenant specifically provides to the contrary, the mitigative actions specified in the construction standards and policies set forth in this AIMP will be implemented in accordance with the General Provisions.

General Provisions

The mitigative actions are subject to change by Landowners or Tenants, provided such changes are negotiated with and acceptable to the Utilities.

Certain provisions of this AIMP require the Utilities to consult with the Landowner and Tenant of a property. The Utilities will engage in a good faith effort to secure the agreement of both Landowner and Tenant in such cases.

Unless otherwise specified, the Utilities will retain qualified contractors to execute mitigative actions. However, the Utilities may negotiate with Landowners or Tenants to carry out the mitigative actions that Landowners or Tenants wish to perform themselves.

Mitigative actions employed by the Utilities pursuant to this AIMP, unless otherwise specified in this AIMP or in an Easement or other agreement negotiated with an individual Landowner or Tenant, will be implemented within 45 days following completion of Final Clean-up on an affected property, weather permitting, or unless otherwise delayed by mutual agreement between Landowner or Tenant and Utility. Temporary repairs will be made by the Utilities during construction as needed to minimize the risk of additional property damage or interference with the Landowner's or Tenant's access to or use of the property that may result from an extended time period to implement mitigative actions.

The Utilities will implement the mitigative actions contained in this AIMP to the extent that they do not conflict with the requirements of any applicable federal and/or state rules and regulations and other permits and approvals that are obtained by the Utilities for the project or they are not determined to be unenforceable by reason of other requirements of federal and state permits issued for the project. To the extent a mitigative action required by this agreement is determined to be unenforceable in the future due to requirements of other federal or state permits issued for the project, the Utilities will so inform the Landowner or Tenant and will work with them to develop a reasonable alternative mitigative action.

Prior to the construction of the transmission line, the Utilities will provide each Landowner and Tenant with a telephone number and address which can be used to contact the Utilities, both during and following the completion of construction, regarding the agricultural impact mitigation work which is performed on their property or other construction-related matter. If the contact information changes at any time before completion of Final Clean-up and/or after the completion of construction, the Utilities will provide the Landowner and Tenant with updated contact information. The Utilities will respond to Landowner and Tenant telephone calls and correspondence within a reasonable time.

The Utilities will use good faith efforts to obtain a written acknowledgement of completion from each Landowner and Tenant upon the completion of Final Clean-up on their respective property.

If any provision of this AIMP is held to be unenforceable, no other provision will be affected by that holding, and the remainder of the AIMP will be interpreted as if it did not contain the unenforceable provision.

Mitigative Actions

The Utilities will reasonably restore or compensate Landowners and/or Tenants, as appropriate, for damages caused by the Utilities as a result of transmission line construction, and as outlined in this plan. The decision to restore land or compensate Landowners will be made by the Utilities after discussion with the Landowner or Tenant.

1. Pole Placement

During the design of the project, the Utilities' engineering, land rights and permitting staff will work together to address pole placement issues. Utilities' staff will work with Landowners on pole placement. When the preliminary design is complete, the land rights agents will review the staked pole locations with the Landowners.

2. Soil and Rock Removal for Bored Holes

Any excess soil and rock will be removed from the site unless otherwise requested by the Landowner.

3. Damaged and Adversely Affected Tile

The Utilities will contact affected Landowners or Tenants for their knowledge of Tile locations prior to the transmission line's installation. Utilities will make every attempt to probe for Tile if the Landowner does not know if Tile is located in the proposed pole location. Tile that is damaged, cut, or removed as a result of this probe will be immediately repaired. The repair will be reported to the Inspector.

If Tile is damaged by the transmission line installation, the Tile will be repaired in a manner that restores the Tile's operating condition at the point of repair. If Tiles on or adjacent to the transmission line's construction area are adversely affected by the construction of the transmission line, the Utilities will take such actions as are necessary to restore the functioning of the Tile, including the relocation, reconfiguration, and replacement of the existing Tile. The affected Landowner or Tenant may elect to negotiate a fair settlement with the Utilities for the Landowner or Tenant to undertake the responsibility for repair, relocation, reconfiguration, or replacement of the damaged Tile. In the event the Landowner or Tenant chooses to undertake the responsibility for repair, relocation, reconfiguration, or replacement of the damaged Tile, the Utilities will not be responsible for correcting Tile repairs after completion of the transmission line (the Utilities are responsible for correcting Tile repairs after completion of the transmission line, provided the repairs were made by the Utilities or their agents or designees).

Where the damaged Tile is repaired by the Utilities, the following standards and policies will apply to the Title repair:

- A. Tiles will be repaired with materials of the same or better quality as that which was damaged.

- B. If water is flowing through a damaged Tile, temporary repairs will be promptly installed and maintained until such time that permanent repairs can be made.
- C. Before completing permanent Tile repairs, Tiles will be examined within the work area to check for Tile that might have been damaged by construction equipment. If Tiles are found to be damaged, they will be repaired so they operate as well after construction as before construction began.
- D. The Utilities will make efforts to complete permanent Tile repairs within a reasonable timeframe after Final Clean-up, taking into account weather and soil conditions.
- E. Following completion of the Final Clean-up and damage settlement, the Utilities will be responsible for correcting and repairing Tile breaks, or other damages to Tile systems that are discovered on the Right-of-Way to the extent that such breaks are the result of transmission line construction. These damages are usually discovered after the first significant rain event. The Utilities will not be responsible for Tile repairs the Utilities have paid the Landowner or Tenant to perform.

4. Installation of Additional Tiles

The Utilities will be responsible for installing such additional Tile and other drainage measures as are necessary to properly drain wet areas on the Right-of-Way caused by the construction of the transmission line.

5. Construction Debris

Construction-related debris and material which are not an integral part of the transmission line, and which have been placed there by the Utilities, will be removed from the Landowner's property at the Utilities' cost. Such material to be removed would include excess construction materials or litter generated by the construction crews.

6. Compaction, Rutting, Fertilization, Liming, and Soil Restoration

- A. Compaction will be alleviated as needed on Cropland traversed by construction equipment. Cropland that has been compacted will be plowed using appropriate deep-tillage and draft equipment. Alleviation of compaction of the topsoil will be performed during suitable weather conditions, and must not be performed when weather conditions have caused the soil to become so wet that activity to alleviate compaction would damage the future production capacity of the land as determined by the Agricultural Monitor.
- B. The Utilities will restore rutted land to as near as practical to its pre-construction condition.
- C. If there is a dispute between the Landowner or Tenant and the Utilities as to what areas need to be ripped or chiseled, the depth at which compacted areas should be

ripped or chiseled, or the necessity or rates of lime, fertilizer, and organic material application, the Agricultural Monitor's opinion will be considered by the Utilities.

7. Damaged Soil Conservation Practices

Soil conservation practices such as terraces and grassed waterways which are damaged by the transmission line's construction, will be restored to their pre-construction condition.

8. Weed Control

On land which is owned by Utilities for substation facilities, the Utilities will work with Landowners if requested on weed control activities outside of the substations with the intent to not allow the spread of weeds onto adjacent Agricultural Land. Any weed control spraying will be in accordance with State of Minnesota regulations.

9. Irrigation Systems

- A. If the transmission line and/or temporary work areas intersect an operational (or soon to be operational) spray irrigation system, the Utilities will establish with the Landowner or Tenant, an acceptable amount of time the irrigation system may be out of service.
- B. If, as a result of the transmission line construction activities, an irrigation system interruption results in crop damages, either on the Right-of-Way or off the Right-of-Way, compensation of Landowners and/or Tenants, as appropriate, will be determined as described in section 11 of this AIMP.
- C. If it is feasible and mutually acceptable to the Utilities and the Landowner or Tenant, temporary measures will be implemented to allow an irrigation system to continue to operate across land on which the transmission line is also being constructed. Utilities will work with the Landowner or Tenant to identify a preferable construction time.

10. Temporary Roads

The location of temporary roads to be used for construction purposes will be discussed with the Landowner or Tenant.

- A. The temporary roads will be designed so as to not impede proper drainage and will be built to mitigate soil erosion on or near the temporary roads.
- B. Upon abandonment, temporary roads may be left intact through mutual agreement of the Landowner or Tenant and the Utilities unless otherwise restricted by federal, state or local regulations.

- C. If a temporary road is to be removed, the Agricultural Land upon which the temporary road is constructed will be returned to its previous use and restored to equivalent condition as existed prior to their construction.

11. Construction in Wet Conditions

If it is necessary to construct during wet conditions, and if the Agricultural Monitor believes conditions are too wet for continued construction, damages which may result from such construction will be paid for by the Utilities and/or appropriate restoration will be conducted. Compensation for Landowners and/or Tenants, as appropriate, will be determined as described in section 12 of this AIMP.

12. Procedures for Determining Construction-Related Damages and Providing Compensation

- A. The Utilities will develop and put into place a procedure for the processing of anticipated Landowners' or Tenants' claims for construction-related damages. The procedure will be intended to standardize and minimize Landowner and Tenant concerns in the recovery of damages, to provide a degree of certainty and predictability for Landowners, Tenants and the Utilities, and to foster good relationships among the Utilities, Landowners and their Tenants over the long term.
- B. Negotiations between the Utilities and any affected Landowner or Tenant will be voluntary in nature and no party is obligated to follow any particular method for computing the amount of loss for which compensation is sought or paid. The compensation offered is only an offer to settle, and the offer shall not be introduced in any proceeding brought by the Landowner or Tenant to establish the amount of damages the Utilities must pay. In the event the Utilities and a Landowner or Tenant are unable to reach an agreement on the amount of damages, the Landowner or Tenant may seek recourse through mediation.

13. Advance Notice of Access to Private Property

The Utilities will endeavor to provide the Landowner and/or Tenant advanced notice before beginning construction on the property. Prior notice will consist of a personal contact, email, letter or a telephone contact, whereby the Landowner and the Tenant are informed of the Utilities' intent to access the land.

14. Role and Responsibilities of Agricultural Monitor

The Agricultural Monitor will be retained and funded by the Utilities, but will report directly to the MDA. The primary function of the Agricultural Monitor will be to audit the Utilities' compliance with this AIMP. The Agricultural Monitor will not have the authority to direct construction activities and will not have authority to stop construction. The Agricultural Monitor will notify the Utilities' Inspector if he/she believes a compliance issue has been identified. The Agricultural Monitor will have full access to Agricultural Land crossed by the CapX2020 projects and will have the option of

attending meetings where construction on Agricultural Land is discussed. Specific duties of the Agricultural Monitor will include, but are not limited to the following:

1. Participate in preconstruction training activities sponsored by the Utilities.
2. Monitor construction and restoration activities on Agricultural Land for compliance with provisions of this AIMP.
3. Report instances of noncompliance to the Utilities Inspector.
4. Prepare regular compliance reports and submit to MDA, as requested by the MDA.
5. Act as liaison between Landowners and Tenants and MDA, if necessary.
6. Maintain a written log of communications from Landowners and/or Tenants regarding compliance with this AIMP. Report Landowner complaints to the Utilities Inspector and/or Right-of-Way representative.
7. In disputes between Utilities and a Landowner and/or Tenant over restoration, determine if agricultural restoration is reasonably adequate in consultation with the Utilities Inspector.

15. Qualifications and Selection of Agricultural Monitor

The Agricultural Monitor will have a bachelor's degree in agronomy, soil science or equivalent work experience. The Agricultural Monitor will have demonstrated practical experience with pipeline or electric transmission line construction and restoration on Agricultural Land. Final selection of the Agricultural Monitor will be a joint decision between the MDA and the Utilities.

16. Role of the Utilities Inspector

The Utilities Inspector will:

1. Be full-time member of the Utilities inspection team.
2. Be responsible for verifying the Utilities compliance with provisions of this AIMP during construction.
3. Work collaboratively with other Utilities Inspectors, Right-of-Way agents, and the Agricultural Monitor in achieving compliance with this AIMP.
4. Observe construction activities on Agricultural Land on a regular basis.
5. Have the authority to stop construction activities that are determined to be out of compliance with provisions of this AIMP.

6. Document instances of noncompliance and work with construction personnel to identify and implement appropriate corrective actions as needed.
7. Provide construction personnel with training on provisions of this AIMP before construction begins.
8. Provide construction personnel with field training on specific topics as needed.

Appendix A: **Definitions**

Agricultural Land	Land that is actively managed for cropland, hayland, or pasture, and land in government set-aside programs.
Agricultural Monitor	Monitor retained and funded by the Utilities, reporting directly to the Minnesota Department of Agriculture (“MDA”) and responsible for auditing the Utilities' compliance with provisions of this AIMP.
Cropland	Land actively managed for growing row crops, small grains, or hay.
Easement	The agreement(s) and/or interest in privately owned Agricultural Land held by the Utilities by virtue of which it has the right to construct, operate and maintain the transmission line together with such other rights and obligations as may be set forth in such agreement.
Final Clean-up	Transmission line activity that occurs after the power line has been constructed. Final Clean-up activities include but are not limited to: removal of construction debris, de-compaction of soil as required, installation of permanent erosion control structures, final grading, and restoration of fences and required reseeding. Once Final Clean-up is finished, Landowners will be contacted to settle all damage issues and will be provided a form to sign confirming final settlement.
Landowner	Person(s) holding legal title to Agricultural Land on the transmission line route from whom the Utilities is seeking, or has obtained, a temporary or permanent Easement, or their representatives.
Non-Agricultural Land	Any land that is not "Agricultural Land" as defined above.
Right-of-Way	The Agricultural Land included in permanent and temporary Easements which the Utilities acquires for the purpose of constructing, operating and maintaining the transmission line.
Tenant	Any Person lawfully renting or sharing land for agricultural production which makes up the "Right-of-Way" as defined in this AIMP.
Tile	Artificial subsurface drainage system.
Topsoil	The uppermost horizon (layer) of the soil, typically with the darkest color and highest content of organic matter.
Utilities Inspector	Full-time on-site inspector retained by the Utilities to verify compliance with requirements of this AIMP during construction of the transmission line. The Inspector will have demonstrated experience with transmission line construction on Agricultural Land.

Appendix B: Mitigative Actions for Organic Agricultural Land

Introduction

The Utilities recognize that Organic Agricultural Land is a unique feature of the landscape and will treat this land with the same level of care as other sensitive environmental features. This Appendix identifies mitigation measures that apply specifically to farms that are Organic Certified or farms that are in active transition to become Organic Certified, and is intended to address the unique management and certification requirements of these operations. All protections provided in the Agricultural Impact Mitigation Plan will also be provided to Organic Agricultural Land in addition to the provisions of this Appendix.

The provisions of this Appendix will apply to Organic Agricultural Land for which the Landowner or Tenant has provided to the Utilities a true, correct and current version of the Organic System Plan within 60 days after the signing of the Easement for such land or 60 days after the issuance of a Route Permit to the Utilities by the PUC, whichever is sooner, or, in the event the Easement is signed later than 60 days after the issuance of the Route Permit. The provisions of this Appendix are applicable when the Organic System Plan is provided to the Utilities at the time of the signing of the Easement.

Organic System Plan

The Utilities recognize the importance of the individualized Organic System Plan (OSP) to the Organic Certification process. The Utilities will work with the Landowner or Tenant, the Landowner or Tenant's Certifying Agent, and/or a mutually acceptable third-party Organic consultant to identify site-specific construction practices that will minimize the potential for Decertification as a result of construction activities. Possible practices may include, but are not limited to: equipment cleaning, planting a deep-rooted cover crop in lieu of mechanical decompaction, applications of composted manure or rock phosphate, preventing the introduction of disease vectors from tobacco use, restoration and replacement of beneficial bird and insect habitat, maintenance of organic buffer zones, use of organic seeds for any cover crop, or similar measures. The Utilities recognizes that Organic System Plans are proprietary in nature and will respect the need for confidentiality.

Prohibited Substances

The Utilities will avoid the application of Prohibited Substances onto Organic Agricultural Land. No herbicides, pesticides, fertilizers or seed will be applied unless requested and approved by the Landowner. Likewise, no refueling, fuel or lubricant storage or routine equipment maintenance will be allowed on Organic Agricultural Land. Equipment will be checked prior to entry to make sure that fuel, hydraulic and lubrication systems are in good working order before working on Organic Agricultural Land. If Prohibited Substances are used on land adjacent to Organic Agricultural Land, these substances will be used in such a way as to prevent them from entering Organic Agricultural Land.

Temporary Road Impacts

Topsoil and subsoil layers that are removed during construction on Organic Agricultural Land for temporary road impacts will be stored separately and replaced in the proper sequence after the transmission line is installed. Unless otherwise specified in the site-specific plan described above, the Utilities will not use this soil for other purposes, including creating access ramps at road crossings. No topsoil or subsoil (other than incidental amounts) may be removed from Organic Agricultural Land. Likewise, Organic Agricultural Land will not be used for storage of soil from non-Organic Agricultural Land.

Erosion Control

On Organic Agricultural Land, the Utilities will, to the extent feasible, implement erosion control methods consistent with the Landowner or Tenant's Organic System Plan. On land adjacent to Organic Agricultural Land, the Utilities' erosion control procedures will be designed so that sediment from adjacent non-Organic Agricultural Land will not flow along the Right-of-Way and be deposited on Organic Agricultural Land. Treated lumber, non-organic hay bales, non-approved metal fence posts, etc. will not be used in erosion control on Organic Agricultural Land.

Weed Control

On Organic Agricultural Land, the Utilities will, to the extent feasible, implement weed control methods consistent with the Landowner's or Tenant's Organic System Plan. Prohibited Substances will not be used in weed control on Organic Agricultural Land. In addition, the Utilities will not use Prohibited Substances in weed control on land adjacent to Organic Agricultural Land in such a way as to allow these materials to drift onto Organic Agricultural Land.

Monitoring

In addition to the responsibilities of the Agricultural Monitor described in the AIMP, the following will apply:

- A. The Agricultural Monitor will monitor construction and restoration activities on Organic Agricultural Land for compliance with the provisions of this appendix and will document any activities that may result in Decertification.
- B. Instances of non-compliance will be documented according to Independent Organic Inspectors Association protocol consistent with the Landowner's Organic System Plan, and will be made available to the MDA, the Landowner, the Tenant, the Landowner's or Tenant's Certifying Agent, the Utilities Inspector and to the Utilities.

If the Agricultural Monitor is responsible for monitoring activities on Organic Agricultural Land, he/she will be trained, at the Utilities' expense, in organic inspection, by the Independent Organic Inspectors Association, unless the Agricultural Monitor received such training during the previous three years.

Compensation for Construction Damages

The settlement of damages will be based on crop yield and/or crop quality determination and the need for additional restoration measures. Unless the Landowner or Tenant of Organic Agricultural Land and Company agree otherwise, at the Utilities expense, a mutually agreed upon professional agronomist will make crop yield determinations, and the Minnesota Department of Agriculture Fruit and Vegetable Inspection Unit will make crop quality determinations. If the crop yield and/or crop quality determinations indicate the need for soil testing, the testing will be conducted by a commercial laboratory that is properly certified to conduct the necessary tests and is mutually agreeable to the Utilities and the Landowner or Tenant. Field work for soil testing will be conducted by a Professional Soil Scientist or Professional Engineer licensed by the State of Minnesota. The Utilities will be responsible for the cost of sampling, testing and additional restoration activities, if needed. Landowners or Tenants may elect to settle damages with the Utilities in advance of construction on a mutually acceptable basis or to settle after construction based on a mutually agreeable determination of actual damages.

Compensation for Damages Due to Decertification

Should any portion of Organic Agricultural Land be Decertified as a result of construction activities, the settlement of damages will be based on the difference between revenue generated from the land affected before Decertification and after Decertification so long as a good faith effort is made by the Landowner or Tenant to regain Certification.

Definitions

Unless otherwise provided to the contrary in this Appendix, capitalized terms used in this Appendix shall have the meanings provided below and in the AIMP. In the event of a conflict between this Appendix and the AIMP with respect to definitions, the definition provided in this Appendix will prevail but only to the extent such conflicting terms are used in this Appendix. The definition provided for the defined words used herein shall apply to all forms of the words.

Apply	To intentionally or inadvertently spread or distribute any substance onto the exposed surface of the soil.
Certifying Agent	As defined by the National Organic Program Standards, Federal Regulations 7 CFR Part 205.2.
Decertified or Decertification	Loss of Organic Certification.
Organic Agricultural Land	Farms or portions thereof described in 7 CFR Parts 205.100, 205.202, and 205.101.
Organic Buffer Zone	As defined by the National Organic Program Standards, Federal Regulations 7 CFR Part 205.2.
Organic Certification or Organic Certified	As defined by the National Organic Program Standards, Federal Regulations 7 CFR Part 205.100 and 7 CFR Part 205.101.
Organic System Plan	As defined by the National Organic Program Standards, Federal Regulations 7 CFR Part 205.2.
Prohibited Substance	As defined by the National Organic Program Standards, Federal Regulations 7 CFR Part 205.600 through 7 CFR 205.605 using the criteria provided in 7 USC 6517 and 7 USC 6518.

Appendix J – Minnesota Route Modifications:

1. Analysis of Route Option eFiled by Xcel Entered into Minnesota Public Utilities Commission Docket 09-1448 August 2, 2011
2. Proposed Modification to Route 3B-003, included with Hillstrom Testimony April 18, 2011, Minnesota Public Utilities Commission Docket 09-1448



Minnesota Highway 19/US Highway 52 Intersection Options

Existing Transmission

- Substation
- 115 kV Transmission Line
- 161 kV Transmission Line
- 345 kV Transmission Line

Route Corridor

- Proposed 1000' Route Corridor

Project Features

- Residence (Barr)
- Modified Preferred Route (US 52) Segment
- Alternate Route Segment
- HWY 19 Interchange Infield Alternative Segment

— MinDOT Hwy 52 ROW

— MinDOT Conceptual Layout

★ Segment Convergence Points



DATA SOURCES: SANDR, B.TS, L.M.C., B.M. M/DOT
 PLANNING DIVISION Highway 52 Intersection, 11/02/22
 MAP LOCATION: P:\2021\180025.DWG, CAPX2025 Layout\Map\CapX2025 Hwy52
 PDF LOCATION: P:\2021\180025.DWG, CAPX2025 Maps\Map\CapX2025 Hwy52



Minnesota 19/Highway 52 Intersection Options

Resource Category	Modified Preferred Route (US 52) Segment	Alternate Route Segment	Highway 19 Interchange Infield Alternative Segment
Residences			
Number of Residences 0-75 feet from route centerline	0	0	0
Number of Residences 76-150 feet from route centerline	2	0	0
Number of Residences 151-300 feet from route centerline	4	13	3
Number of Residences 301-500 feet from route centerline	23	7	24
Number of Residences 0-300 feet from route centerline	6	13	3
Number of Residences 0-500 feet from route centerline	29	20	27
Revised Density (residences/linear mile within 300 feet of route centerline)	0.1	0.2	0.1
Revised Density (residences/linear mile within 500 feet of route centerline)	0.5	0.4	0.5
Use or Paralleling of existing ROW (transportation, pipeline, and electrical transmission systems) and property lines			
Total length (miles)	0.8 miles	1.0 mile	0.8 miles
Length following Transmission Line (miles)	0.0 miles	0 miles	0 miles
Percentage of route following Transmission Line	0%	0%	0%
Length following road but not Transmission Line (miles)	0.6 miles	0 miles	0.6 miles
Percentage of route following road but not Transmission Line	75%	0%	75%
Length following property line but not transmission line or roads (miles)	0 miles	0 miles	0 miles
Percentage of route following property line but not transmission line or roads	0%	0%	0%
Total length following transmission line, roads, or property lines (miles)	0.6 miles	0 miles	0.6 miles
Percentage of route following transmission line, roads or property lines	75%	0%	75%
Length not following transmission line, roads or property lines (miles)	0.2 miles	1.0 mile	0.2 miles
Percentage of route not following transmission line, roads or property lines	25%	100%	25%
Archaeological and Historic Resources Sites Within 1 mile of Route Centerline			

Minnesota 19/Highway 52 Intersection Options

Resource Category	Modified Preferred Route (US 52) Segment	Alternate Route Segment	Highway 19 Interchange Infield Alternative Segment
Archaeological	2	2	2
Architectural			
National Register of Historic Places (NRHP)	8	8	8
Architectural	5	5	5
Natural Environment			
Water Resources			
Permanent Wetlands Impacts	0 acres	0 acres	0 acres
Temporary Wetlands Impacts	0 acres	0 acres	0 acres
Potential Tree Clearing in Wetlands	0 acres	0 acres	0 acres
Stream Crossings	0	0	0
Permanent Impacts to Floodplains	<0.02 acre	<0.02 acre	<0.02 acre
Flora			
Percent Cropland	40.3%	72.1%	38.2%
Percent Grassland	59.3%	17.7%	61.4%
Percent Shrubland	0%	0%	0%
Percent Forested Land	0.4%	10.2%	0.4%
Percent Aquatic	0%	0%	0%
Fauna			
Conservation Reserve Program Lands Crossed	0	0	0
Conservation Reserve Enhancement Program Lands Crossed	0	0	0
Length of Important Bird Areas Crossed	0 miles	0 miles	0 miles
Length of Grassland Bird Conservation Areas Crossed	0 miles	0 miles	0 miles
Number of Federal Rare and Unique Species Known to Occur Within 1 mile of Route Centerline			
Threatened	0	0	0
Endangered	0	0	0
Candidate	0	0	0
Number of State Rare and Unique Species Known to Occur Within 1 mile of Route Centerline			
Threatened	3	3	3
Endangered	0	0	0
Species of Concern	1	1	1
DNR Rare Native Communities	7	10	7
Length of Outstanding Biodiversity Sites Crossed	0 miles	0 miles	0 miles
Length of High Biodiversity Sites Crossed	0 miles	0 miles	0 miles
Length of Moderate Biodiversity Sites Crossed	0 miles	0 miles	0 miles

Kellogg

Belvidere Ave

Dodge St

Legend

Project Features

- Conceptual Alignment
- Highway 42 Segment


Expanded Route Width

Transportation

- Interstate Highway
- US Highway
- State Highway



Sheet Map Index




Data Sources: MNDNR, BTS, LMIC
Hwy35_Sheetmap
P:12007071800_25_CAPXGISLayouts\Applications\MN\Sheetmaps
P:12007071800_25_CAPXGISMaps\Applications\WN\Sheetmaps

Aerial Photography Published by
National Agriculture Imagery Program (NAIP), 2010



Appendix K – Visual Simulations, MN and WI Great River Road



CapX2020

Hampton • Rochester • La Crosse 345 kV Transmission Project


Xcel Energy • Dairyland Power Cooperative • Rochester Public Utilities • WPPI Energy • Southern Minnesota Municipal Power Agency

MN Great River Road
 Photosimulation Location Map



Existing Condition

Photopoint 1 - Southbound Great River Road looking southeast. Looking southeast at the Highway 42 Route Segment.



Proposed Condition

Photopoint 1 - Southbound Great River Road looking southeast. Looking southeast at the Highway 42 Route Segment.

Hampton ▪ Rochester ▪ La Crosse 345 kV Transmission Project



Existing Condition

Photopoint 2 - Southbound Great River Road. Looking southeast at the Alternative 345 kV Route.



Proposed Condition

Photopoint 2 - Southbound Great River Road. Looking southeast at the Alternative 345 kV Route.



Photopoint 3 - Southbound Great River Road. Looking southeast at the Alternative 345 kV Route.



Photopoint 3 - Southbound Great River Road. Looking southeast at the Alternative 345 kV Route.

Hampton ▪ Rochester ▪ La Crosse 345 kV Transmission Project



Existing Condition

Photopoint 3 - Southbound Great River Road. Looking southeast at the Preferred 345 kV Route.



Proposed Condition

Photopoint 3 - Southbound Great River Road. Looking southeast at the Preferred 345 kV Route.

Proposed Structure Location - Structure is partially obscured by trees



Legend

Project Features

- Existing Substation
- Photo Simulation Points

Proposed Alternative Routes

- Q1-Highway 35 Route

Landscape Conditions

- Agricultural
- Bluffs and Blufflands
- Mississippi River and Riparian Areas
- Towns

Scenic Byways
(Census/Digitized EDAW)

- Scenic Byway

Land Cover
(WISCLAND)

- Aquatic
- Urban
- Forest
- Grassland
- Cropland
- Shrubland
- Barren

0 2 4 Miles

Map Vicinity

DATA SOURCES: MNDNR, WDNR, BTS, USGS
 FILENAME: GRR_Landcover_Landscape_101101
 MXD LOCATION: P:\2007\07180025.00_CAPX\GIS\Layouts\Great_River_Assessment
 PDF LOCATION: P:\2007\07180025.00_CAPX\GIS\Maps\Great_River_Assessment

CapX2020

Hampton • Rochester • La Crosse 345 kV Transmission Project

Xcel Energy • Dairyland Power Cooperative • Rochester Public Utilities • WPPI Energy • Southern Minnesota Municipal Power Agency

Landscape Conditions
November 2010

Figure 2: Landscape Conditions



Existing Condition

Photopoint 70 - Buena Vista Park above Alma, WI, looking southwest. The existing double circuit 161 kV transmission line crosses the Mississippi River and Great River Road (WIS 35) at the Dairyland Alma Generation Facility.



Proposed Condition

Photopoint 70 - Buena Vista Park above Alma, WI, looking southwest. The existing transmission line would be rebuilt as a triple-circuit 161 kV / 161 kV / 345 kV transmission line.


Public Service Commission of Wisconsin
REGISTRATION: 06/29/11, 9:52:52 AM

Existing Condition



Photopoint 76 - Bluff side pull out, 1.5 miles south of Dairyland's Alma power plant. Looking northwest. Existing Dairyland 161kV line is on right side of photo behind screen of trees, paralleling Great River Road.

Proposed Condition



Photopoint 76 - Bluff side pull out, 1.5 miles south of Dairyland's Alma power plant. Looking northwest. Existing Dairyland 161kV line rebuilt to 345 / 161 kV double circuit on right side of photo paralleling Great River Road. Designed specifically to allow screen of trees to remain.



Existing Condition

Photopoint 76 - Bluff side pull out, 1.5 miles south of Dairyland's Alma power plant. Looking southeast. Existing Dairyland 161 kV line is on left side of photo behind screen of trees, paralleling Great River Road.



Proposed Condition

Photopoint 76 - Bluff side pull out, 1.5 miles south of Dairyland's Alma power plant. Looking southeast. Existing Dairyland 161 kV line rebuilt to 345 / 161 kV double circuit on left side of photo paralleling Great River Road. Designed specifically to allow screen of trees to remain.



Existing Condition

Photopoint 174 - 2.0 miles southeast of Dairyland's Alma power plant, looking southeast. The existing Dairyland Q1 161 kV transmission line crosses the Great River Road (WIS 35) at the Dairyland Power Road intersection.



Proposed Condition

Photopoint 174 - 2.0 miles southeast of Dairyland's Alma power plant, looking southeast. The existing Dairyland Q1 161 kV transmission line would be rebuilt as a double-circuit 161 kV / 345 kV transmission line.



Existing Condition

Photopoint 189 - 0.6 miles northwest of County Road 00. Looking northwest.



Proposed Condition

Photopoint 189 - 0.6 miles northwest of County Road 00. Looking northwest.



Existing Condition

Photopoint 77 - Lizzy Pauls Pond picnic area, leaf off condition in winter. 3 miles south of the Dairyland's Alma power plant. Looking west. The existing Dairyland 161 kV transmission line parallels the railroad 0.25 miles west of the Great River Road.



Proposed Condition

Photopoint 77 - Lizzy Pauls Pond picnic area, leaf off condition in winter. 3 miles south of the Dairyland's Alma power plant. Looking west. The existing Dairyland 161 kV transmission line would be rebuilt as a double-circuit 161kV / 345kV transmission line.



Existing Condition

Photopoint 77 - Lizzy Pauls Pond picnic area, leave on condition. 3 miles south of Dairyland's Alma power plant. Looking west. The existing Dairyland 161 kV line parallels the railroad 0.25 miles west of Great River Road.



Proposed Condition

Photopoint 77 - Lizzy Pauls Pond picnic area, leave on condition in summer. 3 miles south of Dairyland's Alma power plant. Looking west. The existing Dairyland Q1 161 kV transmission line would be rebuilt as a double-circuit 161 kV / 345 kV transmission line.



Photopoint 190 - Highway 35 at Foegen Road. Looking Southwest.



Photopoint 190 - Highway 35 at Foegen Road. Looking Southwest.



Existing Condition

Photopoint 188 - Highway 35 at Seifert Hill Lane. Looking south. Three existing transmission lines and one distribution line along Great River Road.



Proposed Condition

Photopoint 188 - Highway 35 at Seifert Hill Lane. Looking south. Proposed project crosses the road on the existing 161 kV alignment

Existing Condition



Photopoint 169 - 1 mile north of Cochrane, looking northwest. Existing Dairyland Q1 161kV transmission line parallels the Great River Road.

Proposed Condition



Photopoint 169 - 1 mile north of Cochrane, looking northwest. Existing Dairyland Q1 161kV transmission line would be rebuilt as a double circuit 161 / 345 kV transmission line.



Existing Condition

Photopoint 65 - One-half mile south of Cochrane looking northwest. . The existing Dairyland Q1 161 kV transmission line parallels the Great River Road (WI-35)



Proposed Condition

Photopoint 65 - One-half mile south of Cochrane looking northwest. The existing Dairyland Q1 161 kV transmission line would be removed from the Scenic Easement area on the bluff side of the GRR and rebuilt as a double-circuit 161 / 345 kV transmission on the River side of the GRR where no scenic easements exist.



Photopoint 191 - 0.25 mile southwest of Wisconsin St., Cochrane. Looking Southwest. Three existing transmission lines along Great River Road: 161 kV on far left, 69 kV on left side of road, 69 kV on far right.



Photopoint 191 - 0.25 mile southwest of Wisconsin St., Cochrane. Looking Southwest. The existing Dairyland Q1 161 kV transmission line would be removed from the Scenic Easement area on the bluff side of the GRR and rebuilt as a double-circuit 161 / 345 kV transmission line on the River side of the GRR where no scenic easements exist. In the distance, the route follows the railroad and would remove existing transmission lines from the GRR.



Existing Condition

Photopoint 166 - 1.5 miles south of Cochrane, looking northwest. Three transmission lines parallel Great River Road: Xcel 69kV, Dairyland 69 kV and Dairyland 161 kV.



Proposed Condition

Photopoint 166 - 1.5 miles south of Cochrane, looking northwest. Proposed 345 kV line and existing Dairyland 161 kV consolidated west of road with existing Xcel 69 kV. Dairyland 69 kV removed. The proposed consolidates all transmission lines along the Great River Road.

Existing Condition



Photopoint 79 - View looking west from Cochrane / Fountain City High School. Leaf off condition in winter. The existing Dairyland Q-1 161 kV line parallels the Great River Road (WI-35).

Proposed Condition



Photopoint 79 - View looking west from Cochrane / Fountain City High School. Leaf off condition in winter. The existing Dairyland 161 kV line would be moved 0.5 miles west of Great River Road along a railroad track and consolidated with a proposed 345 kV line.



Existing Condition

Photopoint 79 - View looking west from Cochrane / Fountain City High School. Leaf on condidion in summer. The existing Dairyland Q-1 161kV line parallels the Great River Road (WI-35)



Proposed Condition

Photopoint 79 - View looking west from Cochrane / Fountain City High School. Leaf on condidion in summer. The existing 161kV line would be moved 0.5 miles west of Great River Road along a railroad track and consolidated with proposed 345 kV line.



Existing Condition

Photopoint 163 - 3.0 miles north of Fountain City at Indian Creek Road. Looking northwest. Existing 161 kV line crosses the Great River Road 1.0 mile north of this location and out of view in this photo.



Proposed Condition

Photopoint 163 - 3.0 miles north of Fountain City at Indian Creek Road. Looking northwest. As part of removing 3.1 miles of existing 161 kV line from scenic easement, the 345 / 161 kV line crossing is moved to this location.



Photopoint 192 - 0.4 miles east of Trempealeau River. Looking west. Existing 161 kV line crosses road.




Photopoint 192 - 0.4 miles east of Trempealeau River. Looking west. H-frames requested by WisDOT to reduce height and visual impact. Also see Photopoint 64.



Existing Condition

Photopoint 64 - Trempealeau River Bridge east of Marshland. Leaf off condition in winter. Looking West. Existing Dairyland 161 kV line parallels Great River Road (WI-35) and ascends the bluff.



Proposed Condition

Photopoint 64 - Trempealeau River Bridge east of Marshland. Leaf off condition in winter. Looking West. Existing Dairyland 161 kV line rebuilt to 345/161 kV double circuit. Shorter H-frame poles reduce visual impacts of road crossing.



Existing Condition

Photopoint 64 - Trempealeau River Bridge east of Marshland. Leaf on condition in winter. Looking West. Existing Dairyland 161 kV line parallels Great River Road (WI-35) and ascends the bluff.



Proposed Condition

Photopoint 64 - Trempealeau River Bridge east of Marshland. Leaf on condition in winter. Looking West. Existing Dairyland 161 kV line rebuilt to 345/161 kV double circuit. Shorter H-frame poles reduce visual impacts of road crossing.



Photopoint 160 - 1.5 miles north of Village of Trempealeau. Looking south. The existing Dairyland Q1 161 kV transmission line crosses the Great River Road (WIS 35).




Photopoint 160 - 1.5 miles north of Village of Trempealeau. Looking south. The existing Dairyland Q1 161 kV transmission line would be rebuilt to a double-circuit 161 kV / 345 kV transmission line.



Existing Condition

Photopoint 93 - Great River Road 1.0 mile east of Black River, looking east.



Structure 201 is on the west bluff approximately 40 feet higher than the floodplain elevation.



Proposed Condition

Photopoint 93 - Great River Road 1.0 mile east of Black River, looking east. 345 / 161 kV line constructed on low profile H-frame structures 350 feet north (right) of road.



Existing Condition

Photopoint 154 - Great River Road (Wis 35) 0.25 mile west of US 53 / WIS 35 interchange. Looking southeast.



Proposed Condition

Photopoint 154 - Great River Road (Wis 35) 0.25 mile west of US 53 / WIS 35 interchange. Looking southeast. Proposed 345 / 161 kV line.



Existing Condition

Photopoint 153 - Briggs Road overpass over US 53. Looking Northwest.



Proposed Condition

Photopoint 153 - Briggs Road overpass over US 53. Looking Northwest. Proposed 345 / 161 kV.